

Reporting Date : 4-Feb-08

17-Sep-07

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

3778500 KWHR.

- KWHR.

4-Feb-08

Total		345.92	million tk.
Cost of the Consumed Fuel (PDB):	Gas	Tk32,772,312	Oil : Tk16,500,771
			Total : Tk49,273,083

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 17:35	to 23:05			
Dhaka	181		1477	117	8%
Chittagong Area	117		395	66	17%
Khulna Area	118		370	62	17%
Rajshahi Area	77		300	50	17%
Comilla Area	46		295	50	17%
Mymensing Area	57		195	33	17%
Sylhet Area	40		165	28	17%
Barisal Area	31		70	12	17%
Rangpur Area	53		135	22	16%
Total	720	(19:00)	3402	440	

Planned Shut- Down	Forced Shut- Down
1) Rangpur GT-(28/12/07)	8) Ashuganj -5(24/01/08)
2) Khulna 60 MW (05/07/06)	9) Meghnaghat GT1,2 & st- (02/02/08)
	10) Haripur SBU Gt-1 & 2 (02/02/08)
	11) NEPC-(02/02/08).
	12) Ashuganj 1 (02/02/08)
	13) Siddhirganj 210 MW (02/02/08)
1) Haripur SBU GT-3 (25/05/05)	
2) Sahjibazar GT-8(29/07/06)	
3) Khulna BMPP -1 (27/08/07)	
4) Ashuganj CCPP St-(20/10/07)	
5) Khulna BMPP -2 (03/12/07)	
6) Raozan unit -2 (24/01/08)	
7) Shahjibazar-4 (14/01/08)	

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to gas shortage, Raozan (210MW) and RPCL (210 MW) were limited to 150 and 160 MW respectively.</p> <p>c) Ashuganj unit -3 tripped at 10:57 due to excitation system problem and was synchronized at 13:03.</p> <p>d) After availability of gas, Sikalbaha steam was synchronized at 16:07.</p> <p>e) Baghabari WMPL unit - 2 & 1 were under shut down from 00:10 (04/02/08) to 02:30 and 02:42 to 05:12 respectively to change air filter</p> <p>f) Mirpur 132/33 KV T2 transformer, Bogra - Serajganj 132 KV line -1, Srimongal - Shahjibazar 132 KV line -2 and Bakulia 132/33 KV T1 transformers were under annual maintenance from 08:30 to 13:36, 09:31 to 16:24, 09:40 to 16:09, and 11:12 to 14:22 respectively.</p> <p>g) Hathazari 132/33 KV T1 transformer is under shut down since 19:42 due to oil leakage at 33 KV side.</p> <p>h) After installation of optical fiber, Hasnabad - Shyampur 132 KV line was switched on at 15:58. Again it is under shut down since 07:16 (04/02/08) due to the same reason.</p> <p>i) Hasnabad 230/132 KV TR1 transformer tripped at 09:30 (04/02/08) showing 'Differential & E/F'.</p>	<p>So about 720 MW (19:00) of load shed was imposed over the whole areas of the National grid.</p> <p>Due to generation shortage, about 50 MW of load shed has been running since morning (04/02/08) over Chittagong and Comilla areas of the national grid.</p>

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle