

**DAILY REPORT**

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	17-Sep-07	Reporting Date : 26-Feb-08
<b>The Summary of Yesterday's (</b>		25-Feb-08	<b>) Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>		
Day Peak Generation :	3261.0	MW	Hour :	10:00	Min Gen. at	4:00	2327 MW
Evening Peak Generation :	3749.2	MW	Hour :	19:30	Max Generation :		3800 MW
E.P. Demand (at gen end) :	3900.0	MW	Hour :	19:30	Max Demand :		3900 MW
Maximum Generation :	3749.2	MW	Hour :	19:30	Shortage :		100 MW
Total Gen. (MKWH) :	72.81	System L/ Factor :		80.91%	Load Shed :		92 MW

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Export from Ghorasal to Ishurdi :-	Maximum	342 MW	at	19:00	Energy	6567000 KWHR.
Import from Ishurdi to Ghorasal :-	Maximum	-	MW	at	-	KWHR.

**Water Level of Kaptai Lake at 6:00 A M of**

Actual :	92.42	Ft.(MSL) ,	Rule curve :	93.45	Ft.( MSL )
Gas Consumed : : PDB	431.64	MMCFt.	Oil Consumed :	PDB	
WMPL	18.62	MMCFt.	SKO :	0	Liter
RPCL	26.38	MMCFt.	HSD :	287956	Liter
NEPC	15.28	MMCFt.	FO :	410366	Liter
CDC (H+M)	114.53	MMCFt.			
Total	606.44	MMCFt.			

Cost of the Consumed Fuel (PDB) : Gas :	Tk31,902,781	Oil :	Tk12,212,549	Total :	Tk44,115,329
---	--------------	-------	--------------	---------	--------------

**Load Shedding & Other Information**

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	17:45	to 21:50			
Dhaka		10		1415	34	2%
Chittagong Area		20		440	13	3%
Khulna Area		49		380	8	2%
Rajshahi Area		14		360	6	2%
Comilla Area		15		290	7	2%
Mymensing Area		9		220	5	2%
Sylhet Area		11		170	10	6%
Barisal Area		9		75	7	9%
Rangpur Area		-		203	2	1%
Total		137	( 19:30 )	3553	92	

**Information of the Generating machines under maintenance**

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Haripur SBU GT-3 (25/05/05) 2) Khulna BMPP -1 (27/08/07) 3) Ashuganj CCPP St-(20/10/07) 4) Khulna BMPP -2 (03/12/07) 5) Raozan unit -1 (19/02/08) 6) Sikalbaha st-(04/02/08)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 137 MW (19:30) of load shed was imposed over the whole area (except Rangpur area) of the National grid.
b) Due to gas limitation, Raozan -2 (210 MW), Ghorasal (755 MW), Haripur SBU (64 MW), RPCL (210MW) and Tongi GT (80 MW) were limited to 90 MW, 570 MW, 44 MW, 150 MW and 75 MW respectively.	
c) Due to gas limitation, Raozan unit -1, Sikalbaha St and barge are under shut down.	
d) Tongi GT (80MW) was shut down at 09:40 due to filter change and was synchronized at 14:32.	
e) After maintenance, Ashuganj unit - 5 was synchronized at 11:44.	
f) After maintenance, Siddhirganj 210 MW was synchronized at 16:15.	
g) After maintenance, Kaptai unit - 1 was synchronized at 20:05.	
h) After annual maintenance, Dohazari - Cox's Bazar 132 KV line -1 and Ashuganj - Shahjibazar 132 KV line -1 were switched on at 16:15 and 15:00 respectively. Again Dohazari - Cox's Bazar 132 KV line -2 is under shut down since 08:10 (26/02/08) due to the same reason.	
i) After dead line checking, Sylhet - Chatak 132 KV line -1 was switched on at 16:27. Again it is under shut down since 08:10 (26/02/08) due to the same reason.	
j) After annual maintenance, Rampura - Ghorasal 230 KV line -1 was switched on at 17:40. Again it is under shut down since 08:20 (26/02/08) due to the same reason.	
k) After installation of optical fiber, Comilla (N) - Ashuganj 230 KV line -1 was switched on at 15:51. Again it is under shut down since 07:08 (26/02/08) due to the same reason.	
l) Hasnabad - Meghnaghat 230 KV line -2 was under shut down from 10:55 to 14:32 due to red-hot maintenance of wave trap joint at Hasnabad S/S end.	

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle