

DAILY REPORT

Reporting Date : 2-Jun-08
17-Sep-07

Till now the maximum generation is :-

4130.0 MW at 20:00

on

The Summary of Yesterday's (1-Jun-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3137.7	MW	Hour : 11:00	Min Gen. at 6:00	3070 MW
Evening Peak Generation :	3262.8	MW	Hour : 20:00	Max Generation :	3320 MW
E.P. Demand (at gen end) :	4400.0	MW	Hour : 20:00	Max Demand :	4450 MW
Maximum Generation :	3278.4	MW	Hour : 21:00	Shortage :	1130 MW
Total Gen. (MKWH) :	73.92	System L/ Factor :	93.95%	Load Shed :	978 MW

EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum	252 MW	at 20:00	Energy	5379000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	-	MW at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:00 A M of

2-Jun-08

Actual : 70.70	Ft.(MSL) ,	Rule curve : 76.26	Ft.(MSL)
----------------	------------	--------------------	------------

Oil Consumed :

PDB :	SKO :	0	Liter
	HSD :	411053	Liter
	FO :	75504	Liter

Gas Consumed : Total 631.10 MMCFt.

Cost of the Consumed Fuel (PDB) : Gas :	Tk36,180,231	Oil :	Tk11,309,792	Total :	Tk47,490,023
---	--------------	-------	--------------	---------	--------------

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	18:30	to 00:00			
Dhaka		310		1616	364	23%
Chittagong Area		185		480	132	28%
Khulna Area		135		415	117	28%
Rajshahi Area		80		375	104	28%
Comilla Area		55		282	76	27%
Mymensing Area		75		217	58	27%
Sylhet Area		65		170	47	28%
Barisal Area		7		70	19	27%
Rangpur Area		72		225	61	27%
Total		984	(20:00)	3850	978	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Sikalbaha St -(08/05/08) 9) Ashuganj -3 (13/05/08) 10) Tongi GT (21/05/08) 11) RPCL -1 (22/05/08) 12) Ghorsal 3 (30/05/08) 13) Ashuganj -4 (30/05/08) 14) Ashuganj CAPP GT-1(01/06/08)
	1) Haripur SBU GT-3 (25/05/05) 2) Ashuganj CAPP St-(20/10/07) 3) Shahjibazar -2 (19/05/08) 4) Kaptai unit-3 (19/04/08) 5) Bheramara -2 (18/04/08) 6) 4 units of KPCL 7) Raozan 2 -(18/05/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 984 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW) and Siddhirganj (190 MW) were limited to 120 MW, 158 MW, 180 MW respectively	
c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) Fenchuganj CAPP GT-1 and steam were synchronized at 06:48 and 09:55 respectively. Again GT-2 was shut down at 11:15 due to combined mode and was synchronized at 11:57.	
e) After maintenance, Khulna 110 MW was synchronized at 19:10.	
f) Thakurgaon - Purbasadipur 132 KV line -1 was under shut down from 09:55 to 19:40 due to replacement of PT at Thakurgaon S/S end.	
	Due to generation shortage, about 200 MW of load shed has been running since morning (02/06/08) over the whole area of the national grid.

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle