

**DAILY REPORT**

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 4-Jun-08 17-Sep-07
<b>The Summary of Yesterday's ( 3-Jun-08 )</b>		<b>Generation &amp; Demand</b>			<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>	
Day Peak Generation :	3280.0	MW	Hour :	12:00	Min Gen. at 6:00	3006 MW
Evening Peak Generation :	3376.2	MW	Hour :	19:30	Max Generation :	3539 MW
E.P. Demand (at gen end) :	4400.0	MW	Hour :	19:30	Max Demand :	4400 MW
Maximum Generation :	3376.2	MW	Hour :	19:30	Shortage :	861 MW
Total Gen. (MKWH) :	72.66	System L/ Factor :		89.67%	Load Shed :	732 MW

<b>EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR</b>					
Export from Ghorasal to Ishurdi :-	Maximum	280 MW	at	18:00	Energy 4933500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at -	Energy - KWHR.
Water Level of Kaptai Lake at 6:00 A M of 4-Jun-08					
Actual :	70.27	Ft.(MSL) ,	Rule curve :	76.78	Ft.( MSL )

Oil Consumed :			
PDB :	SKO :	0	Liter
	HSD :	325348	Liter
	FO :	408101	Liter

<b>Gas Consumed : Total</b>	<b>657.50</b>	<b>MMCFt.</b>					
Cost of the Consumed Fuel (PDB) : Gas :			Tk37,590,493	Oil :	Tk13,131,770	Total :	Tk50,722,263

**Load Shedding & Other Information**

Area	Yesterday			Today			
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to 00:00				
Dhaka		211		1570	261	17%	
Chittagong Area		203		470	104	22%	
Khulna Area		93		400	87	22%	
Rajshahi Area		103		360	77	21%	
Comilla Area		70		275	58	21%	
Mymensing Area		68		215	49	23%	
Sylhet Area		59		166	37	22%	
Barisal Area		30		68	15	22%	
Rangpur Area		33		215	44	20%	
Total		870	( 19:30 )	3739	732		

**Information of the Generating machines under maintenance**

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Sikalbaha St -(08/05/08) 9) Ashuganj -3 (13/05/08) 10) Tongi GT ( 21/05/08) 11) RPCL -1 (22/05/08) 12) Ghorsal 3 (30/05/08)
	1) Haripur SBU GT-3 (25/05/05) 2) Ashuganj CCPP St-(20/10/07) 3) Shahjibazar -2 (19/05/08) 4) Kaptai unit-3 (19/04/08) 5) Bheramara -2 (18/04/08) 6) 4 units of KPCL 7) Raozan 2 -(18/05/08)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 870 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan (180 MW ) , RPCL ( 210 MW ) and Siddhirganj (190 MW ) were limited to 120 MW, 160 MW, 180 MW respectively	
c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) Haripur SBU GT-2 was shut down at 15:08 due to gas limitation.	
e) After maintenance, Ashuganj CCPP GT-2 was synchronized at 16:26.	
f) Khulna Rental Power (new) Plant was synchronized at 21:45.	
g) After maintenance, Ashuganj unit - 4 was synchronized at 02:17 (04/06/08)	
h) Khulna Central - Noapara 132 KV line -1 tripped at 11:20 showing ' DIST & E/F' . At the same time, KPCL units also tripped due to voltage fluctuation and was synchronized at 11:27. After inspection and maintenance, the line was switched on at 19:21.	
i) Rangpur - Lalmonirhat 132 KV line was under shut down from 10:58 to 15:40 due to CVT replacement at Lalmonirhat S/S end.	
j) Hasnabad - Shitalakha 132 KV line was under shut down from 13:40 to 15:22 due to CVT replacement at Shitalakha S/S end by DESA.	
k) Bottail 132/33 KV T1 and T2 transformers tripped at 19:40 showing ' Over current' and were switched on at 19:42.	Power interruption occurred (65 MW) under Bottail S/S areas for 2 minutes.
	Due to generation shortage, about 100 MW of load shed has been running since morning (04/06/08) over the whole area of the national grid.

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle