

DAILY REPORT

Till now the maximum generation is :-				4130.0 MW	at	20:00	on	Reporting Date : 8-Jun-08 17-Sep-07	
The Summary of Yesterday's (7-Jun-08) Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	3241.0	MW	Hour :	11:00	Min Gen. at	6:00	2971 MW		
Evening Peak Generation :	3527.1	MW	Hour :	19:30	Max Generation :	3615 MW			
E.P. Demand (at gen end) :	4200.0	MW	Hour :	19:30	Max Demand :	4300 MW			
Maximum Generation :	3527.1	MW	Hour :	19:30	Shortage :	685 MW			
Total Gen. (MKWH) :	76.62	System L/ Factor :	90.51%		Load Shed :	589 MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from Ghorasal to Ishurdi :- Maximum				330 MW	at	20:00	Energy	6451500 KWHR.	
Import from Ishurdi to Ghorasal:- Maximum				-	MW	at -	Energy	-	KWHR.
Water Level of Kaptai Lake at 6:00 A M of				8-Jun-08					
Actual :	70.50	Ft.(MSL) ,		Rule curve :	77.82	Ft.(MSL)			
Oil Consumed :									
PDB					SKO :	0		Liter	
					HSD :	183403		Liter	
					FO :	724446		Liter	
Gas Consumed : Total		681.29	MMCFt.						
Cost of the Consumed Fuel (PDB) : Gas :			Tk39,706,387	Oil :	Tk13,335,265	Total :	Tk53,041,652		

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	18:30	to 00:00			
Dhaka		185		1570	218	14%
Chittagong Area		128		461	82	18%
Khulna Area		45		392	69	18%
Rajshahi Area		65		355	63	18%
Comilla Area		40		273	49	18%
Mymensing Area		50		209	37	18%
Sylhet Area		30		163	29	18%
Barisal Area		10		67	12	18%
Rangpur Area		25		206	30	15%
Total		578	(19:30)	3696	589	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Haripur SBU GT1(05/06/08) 10) Haripur SBU GT2(03/06/08)
	1) Ashuganj CCPP St-(20/10/07) 2) Shahjibazar -2 (19/05/08) 3) Kaptai unit-3 (19/04/08) 4) 4 units of KPCL 5) Raozan1 -(06/06/08) 6) Sikalbaha St -(08/05/08) 7) Ashuganj -3 (13/05/08) 8) RPCL -1 (22/05/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 578 MW (19:30) of load shed was imposed over the whole area (except Barisal) of the national grid.
b) Due to gas limitation, Raozan (180 MW) , RPCL (210 MW) and Siddhirganj (190 MW) were limited to 120 MW, 160 MW, 120 MW respectively	
c) Due to gas limitation, Haripur SBU -1 & 2, Raozan -1, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down	
d) Sylhet GT tripped at 20:05 showing ' over loaded oil fire alarm' ans was synchronized at 00:30 (08/06/08). But it tripped again at 00:45 showing ' auxiliary motor over load' and was synchronized at 07:30.	
e) Aftre maintenance, Ghorasal unit - 3 was synchronized at 03:15 (08/06/08).	
f) Aminbazar 230/132 KV T2 transformer was under shut down from 09:14 to 14:47 due to fire fighting test.	
g) Ashuganj - Shahjibazar 132 KV line -1 was under shut down from 10:25 to 18:15 for maintenance.	
h) Faridpur 132/33 KV T1 and T2 tripped at 12:38 showing ' E/F ' due to 33 KV Magura feeder fault and were switched on at 12:41.	Power interruption occurred (25 MW) under Faridpur S/S areas for 3 minutes.

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle