

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 9-Jun-08 17-Sep-07
The Summary of Yesterday's (8-Jun-08)		Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3373.5	MW	Hour :	10:00	Min Gen. at 6:00	2922 MW
Evening Peak Generation :	3516.8	MW	Hour :	19:30	Max Generation :	3490 MW
E.P. Demand (at gen end) :	4300.0	MW	Hour :	19:30	Max Demand :	4300 MW
Maximum Generation :	3516.8	MW	Hour :	19:30	Shortage :	810 MW
Total Gen. (MKWH) :	78.39	System L/ Factor :		92.88%	Load Shed :	695 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :-	Maximum	300 MW	at 1:00	Energy	5758500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of 9-Jun-08					
Actual :	70.50	Ft.(MSL) ,	Rule curve :	78.08	Ft.(MSL)

Oil Consumed :			
PDB	SKO :	0	Liter
	HSD :	380575	Liter
	FO :	739377	Liter

Gas Consumed : Total	671.94	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas :			Tk39,199,964	Oil :	Tk18,504,881	Total : Tk57,704,846

Load Shedding & Other Information

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to	00:00				MW
Dhaka		199			1562	260	17%	
Chittagong Area		131			461	97	21%	
Khulna Area		71			392	81	21%	
Rajshahi Area		60			355	73	21%	
Comilla Area		36			273	57	21%	
Mymensing Area		57			209	43	21%	
Sylhet Area		44			163	34	21%	
Barisal Area		15			67	14	21%	
Rangpur Area		59			206	36	17%	
Total		672	(19:30)	3688	695		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Haripur SBU GT1(05/06/08) 10) Haripur SBU GT2(03/06/08)
	1) Ashuganj CCPP St-(20/10/07) 2) Shahjibazar -2 (19/05/08) 3) Kaptai unit-3 (19/04/08) 4) 4 units of KPCL 5) Raozan1 -(06/06/08) 6) Sikalbaha St -(08/05/08) 7) Ashuganj -3 (13/05/08) 8) RPCL -1 (22/05/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 672 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW) , RPCL (210 MW) and Siddhirganj (190 MW) were limited to 690 MW, 100 MW, 126 MW and 100 MW respectively	
c) Due to gas limitation, Haripur SBU -1 & 2, Raozan -1, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down	
d) After maintenance, Barapukuria unit -1 was synchronized at 16:12.	
e) Ashuganj Steam unit -1 was forced shut down at 00:42 (09/06/08) due to boiler tube leakage.	
f) Kulshi 132/33 KV T3 transformer was under shut down from 08:32 to 10:55 due to maintenance work .	
g) Aminbazar 230/132 KV T1 transformer was under shut down from 09:36 to 14:18 for project work.	
	Due to generation shortage, about 150 MW of load shed has been running since morning (09/06/08) over the whole area of the national grid.

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle