

DAILY REPORTReporting Date : 14-Jun-08
17-Sep-07

Till now the maximum generation is :-

4130.0 MW at 20:00

on

The Summary of Yesterday's (13-Jun-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3215.0	MW	Hour : 10:00	Min Gen. at 6:00	3045 MW
Evening Peak Generation :	3285.8	MW	Hour : 20:00	Max Generation :	3421 MW
E.P. Demand (at gen end) :	4200.0	MW	Hour : 20:00	Max Demand :	4300 MW
Maximum Generation :	3300.8	MW	Hour : 21:00	Shortage :	879 MW
Total Gen. (MKWH) :	75.06	System L/ Factor :	94.76%	Load Shed :	737 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	306 MW	at 22:00	Energy	5362500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of		14-Jun-08			
Actual :	69.77	Ft.(MSL) ,	Rule curve :	79.68	Ft.(MSL)

Oil Consumed :

PDB	SKO :	0	Liter
	HSD :	102679	Liter
	FO :	740806	Liter

Gas Consumed : Total 632.39 MMCFt.

Cost of the Consumed Fuel (PDB) : Gas : Tk42,289,005 Oil : Tk11,488,485 Total : Tk53,777,491

Load Shedding & Other Information

Area	Yesterday				Today				
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)		Estimated Shedding (s/s end)		Rates of Shedding (On Estimated Demand)
	from	18:30	to	6:30					
Dhaka		232				MW		MW	
Chittagong Area		200				1538		289	
Khulna Area		69				440		93	
Rajshahi Area		81				380		83	
Comilla Area		35				345		75	
Mymensing Area		39				260		55	
Sylhet Area		46				205		46	
Barisal Area		10				158		35	
Rangpur Area		50				65		14	
						210		47	
Total		762	(20:00)	3601		737	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Haripur SBU GT-1 (05/06/08) 10) Haripur SBU GT-2 (03/06/08) 11) Ghorasal -1 (10/06/08) 12) Bheramara -3 (09/06/08) 13) Baghabari 100 (13/06/08) 14) Kaptai 1 & 2 (13/06/08)
	1) Ashuganj CCPP ST-(20/10/07) 2) Shahjibazar -2 (19/05/08) 3) Kaptai-3(19/04/08) 4) 4 units of KPCL 5) Raozan -1 (06/06/08) 6) Sikalbaha St- (08/05/08) 7) Ashuganj -3 (13/05/08) 8) RPCL 1(22/05/8)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 762 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW), Raozan (180 MW), RPCL (21 MW) and Siddhirganj (190 MW) were limited to 700 MW, 110 MW, 155 MW and 100 MW respectively.	
c) Due to gas limitation, Sikalbaha St & Barge, Haripur SBU 1 & 2, Raozan -1 and Shahjibazar -2 were under shut down.	
d) Shahjibazar unit -9 tripped at 16:09 showing ' Inlet guide van control trouble' . It may be synchronized before evening peak hour today.	
e) Fenchuganj CCPP GT-1 and Steam units tripped at 18:08 due to auxiliary failure and were synchronized at 19:31 and 20:51 respectively.	
f) Tongi GT was shut down at 21:47 due to maintenance work by Titas Gas and was synchronized at 11:12.	
g) Ashuganj CCPP GT-2 tripped at 00:32 (14/06/08) due to gas pressure low.	
h) After maintenance, Ashuganj St -2 was synchronized at 02:41 (14/06/08).	
i) Kabirpur 132 KV main bus was shut down at 07:06 due to conductor change.	
j) Kulshi 132 KV main bus was under shut down from 11:26 to 21:20 for project work by Greater Chittagong (Distribution).	Partial power interruption occurred(20 MW) Kulshi S/S areas from 11:26 to 21:20.
k) Mymensingh 132/33 KV T3 transformer was shut down at 12:59 due to maintenance work at 33 KV bus by Distribution Division.	
l) Hathazari - Kaptai 132 KV line -2 was under shut don from 21:58 to 09:24 (14/06/08) due to maintenance work at Kaptai.	
m) After maintenance, Kallyanpur 132/33 KV T1 transformer was switched on at 17:45. Again it was under shut down from 07:15 (14/06/08) to 10:20 due to the same reason.	
n) After installation of optical fiber, Bagerhat - Mongla 132 KV line was switched on at 1:48.	
o) After maintenance, Bottail 132/33 KV T1 transformer was switched on at 20:10.	

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle