DAILY REPORT Page -1 Reporting Date : Till now the maximum generation is 4130.0 MW οn The Summary of Yesterday's (16-.lun-08) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand MW Day Peak Generation 3191.0 10:00 Min Gen. at 2610.4 MW Hour 4:00 **Evening Peak Generation** 3355.7 MW Hour 20:00 Max Generation 3460 MW E.P. Demand (at gen end) 4400.0 MW 20:00 Max Demand 4300 MW Hour Maximum Generation 3416.5 MW Hour 24:00 Shortage 840 MW Total Gen. (MKWH) 75.61 712 MW System L/ Factor 92.22% Load Shed THROUGH EAST-WEST INTERCONNECTOR EXPORT / IMPORT Export from Ghorasal to Ishurdi :- Maximum 6946500 KWHR. 348 MW Energy Import from Ishurdi to Ghorasal:-MW **KWHR** Water Level of Kaptai Lake at 6:00 A M of 17-Jun-08 70.06 Actual Rule curve 80.22 Ft.(MSL) Oil Consumed : PDB SKO 0 Liter HSD 278513 Liter FO 359744 Liter Gas Consumed: Total MMCFt. 649.27 Cost of the Consumed Fuel (PDB): Gas Tk37,680,786 Tk11,366,079 Tk49,046,865 Total **Load Shedding & Other Information** Area Yesterday Today Estimated Shedding (s/s end) Actual Shedding (s/s end), MW Estimated Demand(s/s end) Rates of Shedding ŃΨ (On Estimated Demand) 18:30 01:15 from to Dhaka 250 1550 274 Chittagong Area 140 450 94 21% 80 21% Khulna Area 104 385 74 Rajshahi Area 350 21% 113 57 Comilla Area 54 268 51 205 43 21% Mymensing Area Sylhet Area 68 160 34 21% Barisal Area 30 65 13 20% 75 210 43 20% Rangpur Area Total 885 20:00 3643 712 Information of the Generating machines under maintenance Planned Shut- Down Forced Shut-Down 9) Haripur SBU GT-1 (05/06/08) 1) Ashuganj CCPP ST-(20/10/07) 2) Shahjibazar -4 (22/05/08) 10) Haripur SBU GT-3(13/06/08) 3) Kaptai-3(19/04/08) 11) Ghorasal -1 (10/06/08) 4) 4 units of KPCL 12) Bheramara -3 (09/06/08) 5) Raozan -1 (06/06/08) 6) Sikalbaha St- (08/05/08 7) Ashuganj -3 (13/05/08) 8) RPCL 1(22/05/8) Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) There was generation shortage in the evening peak hour yesterday So about 885 MW (20:00) of load shed was imposed over the whole area of the national grid. b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW), RPCL (210 MW) and Siddhirganj (190 MW) were limited to 700 MW, 100 MW, 157 MW and 105 MW respectively c) Due to gas limitation, Haripur SBU -1 & 3, Raozan -1, Sikalbaha Steam & Barge and Shahjibazar - 4 were under shut down d) Ashuganj CCPP GT-1 tripped at 10:24 due to combustion abnormal and was synchronized at 11:25. Ashugani Steam unit-1 was forced shut down at 12:25 to attend carbon brush and was synchronized e) After maintenance, Khulna 110 MW was synchronized at 20:16. f) After maintenance, Baghabari GT-2 (100 MW) was synchronized at 23:30. g) Baghabari WMPL unit -1 tripped at 01:28 (17/06/08) due to turbinevibration high and was synchronized h) Sylhet GT (20 MW) was forced shut down at 06:05 (17/06/08) due to air filter change. It may be synchronized before evening peak hour today. i) After maintenance, Kabirpur 132 KV main bus was switched on at 18:02

Deputy / Asstt. Manager Manager Load Despatch Division Load Despatch Division

Deputy General Manager Load Despatch Circle