

**DAILY REPORT**

Reporting Date : 27-Jun-08

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	17-Sep-07
<b>The Summary of Yesterday's (</b>		26-Jun-08	<b>) Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>	
Day Peak Generation :	3151.0	MW	Hour :	11:00	Min Gen. at	8:00 3046 MW
Evening Peak Generation :	3210.5	MW	Hour :	19:30	Max Generation :	3312 MW
E.P. Demand (at gen end) :	4350.0	MW	Hour :	19:30	Max Demand :	4100 MW
Maximum Generation :	3229.9	MW	Hour :	24:00	Shortage :	788 MW
Total Gen. (MKWH) :	73.77		System L/ Factor :	95.16%	Load Shed :	664 MW

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Export from Ghorasal to Ishurdi :-	Maximum	330 MW	at	1:00	Energy	6781500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at	-	Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of

Actual :	72.57	Ft.(MSL) ,	Rule curve :	82.92	Ft.( MSL )
----------	-------	------------	--------------	-------	------------

Oil Consumed :

PDB	SKO :	0	Liter
	HSD :	362170	Liter
	FO :	562310	Liter

<b>Gas Consumed : Total</b>	651.22	MMCFt.
Cost of the Consumed Fuel (PDB) : Gas :	Tk38,097,083	Oil : Tk15,914,227 Total : Tk54,011,310

**Load Shedding & Other Information**

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to	07:50				MW
Dhaka		309			1450	232	16%	
Chittagong Area		178			460	123	27%	
Khulna Area		97			370	80	22%	
Rajshahi Area		102			330	67	20%	
Comilla Area		60			250	50	20%	
Mymensing Area		59			194	39	20%	
Sylhet Area		66			148	29	20%	
Barisal Area		30			60	11	18%	
Rangpur Area		71			193	33	17%	
Total		972	(	19:30	)	3455	664	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Haripur SBU GT-1 (05/06/08) 9) Haripur SBU GT-3(13/06/08) 10) Ghorasal -1 (22/06/08) 11) Barapukuria-1 (18/06/08) 12) Kaptai 1 &2-(23/06/08) 13) 1 unit of KPCL
	1) Ashuganj CCPP ST-(20/10/07) 2) Kaptai- 3 (19/04/08) 3) Raozan -2 (19/06/08) 4) Sikalbaha St- (19/06/08) 5) Ashuganj -3 (13/05/08) 6) Shahjibazar GT-8 (24/0608)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 972 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW) , RPCL ( 210 MW ) and Siddhirganj (190 MW) were limited to 710 MW, 90 MW, 105 MW and 100 MW respectively.	
c) Due to gas limitation, Haripur SBU -1, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) Ashuganj unit -2 was forced shut down at 18:05 due to line steam temprature high. It is now under maintenance.	
	Due to generation shortage, about 100 MW of load shed has been running since morning (27/06/08) over the whole areas (except Mymensing and Sylhet areas) of the national grid.

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle