

QF-LDC-08
Page -1

| Description | Forced load shaded / Interrupted Areas |
|---|--|
| a) There was generation shortage in the evening peak hour yesterday. | So about 1030 MW (20:00) of load shed was imposed over the whole areas of the national grid . Due to generation shortage, about 165 MW (09:00) of load shed has been running since morning (02/11/10) over the whole area (except Sylhet) of the national grid. |
| b) Due to low gas pressure Baghabari 100 MW ,RPCL (210 MW) and Tongi GT were limited to 60 MW, 107 MW and 30 MW respectively. | |
| c) After maintenance Kaptai #3 was synchronized at 18:42. | |
| d) After maintenance Baghabari-71 MW was synchronized at 08:21. | |
| e) Khulna QRPP tripped at 08:52 due to tripping of 33 KV feeder and was synchronized at 09:15. | |
| f) Kaptai #5 was shut down at 00:03 for overhauling. | |
| g) Dohazari - Sikalbaha 132 KV line -1 was shut down at 08:43 due to annual maintenance and was switched on at 16:20. | |
| h) Tangail - Kabirpur 132 KV line-1 was shut down at 08:43 due to annual maintenance and was switched on at 16:55 | |
| i) Palashbari 132/33 KV T1 transformer was shut down at 09:56 due to annual maintenance and was switched on at 15:30. | |

Deputy / Asstt. Manager
Network Operation Division

Manager
Network Operation Division

Deputy General Manager
Load Despatch Circle