QF-LDC-08 Page -1

436 MW

Reporting Date: 2-Dec-08 Till now the maximum generation is: - MW at 4130.0 20.00 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW Hour 12:00 Min Gen. at 2220 MW **Evening Peak Generation** 3535 2 1/1/1/ Hour 18:00 Max Generation 3540 MW E.P. Demand (at gen end) 4050.0 MW Hour 18:00 Max Demand 4050 MW Maximum Generation 3535.2 MW 510 MW Hour 18:00 Shortage

81.18% Total Gen. (MKWH) 68.88 System L/ Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum 256 MW 21:00 Energy 3135000 KWHR. Import from Ishurdi to Ghorasal:- Maximum MW Energy KWHR. Water Level of Kaptai Lake at 6:00 A M of 2-Dec-08

84.01 105.99 Ft.(MSL) Actual Ft.(MSL) Rule curve

Gas Consumed: Total 597.87 MMCFt Oil Consumed (PDB): SKO Liter HSD 280844 Liter

FO 494067 Liter

Load Shed

Cost of the Consumed Fuel (PDB): Gas Tk44.188.572 Oil : Tk13.036.968 Tk57 225 540 Total

Load Shedding & Other Information

| Area | Yesterday | | | Today | | | |
|-----------------|-------------------------------|------|---------------|---------------------------|--|------------------------------|-----------------------|
| | Actual Shedding (s/s end), MW | | (s/s end), MW | Estimated Demand(s/s end) | | Estimated Shedding (s/s end) | Rates of Shedding |
| | frtom 1 | 7:05 | 0:11 | MW | | MW | (On Estimated Demand) |
| Dhaka | | 138 | | 1500 | | 106 | 7% |
| Chittagong Area | | 66 | | 445 | | 75 | 17% |
| Khulna Area | | 58 | | 397 | | 67 | 17% |
| Rajshahi Area | | 46 | | 316 | | 53 | 17% |
| Comilla Area | | 44 | | 242 | | 40 | 17% |
| Mymensing Area | | 28 | | 184 | | 31 | 17% |
| Sylhet Area | | 26 | | 147 | | 25 | 17% |
| Barisal Area | | 11 | | 73 | | 12 | 16% |
| Rangpur Area | | 23 | | 155 | | 27 | 17% |
| | | (| | | | | |
| Total | | 440 | 18:00 | 3459 | | 436 | |

Information of the Generating machines under maintenance

| Planned Shut- Down | | Forced Shut- Down |
|----------------------------|---------------------------------|-----------------------------------|
| 1) Khulna 60 MW (05/07/06) | 1) Kaptai- 3 (19/04/08) | 9) Sikalbaha Barge (19/06/08) |
| | 2) Raozan -1 (19/11/08) | 10) Sikalbaha Steam (21/11/08) |
| | 3) Shajibazar-2 (13/07/08) | 11) Haripur SBU GT1 (24/11/08) |
| | 4) Shajibazar-4 (18/10/08) | 12) Ashuganj CCPP GT 2 (27/11/08) |
| | 5) Ghorasal-1 (30/09/08) | 13) Ghorasal - 4 (28/11/08) |
| | 6) Meghnaghat GT-1 (31/10/08) | |
| | 7) Haripur SBU GT-2 (25/11/08) | |
| | 8) Shajibazar-5 (22/11/08) | |

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

- a) There was generation shortage in the evening peak hour yesterday
- b) Due to gas limitation, Sikalbaha Barge & St, Raozan -1, Haripur SBU GT-1& GT-2 and Shahjibazar -2, 4 & 5 are under shut down. c) After maintenance, Shahjibazar GT-9 was synchronized at 15:34. GT-6 was forced shut down at 00:30
- (02/12/08) for emergency maintenance of Carbon brash. d) Siddhirganj 132/33 KV T1 transformer tripped at 08:30 showing 'Inst E/F' due to 33 KV Demra feeder fault Power interruption occurred (54 MW) under Siddhirganj S/S
- and was switched on at 08:35. e) Basundhara - Tongi 132 KV line -1 & 2 were under annual maintenance from 10:54 to 19:38.
- f) After annual maintenance, Madanhat Kaptai 132 KV line -1, Bogra Palashbari 132 KV line -1 and Joydevpur S/S - Ghorasal P/S 132 KV line -1 were switched on at 15:57, 14:48 and 13:37 respectively
- g) After annual maintenance, Ghorasal Rampura 230 KV line -1, Ghorasal Ashuganj 230 KV line -1 and Haripur (S/S) - Haripur Power Ltd. 230 KV line -2 were switched on at 17:36, 16:58 and 12:46 respectively
- h) Haripur Meghnaghat 230 KV line -1 and Haripur Rampura 230 KV line -1 tripped at 14:02 due to burst of B-phase lightning arrester at Haripur S/S. The lines were switched on at 20:50 and 14:14 respectively.
- i) Patuakhali 132/33 KV T3 transformer, Gopalganj 132/33 KV T2 transformer, Fenchuganj Sreemongal 132 KV line -1, Jessore - Jhenidaha 132 KV line -2, Ashuganj - Kishorganj 132 KV line -1 and Mymensing - Jamalpur 132 KV line -1 are under annual maintenance since 07:07 (02/12/08), 07:40, 07:42,09:09, 08:24, and 08:35 respectively.
- j) Ghorasal Ashuganj 230 KV line -1 and Rampura Ghorasal 230 KV line -1 are under annual maintenance since 07:48(02/12/08) and 08:45 respectively

areas for 5 minutes

area of the national grid.

So about 440 MW (18:00) load shed was imposed over the whole

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle