

QF-LDC-08  
Page -1

The Summary of Yesterday's (		7-Dec-08		) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	2819.0	MW	Hour :	9:00	Min Gen. at	4:00	1999 MW		
Evening Peak Generation :	3917.2	MW	Hour :	18:30	Max Generation	:	3920 MW		
E.P. Demand (at gen end) :	3917.2	MW	Hour :	18:30	Max Demand	:	3800 MW		
Maximum Generation :	3917.2	MW	Hour :	18:30	Shortage	:	0 MW		
Total Gen. (MKWH) :	67.49	System L/ Factor	:	71.79%	Load Shed	:	-- MW		

Export from Ghorasal to Ishurdi :- Maximum	360 MW	at 18:30	Energy	5857500 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	-	at -	Energy	- KWHR.

Actual :		83.75	Water Level of Kaptai Lake at 6:00 A M of	8-Dec-08
			Ft.(MSL) ,	Rule curve :
				105.37 Ft.(MSL)

Gas Consumed :	Total	584.13	MMCFt.	Oil Consumed (PDB) :	SKO :	0	Liter
					HSD :	170497	Liter
					FO :	477339	Liter

### Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end) MW	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
	from	-			
Dhaka	-	-	1564	-	-
Chittagong Area	-	-	465	-	-
Khulna Area	-	-	415	-	-
Rajshahi Area	-	-	331	-	-
Comilla Area	-	-	254	-	-
Mymensing Area	-	-	192	-	-
Sylhet Area	-	-	153	-	-
Barisal Area	-	-	77	-	-
Rangpur Area	-	-	162	-	-
		(			
<b>Total</b>	<b>0</b>		<b>3613</b>	<b>0</b>	

[illegible]

Description	Forced load shaded / Interrupted Areas
-------------	--

So no load shed required.

- b) Due to gas limitation, Sikalaha Barge & St, Raozan -1, Haripur SBU GT-2 and Shahjibazar -2, 4, 5 & 6 are under shut down.
- c) Ashuganj - Shahjibazar 132 KV line -2 was under annual maintenance from 09:25 to 13:52.
- d) Chatak 132/33 KV T2 transformer tripped at 09:56 showing ' O/C at A-phase' and was switched on at 10:03.
- e) Comilla (S) 132/33 KV T2 transformer was under shut down from 11:05 to 12:24 due to change of R-phase lightning arrester .
- f) Ishurdi 132/ 33KV T1 transformer was under shut down from 11:46 to 12:27 due to sparking at B-phase loop.
- g) Naogaon 132/33 KV T1 transformer was under shut down from 13:30 to 16:30 due to oil leakage from top cover. Again it was shut down at 20:35 due to the same reason. It is now under inspection and maintenance.

Deputy General Manager  
Load Despatch Circle