

POWER GRID COMPANY OF BANGLADESH LTD.
CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA
DAILY REPORT

QF-LDC-08
Page -1

Till now the maximum generation is :- MW at		4130.0	20:00	Reporting Date : 12-Dec-08
The Summary of Yesterday's (11-Dec-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand
Day Peak Generation :	2068.0	MW	Hour : 9:00	Min Gen. at 4:00 1707 MW
Evening Peak Generation :	3491.6	MW	Hour : 18:30	Max Generation : 3564 MW
E.P. Demand (at gen end) :	3491.6	MW	Hour : 18:30	Max Demand : 3500 MW
Maximum Generation :	3491.6	MW	Hour : 18:30	Shortage : 0 MW
Total Gen. (MKWH) :	55.04	System L/ Factor :	65.68%	Load Shed : -- MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR				
Export from Ghorasal to Ishurdi :- Maximum		280 MW	at 18:30	Energy 4471500 KWHR.
Import from Ishurdi to Ghorasal:- Maximum		-	at -	Energy - KWHR.
Water Level of Kaptai Lake at 6:00 A M of		12-Dec-08		
Actual :	83.62	Ft.(MSL) ,	Rule curve :	105.00 Ft.(MSL)
Gas Consumed : Total 520.02 MMCFt. Oil Consumed (PDB) : SKO : 0 Liter				
HSD : 174320 Liter				
FO : 456364 Liter				
Cost of the Consumed Fuel (PDB) : Gas : Tk38,434,678 Oil : Tk9,888,403 Total : Tk48,323,081				

Load Shedding & Other Information

Area	Yesterday	Estimated Demand(s/s end) MW	Today Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
	Actual Shedding (s/s end), MW from - -			
Dhaka	-	1427	-	-
Chittagong Area	-	395	-	-
Khulna Area	-	352	-	-
Rajshahi Area	-	280	-	-
Comilla Area	-	214	-	-
Mymensing Area	-	162	-	-
Sylhet Area	-	130	-	-
Barisal Area	-	65	-	-
Rangpur Area	-	136	-	-
Total	0	3161	0	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)
	2) Raozan -2 (09/12/08)
	3) Shajibazar-2 (13/07/08)
	4) Shajibazar-4 (18/10/08)
	5) Ghorasal-1 (30/09/08)
	6) Meghnaghat GT-1 (31/10/08)
	7) Haripur SBU GT-2 (25/11/08)
	8) Shajibazar-5 (22/11/08)
	9) Sikalbaha Barge (19/06/08)
	10) Meghnaghat GT-2 - (09/12/08)
	11) Ashuganj - 2 (08/12/08)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was no generation shortage in the evening peak hour yesterday .	So no load shed required.
b) Due to gas limitation, Sikalbaha Barge , Raozan -2, Haripur SBU GT-2 and Shahjibazar -2, 4 , & 5 are under shut down.	
c) Ashuganj CCPP GT-1 was synchronized at 10:11.	
d) Madanhath - Kaptai 132 KV line -1 tripped at 16:40 from Kaptai end showing ' no relay ' and was switched on at 17:10.	
h) After project work , Hasnabad - Meghnaghat 230 KV line -2 was switched on at 21:24.	
i) After project work, Meghnaghat - Haripur 230 KV line -1 was switched on at 21:24. Again it is under shut down since 07:28 (12/12/08) due to the same reason.	
j) Hasnabad 132/33 KV T2 transformer tripped at 21:45 due to burst of lightning arrester and was switched on at 23:35.	
k) Siddhirganj - Ullon 132 KV line -1 tripped at 23:34 from Siddhirganj end showing ' DIST ABC ' and was switched on at 23:49.	
l) Haripur - Rampura 132 KV line -2 tripped at 23:36 from Haripur end showing 'DIST Z-1' and was switched on at 23:57.	
m) Ashuganj - Kishorganj 132 KV line -2 and Gulshan 132/33 KV T1 transformer are under annual maintenance since 07:30 (12/12/08) and 07:52 respectively.	

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle