POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA DAILY REPORT

QF-LDC-08 Page -1

Liter

Reporting Date : 13-Dec-08 Till now the maximum generation is: - MW at 4130.0 20:00 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW 9:00 Hour Min Gen. at 5:00 **Evening Peak Generation** 3500.7 1/1/1/ Hour 18:30 Max Generation 3760 MW E.P. Demand (at gen end) : 3509.7 MW Hour 18:30 Max Demand 3550 MW Maximum Generation 3509.7 MW 18:30 Shortage 0 MW Hour Total Gen. (MKWH) 64.02% Load Shed - MW 53.93 System L/ Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from Ghorasal to Ishurdi :- Maximum 280 MW 18:00 Energy 4900500 KWHR. Import from Ishurdi to Ghorasal:- Maximum MW Energy KWHR.

13-Dec-08

Water Level of Kaptai Lake at 6:00 A M of 83.63 Ft.(MSL) 104.90 Ft.(MSL) Actual : Rule curve :

Gas Consumed: Total 502.80 MMCFt Oil Consumed (PDB): SKO 161887 HSD

Liter FO 459434 Liter

Cost of the Consumed Fuel (PDB): Gas Tk37.161.948 Oil Tk9.610.560 Total Tk46.772.508

Load Shedding & Other Information

Area	Yesterday	Today		
	Actual Shedding (s/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	frtom	MW	MW	(On Estimated Demand)
Dhaka	-	1427	-	-
Chittagong Area	-	395	-	-
Khulna Area	-	352	-	-
Rajshahi Area	-	280	-	-
Comilla Area	-	214	-	-
Mymensing Area	-	162	-	-
Sylhet Area	-	130	-	-
Barisal Area	-	65	-	-
Rangpur Area	-	136	-	-
	(
Total	0	3161	0	

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Sikalbaha Barge (19/06/08)		
	2) Raozan -2 (09/12/08)	10) Meghnaghat GT-2 - (09/12/08)		
	3) Shajibazar-2 (13/07/08)	11) Ashuganj - 1 (12/12/08)		
	4) Shajibazar-4 (18/10/08)			
	5) Ghorasal-1 (30/09/08)			
	6) Meghnaghat GT-1 (31/10/08)			
	7) Haripur SBU GT-2 (25/11/08)			
	8) Shaiibazar-5 (22/11/08)			

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas a) There was no generation shortage in the evening peak hour yesterday So no load shed required.

- b) Due to gas limitation, Sikalbaha Barge , Raozan -2, Haripur SBU GT-2 and Shahjibazar -2, $\,4\,$,
- & 5 are under shut down.
- c) After maintenance Ashuganj unit -2 was synchronized at 14:10. But unit -1 was shut down at 22:25 due to water wall tube leakage.
- d) Kallyanpur 132/33 KV GT-3 transformer was under annual maintenance from 08:13 to 13:09
- e) Hasnabad 230/132 KV AT3 transformer was under annual maintenance from 09:20 to 18:03.
- f) After annual maintenance, Ashuganj Kishorganj 132 KV line -2 and Gulshan 132/33 KV T1 transformer were switched on at 19:44 and 16:33 respectively.

Deputy / Asstt. Manager Load Despatch Division

Load Despatch Division

Deputy General Manager Load Despatch Circle