

**DAILY REPORT**

Till now the maximum generation is :-				4130.0 MW	at	20:00	on	Reporting Date : 30-Apr-08 17-Sep-07	
The Summary of Yesterday's (		29-Apr-08	) Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	3361.0	MW	Hour :	12:00	Min Gen. at	1:00	3490.7 MW		
Evening Peak Generation :	3588.4	MW	Hour :	19:30	Max Generation :	3550 MW			
E.P. Demand (at gen end) :	4600.0	MW	Hour :	19:30	Max Demand :	4600 MW			
Maximum Generation :	3588.4	MW	Hour :	19:30	Shortage :	1050 MW			
Total Gen. (MKWH) :	79.52	System L/ Factor :		92.34%	Load Shed :	876 MW			
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR									
Export from Ghorasal to Ishurdi :- Maximum				360 MW	at	17:00	Energy	7458000 KWHR.	
Import from Ishurdi to Ghorasal:- Maximum				-	MW	at -	Energy	- KWHR.	
Water Level of Kaptai Lake at 6:00 A M of				30-Apr-08					
Actual :	75.41	Ft.(MSL) ,		Rule curve :	82.20	Ft.( MSL )			
Oil Consumed :									
PDB					SKO :	0	Liter		
					HSD :	303533	Liter		
					FO :	412254	Liter		
Gas Consumed : Total		716.81	MMCFt.						
Cost of the Consumed Fuel (PDB) : Gas :			Tk37,318,589	Oil :	Tk12,629,463	Total :	Tk49,948,052		

**Load Shedding & Other Information**

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:15	to	0:00				
Dhaka		250			1580	339	21%	
Chittagong Area		170			460	110	24%	
Khulna Area		110			408	100	25%	
Rajshahi Area		68			380	84	22%	
Comilla Area		65			315	83	26%	
Mymensing Area		60			220	41	19%	
Sylhet Area		50			180	49	27%	
Barisal Area		33			80	24	30%	
Rangpur Area		38			216	46	21%	
Total		844	(	19:30 )	3839	876		

**Information of the Generating machines under maintenance**

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Haripur SBU GT-3 (25/05/05) 2) Ashuganj CCPP St-(20/10/07) 3) Haripur SBU GT-2 (12/04/08) 4) Shahjibazar -4 (23/04/08) 5) Kaptai unit-3 (19/04/08) 6) Bheramara -2 (18/04/08) 7) NEPC # 4 8) Ashuganj 3-(28/04/08)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 844 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW), Raozan (360 MW), RPCL (210 MW), Tongi (80MW), Baghabari (71 MW), WMPL (90 MW) and Siddhirganj (190 MW) were limited to 640 MW, 260 MW, 140 MW, 50MW, 66 MW, 67 MW and 100 MW respectively.	
c) Due to gas limitation, Haripur SBU GT-2, Sikalbaha Barge and Shahjibazar -4 were under shut down.	
d) After maintenance Ghorasal unit - 6 was synchronized at 11:40.	
e) Ashuganj GT-1 was synchronized at 15:43.	
f) After maintenance Kaptai unit -1 was synchronized at 18:06.	
g) Khulna central - Noapara 132KV line-1 was under maintenance from 06:17 to 08:32 due to CT oil leakage at Noapara end.	Due to generation shortage, about 200 MW of load shed has been running since morning (30/04/08) over the whole area of the national grid.

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle