

Reporting Date : 22-May-08  
17-Sep-07

17-Sep-07

Oil Consumed :				
PDB	SKO	:	0	Liter
	HSD	:	342665	Liter
	FO	:	416029	Liter

Gas Consumed : Total	642.75	MMCFt.					
Cost of the Consumed Fuel (PDB) : Gas	:		Tk36,782,467	Oil	:	Tk13,665,187	Total : Tk50,447,655

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	18:30	to 00:00			
Dhaka		273		1630	342	21%
Chittagong Area		186		500	140	28%
Khulna Area		154		410	102	25%
Rajshahi Area		118		364	85	23%
Cornilla Area		64		280	67	24%
Mymensing Area		69		215	51	24%
Sylhet Area		62		170	43	25%
Barisal Area		26		72	19	26%
Rangpur Area		73		220	52	24%
<b>Total</b>		<b>1025</b>	( 20:00 )	<b>3861</b>	<b>901</b>	

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Sikalbaha St -(08/05/08)
2) Haripur SBU GT-3 (25/05/05)	10) Ashuganj -3 (13/05/08)
3) Ashuganj CCPP St-(20/10/07)	11) Ghorasal 4 (20/05/08)
3) Shahjibazar -2 (19/05/08)	12) Tongi GT ( 21/05/08)
4) Kaptai unit-3 (19/04/08)	
5) Bheramara -2 (18/04/08)	
6) 4 units of KPCL	
7) Raozan 2 -(18/05/08)	
8) Ashuganj 5-(11/05/08)	

- a) Due to gas limitation, Raozan (180 MW) , RPCL ( 210 MW ) and Siddhirganj (190 MW ) were limited to 130 MW, 162 MW, 180 MW respectively
- c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.
- d) After maintenance Tongi GT synchronized at 17:08 again it tripped at 17:10 due to GBC temperature high and was synchronized at 20:13. Again it tripped at 00:37 (22/05/08) due to auxiliary fail and was synchronized at 07:01. It tripped again at 09:15 (22/05/08) due to GBC temperature high, now it is under maintenance.
- e) After maintenance Ahsuganj CCGP GT-1 was synchronized at 21:50.
- f) After maintenance Shahjibazar unit -8 & 9 were synchronized at 07:28(22/05/08) and 07:30 (22/05/08) respectively.
- g) Fenchugonj GT-1 was under shut down from 07:52 (22/05/08) to 08:38 for combined mood operation.
- i) Kulshi - Halishahar 132 KV line was under shut down from 09:30 to 12:52 due to insulator replacement at tower # 70.
- j) Saidpur - Rangpur 132 KV line- 2 was under shut down from 09:23 to 18:30 at Rangpur end due to CVT change.
- k) Natore - Rajshahi 132 KV line -1 was under maintenance from 07:16 to 10:45 due to red hot maintenance at Rajshahi end.
- l) Due to heavy rain and thunder storm, Sahajibazar - Sreemongal (Dist-C,Z2) 132 KV line -1 & 2 , Fenchugonj P/S (67N) - Fenchugonj S/S line 1 & 2 tripped at 05:43 (22/05/08). Fenchugonj GTs and Sylhet GT were isolately running with Sylhet and Chatak. Power was restored at Sreemongal and Fenchugonj S/S by switching on Shagibazar - Sreemongal line 1 & 2 at 07:10 and Fenchugonj P/S - Fenchugonj S/S line- 2 was synchronized at 07:28. and line -1 was switched on at 07:30.
- h) After installation of optical fiber, Haripur - Comilla 132 KV line was switched on at 16:15, and Kallanpur - Hasnabad 132 KV line -1 is under shut down since 06:45 (22/05/08) due to the same reason.

Due to generation shortage, about 250 MW of load shed has been running since morning (22/05/08) over the whole area of the national grid.

Deputy General Manager  
Load Despatch Circle