

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 29-May-08
The Summary of Yesterday's (28-May-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	3281.5	MW	Hour :	9:00	Min Gen. at 6:00	2968 MW
Evening Peak Generation :	3381.8	MW	Hour :	19:30	Max Generation :	3410 MW
E.P. Demand (at gen end) :	4450.0	MW	Hour :	19:30	Max Demand :	4500 MW
Maximum Generation :	3381.8	MW	Hour :	19:30	Shortage :	1090 MW
Total Gen. (MKWH) :	76.38	System L/ Factor :		94.10%	Load Shed :	928 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :-	Maximum	282 MW	at 3:00	Energy	5626500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of 29-May-08					
Actual :	71.48	Ft.(MSL) ,	Rule curve :	76.60	Ft.(MSL)

Oil Consumed :

PDB :	SKO :	0	Liter
	HSD :	305178	Liter
	FO :	389225	Liter

Gas Consumed : Total	661.19	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas :		Tk38,350,249	Oil :	Tk12,394,742	Total :	Tk50,744,991

Load Shedding & Other Information

Area	Yesterday				Estimated Demand(s/s end)	Today		
	Actual Shedding (s/s end), MW					Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to	00:00				MW
Dhaka		311			1600	334	21%	
Chittagong Area		159			500	148	30%	
Khulna Area		113			405	103	25%	
Rajshahi Area		84			365	91	25%	
Comilla Area		48			295	86	29%	
Mymensing Area		57			210	49	23%	
Sylhet Area		33			174	49	28%	
Barisal Area		20			74	23	31%	
Rangpur Area		76			210	45	21%	
Total		901	(19:30)	3833	928	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Sikalbaha St -(08/05/08) 9) Ashuganj -3 (13/05/08) 10) Tongi GT (21/05/08) 11) RPCL -1 (22/05/08)
	1) Haripur SBU GT-3 (25/05/05) 2) Ashuganj CCPP St-(20/10/07) 3) Shahjibazar -2 (19/05/08) 4) Kaptai unit-3 (19/04/08) 5) Bheramara -2 (18/04/08) 6) 4 units of KPCL 7) Raozan 2 -(18/05/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 901 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW) and Siddhirganj (190 MW) were limited to 100 MW, 130 MW, 105 MW respectively	
c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) Ashugonj GT-1 tripped at 09:13 due to combustion abnormality and was synchronized at 10:04. again it tripped at 17:53 due to same reason and was synchronized at 19:01.	
e) Sylhet GT tripped at 10:08 due to Generator electrical trouble.	
f) Ashugonj unit-4 tripped at 21:38 due to control power failure and was synchronized at 23:56.	
g) Kulshi 132/33 KV T1 transformer tripped at 08:05 showing pressure relay device and was switched on at 10:16.	Power interruption (6 MW) has been occurring under BSRM at 08:05 to 10:16.
g) Ghorasal 230/132 KV AT2 transformer tripped at 10:25 showing KHI non phase and was switched on at 11:12.	
h) After maintenance Ashugonj - Shahjibazar line -1 was switched on at 12:05.	
i) Kamrangirchor (new) S/S 132 KV bus energised on at 16:20. and T1 & T2 transformer were switched on at 132 KV side at 16:22 & 16:21 respectively.	Due to generation shortage, about 160 MW of load shed has been running since morning (29/05/08) over the whole area of the national grid.

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle