

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 1-Nov-08 17-Sep-07
The Summary of Yesterday's (31-Oct-08)		Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	2706.0	MW	Hour :	12:00	Min Gen. at 4:00	2411 MW
Evening Peak Generation :	3719.3	MW	Hour :	20:00	Max Generation :	3700 MW
E.P. Demand (at gen end) :	3950.0	MW	Hour :	20:00	Max Demand :	4050 MW
Maximum Generation :	3719.3	MW	Hour :	20:00	Shortage :	350 MW
Total Gen. (MKWH) :	67.82	System L/ Factor :		75.98%	Load Shed :	308 MW

EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :-	Maximum	336 MW	at 19:30	Energy	6864000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of 1-Nov-08					
Actual :	86.07	Ft.(MSL) ,	Rule curve :	101.00	Ft.(MSL)

Gas Consumed : Total	621.66	MMCFt.	Oil Consumed (PDB) :	SKO :	0	Liter
				HSD :	214776	Liter
				FO :	324292	Liter

Cost of the Consumed Fuel (PDB) : Gas : Tk45,946,891 Oil : Tk9,327,485 Total : Tk55,274,375

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)		
	from 17:20	to 21:30		Estimated Shedding (s/s end)	MW	Rates of Shedding (On Estimated Demand)
Dhaka	96		1540	48		3%
Chittagong Area	21		459	60		13%
Khulna Area	26		410	54		13%
Rajshahi Area	16		325	41		13%
Comilla Area	16		250	32		13%
Mymensing Area	10		189	24		13%
Sylhet Area	8		151	19		13%
Barisal Area	4		76	10		13%
Rangpur Area	6		159	20		13%
Total	203	(20:00)	3559	308		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08) 2) Raozan -1 (17/09/08) 3) Sikalbaha St- (19/06/08) 4) Shajibazar-2 (13/07/08) 5) Shajibazar-4 (27/09/08) 6) Ghorasal-1 (30/09/08)
	7) Haripur SBU GT-3(27/10/08) 8) Barapukuria -1 (29/10/08) 9) Ashuganj CCPP GT-1 & St - 30/10/08 10) Khulna 110 MW (30/10/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 203 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan -1, Sikalbaha Steam, Haripur SBU GT3 and Shahjibazar -2, 4, 6 are under shut down.	
c) Fenchuganj GT-4 was synchronized (on test) at 09:40.	
d) After maintenance Baghabari GT-2 (100 MW) was synchronized at 18:01.	
e) Haripur SBU GT-1 and GT-2 were synchronized at 19:04 and 19:38 respectively.	
f) Fenchuganj CCPP GT-1 was shut down at 00:21 (01/11/08) for maintenance.	
g) Haripur NEPC tripped at 07:05 showing ' Fire alarm' and was synchronized at 07:13.	
h) Bottail 33 KV bus was under shut down from 08:20 to 08:59 due to red-hot maintenance of Y-phase isolator at 33 KV REB feeder.	Power interruption occurred (20 MW) under Bottail S/S areas from 08:20 to 08:59.
i) Haripur 132 KV reserve bus and 230/132 KV TR3 transformer were under shut down from 09:54 to 12:30 and 13:20 to 17:04 respectively for project work.	
j) Haripur - Maniknagar 132 KV line -2 tripped at 12:45 from Maniknagar end showing 'Back up protection relay' and was switched on at 13:05.	
k) Faridpur 132/33 KV T1 transformer is under shut down since 07:06(01/11/08) for annual maintenance.	

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle