POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC,DHAKA DAILY REPORT

QF-LDC-08 Page -1

Tk59,310,717

Total :

				Reporting Date :	13-Nov-08
Till now the maximum generation	is:- MW at	4130.0	20:00	17-Sep-07	
The Summary of Yesterday's (12-Nov-08) Generation & Demand	Today's Actu	al Min Gen. & Probab	le Gen. & Demand
Day Peak Generation :	3022.0	MW Hour :	12:00 Min Gen. a	t 4:00	2355 MW
Evening Peak Generation :	3740.4	MW Hour :	19:30 Max Genera	tion	3795 MW
E.P. Demand (at gen end) :	4150.0	MW Hour :	19:30 Max Deman	d :	4100 MW
Maximum Generation :	3740.4	MW Hour :	19:30 Shortage	:	305 MW
Total Gen. (MKWH)	70.63	System L/ Factor :	78.67% Load Shed		258 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :- N	Maximum		300 MW at 19:30	Energy	4356000 KWHR.
Import from Ishurdi to Ghorasal:- M	laximum	-	MW at -	Energy	- KWHR.
1	Water Level of Kapt	ai Lake at 6:00 A M of	13-Nov-08		
Actual : 84.85	Ft.(MSL),		Rule curve : 107.80 Ft.(MSL)		
Gas Consumed : Total	640.92	MMCFt.	Oil Consumed (PDB) :	SKO : HSD :	0 Liter 218928 Liter
				FO :	533271 Liter

Tk47,370,397

Oil

: Tk11,940,320

Cost of the Consumed Fuel (PDB): Gas

Load Shedding & Other Information

Area	Yesterday Actual Shedding (s/s end), MW		Тодау			
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Estimated Shedding (s/s end) Rates of Shedding	
	fr too m 17:15	22:25	MW	MW	(On Estimated Demand)	
Dhaka	74		1507	30	2%	
Chittagong Area	56		446	52	12%	
Khulna Area	55		398	46	12%	
Rajshahi Area	43		317	37	12%	
Comilla Area	38		244	29	12%	
/lymensing Area	27		184	21	11%	
Sylhet Area	24		147	17	12%	
Barisal Area	10		73	8	11%	
Rangpur Area	20		155	18	12%	
	(
Total	347	19:30	3471	258		

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	7) Barapukuria -1 (29/10/08)		
	2) Raozan -2(02/11/08)	8) Meghnaghat GT-1 (31/10/08)		
	3) Sikalbaha St- (19/06/08)	9) Haripur SBU GT-2 (02/11/08)		
	4) Shajibazar-2 (13/07/08)	10) Haripur SBU GT-3 (03/11/08)		
	5) Shajibazar-4 (18/10/08)	11) Shajibazar-6 (11/11/08)		
	6) Ghorasal-1 (30/09/08)			

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yes	sterday .	: So about 347 MW (19:30) of load shed was imposed over the whole area of the national grid.
 b) Due to gas limitation, Raozan -2, Haripur SBU GT-2, GT-3, S are under shut down. c) Westmont-1 tripped at 03:01 (13/11/08) due to vibration h peak hour today. d) Fenchuganj - Srimongal 132 KV line -2, Tongi - Uttara 132 K & Netrokona 132/33 KV T2 transformer were under annual m 08:34 to 15:55, 10:08 to 16:24 & 10:55 to 14:40 respectifie) Khulshi - Madanhat 132 KV line-2 was under shut down f maintenance at Khulshi end. f) Sitalakhya 132/33 KV T2 transformer was shut down at 7 was switched on at 12:45. 	high. It may be synchronized before evening V line , Tongi - Mirpur 132 KV line (New) haintenance from 08:27 to 14:15, vely. rom 09:48 to 11:20 due to 132 KV breaker loop	
Deputy / Asstt. Manager Load Despatch Division	Manager Load Despatch Division	Deputy General Manager Load Despatch Circle