

QF-LDC-08  
Page -1

Reporting Date : 14-Nov-10  
Hrs on 20-Aug-10

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

Actual : 104.36

HSD	:	1426291	Liter
FO	:	0	Liter

Oil : Tk57,051,648      Total : Tk104,731,728

### Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (s/s end) from                      tð/W	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
	MW				
Dhaka	524	(17:00-22:50 gen. shortage)	1850	410	22%
Chittagong Area	144	(17:05-22:37 gen. shortage)	521	137	26%
Khulna Area	115	(17:05-21:40 gen. shortage)	476	125	26%
Rajshahi Area	101	(17:05-22:24 gen. shortage)	390	102	26%
Comilla Area	76	(17:05-22:28 gen. shortage)	305	78	26%
Mymensing Area	62	(17:05-22:25 gen. shortage)	196	49	25%
Sylhet Area	23	(17:05-22:06 gen. shortage)	210	24	11%
Barisal Area	27	(17:05-21:40 gen. shortage)	92	24	26%
Rangpur Area	59	(17:05-22:24 gen. shortage)	218	57	26%
Total	1131	19:30	4258	1006	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
1) Haripur SBU GT-3 (18/06/09)	8) Megnaghat P. ltd GT-1(7/11/10)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	9) Barapukuria-1(09/11/10)	2) Shahjibazar GT-9(13/10/10)
3) Siddirganj GT-1 (18/06/10)		3) Khulna 60 MW (27/10/10)
4) Ashuganj-4(12/09/10)		4) Ashuganj-1(09/11/10)
5) Raozan-1 (03/10/10)		
6) Sikalbaha GT (24/10/10)		
7) Raozan-2 (21/10/10)		

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure Baghabari 100 MW and RPCL (210 MW) were limited to 60 MW and 90 MW respectively.</p> <p>c) 132 KV Mirpur-Aminbazar line-2 was under shut down from 08:10 to 18:46 for changing isolator.</p> <p>d) Bogra 230/132 KV transformer was under shut down from 09:45 to 15:25 due to project work.</p> <p>e) Kabirpur-Manikganj 132 KV line-1 tripped at 09:51 showing E/F relay from both end and was switched on at 10:20.</p> <p>f) Chatak 132/33 KV T3 X-former was under shut down from 12:34 to 14:30 due to 132 KV CT maint.</p> <p>g) 132 KV Madanhat-Hathazari line-2 from 08:32 to 14:52, Ishurdi-Natore line-2 from 08:58 to 15:51 Shyampur - Haripur line from 09:19 to 16:44 and 230 KV Hathazari - Raozan line -2 from 08:45 to 16:32 were under annual maintenance.</p> <p>h) Kabirpur T-2 from 09:25 to 15:51, Rajshahi T-3 from 10:20 to 17:20 132/33 KV and Aminbazar 230/132 KV T-2 from 08:16 to 17:25 X-formers were under annual maintenance.</p>	<p>So about 1131 MW (19:30) of load shed was imposed over the whole areas of the national grid .</p> <p>Due to generation shortage, about 70 MW (09:00) of load shed has been running since morning (14/11/10) over the whole area (except Sylhet) of the national grid.</p>

Deputy / Asstt. Manager

Network Operation Division

Manager

Network Operation Division

Deputy General Manager

Load Despatch Circle