

POWER GRID COMPANY OF BANGLADESH LTD.
CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA
DAILY REPORT

QF-LDC-08
Page -1

Till now the maximum generation is :- MW at		4130.0	20:00	Reporting Date : 15-Nov-08
The Summary of Yesterday's (14-Nov-08)		17-Sep-07		
		Generation & Demand		
Day Peak Generation :	2565.5	MW	Hour : 12:00	Min Gen. at 4:00 2153 MW
Evening Peak Generation :	3951.9	MW	Hour : 19:30	Max Generation : 4000 MW
E.P. Demand (at gen end) :	3952.0	MW	Hour : 19:30	Max Demand : 4000 MW
Maximum Generation :	3951.9	MW	Hour : 19:30	Shortage : 0 MW
Total Gen. (MKWH) :	65.34	System L/ Factor :	68.89%	Load Shed : -- MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR				
Export from Ghorasal to Ishurdi :- Maximum		270 MW	at 19:00	Energy 2178000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum		-	at -	Energy - KWHR.
Water Level of Kaptai Lake at 6:00 A M of		15-Nov-08		
Actual :	84.70	Ft.(MSL) ,	Rule curve :	107.60 Ft.(MSL)
Gas Consumed : Total 565.69 MMCFt. Oil Consumed (PDB) : SKO : 0 Liter				
HSD : 442430 Liter				
FO : 643053 Liter				
Cost of the Consumed Fuel (PDB) : Gas : Tk41,810,148 Oil : Tk18,914,535 Total : Tk60,724,682				

Load Shedding & Other Information

Area	Yesterday	Estimated Demand(s/s end) MW	Today	
	Actual Shedding (s/s end), MW from - -		Estimated Shedding (s/s end) MW -	Rates of Shedding (On Estimated Demand) -
Dhaka	-	1599	-	-
Chittagong Area	-	445	-	-
Khulna Area	-	398	-	-
Rajshahi Area	-	315	-	-
Comilla Area	-	243	-	-
Mymensing Area	-	183	-	-
Sylhet Area	-	146	-	-
Barisal Area	-	73	-	-
Rangpur Area	-	155	-	-
Total	0	3557	-	-

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)
	2) Raozan -2(02/11/08)
	3) Sikalbaha St- (19/06/08)
	4) Shajibazar-2 (13/07/08)
	5) Shajibazar-4 (18/10/08)
	6) Ghorasal-1 (30/09/08)
	7) Ashuganj 2 (13/11/08)
	8) Meghnaghat GT-1 (31/10/08)
	9) Haripur SBU GT-3 (03/11/08)
	10) Shajibazar-6 (11/11/08)

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was no generation shortage in the evening peak hour yesterday .	So no load shed required.
b) Due to gas limitation, Raozan -2, Haripur SBU GT-3, Sikalbaha Steam and Shahjibazar -2, 4 & 6 are under shut down.	
c) After maintenance, Fenchuganj CAPP GT-1 was synchronized at 09:57.	
d) Kishorganj 132/33 KV T2 transformer, Jamalpur 132/33 KV T2 transformer, Kabirpur 132/33 KV T1 transformer and Madanganj 132/33 KV T1 transformers were under annual maintenance from 08:20 to 14:50, 08:14 to 15:07, 08:22 to 17:20 and 09:35 to 16:05 respectively.	
e) Tongi - Ghorasal 230 KV line -2 was under annual maintenance from 08:40 to 17:20.	
f) After project work, Ishurdi - Bheramara 132 KV line -1 & 2 were switched on at 17:33 and 17:34 respectively	
g) After maintenance, Halisahar 33 KV and 132 KV bus were switched on at 11:07.	
h) After annual maintenance, Kulshi - Halisahar 132 KV line -1 & 2 were switched on at 11:07	
i) Ishurdi - Bheramara 132 KV line -1 & 2 are under shut down since 06:42 (15/11/08) and 06:53 respectively due to project work.	
j) Kaptai - Chandraghona 132 KV line -2, Tangail - Kabirpur 132 KV line -1, Netrokona 132/33 KV T2 transformer, Jamalpur 132/33 KV T2 transformer, Kishorganj 132/33 KV T2 transformer and Ullon 132/33 KV T2 transformers are under annual maintenance since 07:35 (15/11/08), 07:55, 07:56, 08:12, 08:15 and 08:16 respectively.	
k) Hasnabad - Meghnaghat 230 KV line -2, Ishurdi - Ghorasal 230 KV line -2 and Aminbazar 230/132 KV T3 transformer are under annual maintenance since 07:44 (15/11/08), 07:58 and 08:08 respectively	

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle