

QF-LDC-08
Page -1

Reporting Date : 17-Nov-08
17-Sep-07

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

		Water Level of Kaptai Lake at 6:00 A M of		17-Nov-08	
Actual :	84.60	Ft.(MSL) ,	Rule curve :	107.40	Ft.(MSL)

Cost of the Consumed Fuel (PDB): Gas	: Tk45,437,651	Oil	: Tk11,222,247	Total	: Tk56,659,898
--------------------------------------	----------------	-----	----------------	-------	----------------

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand (s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	17:15 23:55			
Dhaka		84	1565	18	1%
Chittagong Area		27	450	35	8%
Khulna Area		25	402	31	8%
Rajshahi Area		25	320	25	8%
Comilla Area		23	245	19	8%
Mymensing Area		17	185	13	7%
Sylhet Area		11	149	12	8%
Barisal Area		5	75	6	8%
Rangpur Area		13	158	14	9%
		(
Total		230 19:30	3549	173	

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	7) Meghnaghat GT-1 (31/10/08)
	8) Haripur SBU GT-3 (03/11/08)
2) Raozan -2(02/11/08)	9) Shajibazar-6 (11/11/08)
3) Shajibazar-2 (13/07/08)	10) WMPL #1-(15/11/08)
4) Shajibazar-4 (18/10/08)	11) Sikalbaha Barge (19/06/08)
5) Ghorasal-1 (30/09/08)	
6) Ashuganj 2 (13/11/08)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 230 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Sikalbaha Barge, Raozan -2, Haripur SBU GT-3 and Shahjibazar -2, 4 & 6 are under shut down.	
c) Fenchuganj GT-2 was shut down at 12:11 due to combined mode and was synchronized at 16:08.	
d) After maintenance, Tongi GT was synchronized at 18:39.	
e) After maintenance, Ashuganj Steam unit -2 was synchronized at 23:28.	
f) Mymensing 132/33 KV T2 transformer, Jessore - Noapara 132 KV line -1, Purbasadipur 132/33 KV T1 transformer, Fenchuganj 132/33 KV T2 transformer and Bogra - Naogaon 132 KV line -1 were under annual maintenance from 09:25 to 13:25, 09:28 to 14:34, 08:50 to 14:26, 08:55 to 16:50 and 08:44 to 15:23 respectively.	
g) Meghnaghat - Haripur 230 KV line -2 and Hasnabad 230/132 KV TR1 transformers were under annual maintenance from 08:27 to 14:25 and 09:04 to till now	
h) Chatak 132/33 KV T1 transformer tripped at 12:30 showing ' O/C at A-phase' and was switched on at 12:32	
i) After annual maintenance, Madaripur 132/33 KV T1 transformer, Barisal 132/33 KV T2 transformer, Kaptai - Chandraghona 132 KV line-2 and Comilla (N) 132/33 KV T03 transformers were switched on at 15:36, 16:10, 15:58 and 13:02 respectively.	
j) After annual maintenance, Ishurdi - Ghorasal 230 KV line -2 was switched on at 16:18.	
k) Basundhara - Rampura 132 KV line -1, Chandraghona - Kaptai 132 KV line -2, Madaripur 132/33 KV T1 transformer, Barisal 132/33 KV T2 transformer, Joydevpur 132/33 KV T4 transformer and Jamalpur 132/33 KV T2 transformers are under annual maintenance since 07:26 (17/11/08), 07:32, 07:06, 07:06, 07:41 and 08:03 respectively.	
l) Ishurdi - Ghorasal 230 KV line -2 and Haripur - Meghnaghat 230 KV line -1 are under annual maintenance since 07:30 (17/11/08) and 08:16 respectively.	

Deputy General Manager
Load Despatch Circle