

QF-LDC-08
Page -1

Reporting Date : 16-Feb-10
Hrs on 18-Sep-09

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Actual :	88.50	Water Level of Kaptai Lake at 6:00 A M of	16-Feb-10
		Ft.(MSL) ,	Rule curve : 94.90 Ft.(MSL)

Cost of the Consumed Fuel (PDB): Gas : Tk52,127,245 Oil : Tk11,947,908 Total : Tk64,075,153

Area	Yesterday		Today		
	Actual Shedding (s/s end)		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	MW				
Dhaka	217	(17:40-23:38, gen. shortage)	1680	258	15%
Chittagong Area	95	(17:40-23:38, gen. shortage)	456	99	22%
Khulna Area	91	(17:40-22:56 gen. shortage)	420	91	22%
Rajshahi Area	91	(17:40-23:20, gen. shortage)	388	85	22%
Comilla Area	74	(17:40-22:53, gen. shortage)	310	67	22%
Mymensing Area	53	(17:40-22:53, gen. shortage)	228	49	21%
Sylhet Area	-	0	209	-	-
Barisal Area	18	(17:40-22:56 gen. shortage)	85	18	21%
Rangpur Area	43	(17:40-23:20, gen. shortage)	226	48	21%
Total	682	19:00	4002	715	

Planned Shut- Down		Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08) 2) Shajibazar- 2 (13/07/08) 3) Shajibazar-4 (18/10/08) 4) Khulna 110 (31/03/09) 5) Haripur SBU GT-3 (18/06/09). 6) Shahjibazar 5 (05/08/09) 7) Shahjibazar -6 (11/10/09). 8) Raozan -2 (08/11/09)	09) Ashuganj CCPP ST (05/12/09) 10) Raozan -1(19/12/09) 11) Sikalbaha St (27/12/09) 12) Kaptai -4 (17/01/10) 13) Baghabari GT-1 (17/01/10) 14) Ghorasal 3 (13/02/10).

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 682 MW (19:00) of load shed was imposed over the whole area (except Sylhet) of the national grid .
b) Due to gas limitation, RPCL (175 MW) , Tongi GT (105 MW) and Siddhirganj 210 MW were limited to 91 MW, 35 MW and 100 MW respectively.	
c) Due to gas limitation, Sikalbaha Steam, Haripur SBU GT-1 & 2 , Baghabari GT-1 (71 MW), NEPC & Raozan -1, 2 were under shut down.	
d) Baghabari WMPG GT-1 tripped at 14:26 showing ' High inlet manifold vacuum' and was synchronized at 17:18.	
e) Ghorasal - Tongi 230 KV line -1 was under NLDC project work from 09:14 to 09:45.	
f) Khulshi - Baraulia 132 KV line -2 from 09:12 to 16:21 and Haripur - Comilla 132 KV line -2 from 09:30 to 15:40 were under annual maintenance.	
g) Ishurdi 132/33 KV T2 transformer was under shut down from 10:12 to 17:48 due to connection of new transformer.	
h) Ghorasal - Bhulta 132 KV line was under shut down from 10:57 to 14:57 due to red-hot maintenance of isolator at Ghorasal end.	
i) Rampura 132 KV bus bar was under shut down from 09:22 to 15:12 due to project work by Shunt Compensation project.	
	Due to generation shortage, about 100 MW (09:00) of load shed has been running since morning (16/02/10) over the whole area (except Sylhet) of the national grid.

Deputy General Manager
Load Despatch Circle