QF-LDC-08

Page -1

POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

MW

18:30

Reporting Date: 25-Feb-10 Till now the maximum generation is: 4296.0 MW at 24-Feb-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3422.0 MW 10:00 Min Gen. at 3159 Hour 4:00 ΜW Evening Peak Generation MW 3622.5 Max Generation MW 20:00 3800 E.P. Demand (at gen end) 4000.0 MW Hour 20:00 Max Demand 4700 MW Maximum Generation 3734 5 MW Hour 21:00 Shortage 900 MW Total Gen. (MKWH) 79.53 System L/ Factor 85.41% Load Shed 776 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Import from West grid to East grid :- Maximum - MW at
Water Level of Kaptai Lake at 6:00 A M of 25-Feb-10

Actual: 86.37 Ft.(MSL), Rule curve: 93.60 Ft.(MSL)

695.20 MMCFt. Oil Consumed (PDB):

HSD : 193716 Liter FO : 0 Liter

Energy

12084000 KWHR.

KWHR

Cost of the Consumed Fuel (PDB): Gas : Tk51,382,232 Oil : Tk7,748,654 Total : Tk59,130,886

Load Shedding & Other Information

Export from East grid to West grid :- Maximum

Gas Consumed:

Area	Yesterday			Today	
	Actual Sheddir	ng (s/s end)	Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from tonW	MW	(On Estimated Demand)
Dhaka	58	(17:40-19:50, gen. shortage)	1710	292	17%
Chittagong Area	69	(17:40-22:00, gen. shortage)	460	104	23%
Khulna Area	47	(17:40-21:45, gen. shortage)	425	97	23%
Rajshahi Area	30	(17:40-22:00, gen. shortage)	390	88	23%
Comilla Area	46	(17:40-21:50, gen. shortage)	312	70	22%
Mymensing Area	39	(17:40-21:35, gen. shortage)	231	52	23%
Sylhet Area	-	0	209	-	-
Barisal Area	10	(17:40-21:45, gen. shortage)	87	20	23%
Rangpur Area	27	(17:40-22:00, gen. shortage)	230	53	23%
Total	326	20:00	4054	776	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut-Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	09) Ashuganj CCPP ST (05/12/09)
	2) Shajibazar- 2 (13/07/08)	10) Kaptai -4 (17/01/10)
	3) Shajibazar-4 (18/10/08)	11) HPL GT & ST (22/02/10)
	4) Khulna 110 (31/03/09)	12) Siddhirganj Gt -(23/02/10).
	5) Haripur SBU GT-3 (18/06/09).	
	6) Shahjibazar 5 (05/08/09)	
	7) Shahjibazar -6 (11/10/09).	
	8) Raozan -2 (08/11/09)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
\	Ob+ 000 MMM (00.00) -f ll

- There was generation shortage in the evening peak hour yesterday. Due to heavy rain and Storm the demand was dropped.
- b) Due to gas limitation, Ghorasal (830 MW), RPCL (175 MW), NEPC (110MW), Baghabari GT-2 (100 MW), Raozan (180 MW) and Siddhirganj 210 MW were limited to 810 MW, 71 MW, 3 MW, 80 MW and 150 MW respectively.
- c) Baghabari WMPL unit -2 tripped at 11:08 showing 'vibration high' and was synchronized at 14:15.
- of filter
- e) After maintenance, Ashuganj unit -1 was synchronized at 13:13.
- f) After maintenance, Ghorasal unit 4 was synchronized at 14:30.
- g) Tongi GT tripped at 18:38 showing 'Over frequency' and was synchronized at 20:20.
- h) Hathazari Comilla (N) 230 KV line -1 from 08:19 to 17:25, Netrokona 132/33 KV T2 transformer, from 08:35 to 16:10 and Goalpara Khulna Central 132 KV line -1 from 09:30 to 14:28 were under annual maintenance.
- i) Ashuganj Ghorasal 230 KV line -2 was under shut down from 09:51 to 18:19 due to oil filling at CT.
- j) Bottail 132/33 KV T1 and T2 transformer tripped at 09:36 showing 'E/F' and were switched on at 09:45.
- k) After annual maintenance, Barisal S/S P/S 132 KV line was switched on at 16:31.
- Aminbazar (on DIST RST) Mirpur (on DIST) 132 KV line -2 tripped at 17:08 from both end and was switched on at 17:45.
- m) Due to heavy rain and storm, Rampura Ullon 132 KV line from Rampura end showing 'DIST Z2', Moghbazar Ullon 132 KV line from Moghbazar end showing 'Main prot. trip' and Siddhirganj Ullon 132 KV line -1 & 2 tripped from Siddhirganj end showing 'O/C, inst. E/F' tripped at 17:26. Rampura Ullon 132 KV line and Siddhirganj Ullon 132 KV line -1 & 2were switched on at 17:44 17:55 and 17:56 respectively. Moghbazar Ullon 132 KV line is now under maintenance.
- n) Shyampur (DIST Z1) Hasnabad (on DIST Z2) 132 KV line tripped at 17:28 from both end and was switched on at 18:45 then it tripped again . On the other hand , Shyampur - Haripur 132 KV line was forced shut down at 17:35 due to firing at 132 KV insulator. The lines were switched on at 20:52 and 18:05 respectively.
- o) Ghorasal Narsingdi 132 line tripped at 16:15 from both end showing 'Remote prot.'. It is now under inspection and maintenance.
- p) Haripur Madanganj 132 KV line tripped at 18:29 from Haripur end showing ' DIST prot. Diff. E/F and was switched on at 18:38.
- q) Tongi Uttara 132 KV line tripped at 18:33 from Tongi end showing 'DIST Z2' and was switched on at 23:03. Power restored at Uttara by switched on Mirpur - Uttara 132 KV line at 18:40.
- r) Comilla (N) Chandpur 132 KV line tripped at 18:49 from Comilla end showing ' Directional O/C' and was switched on at 18:50.
- s) Gulshan 132/33 KV MT2 transformer tripped at 18:02 showing ' Gent prot. & differential ' and was switched on at 22:41.

So about 326 MW (20:00) of load shed was imposed over the whole area (except Sylhet) of the national grid.

Power interruption occurred (26 MW) under Bottail S/S areas for 9 minutes.

Power interruption occurred (131 MW) under Ullon and Dhanmondi S/S areas from 17:26 to 17:44.

Power interruption occurred (62 MW) under Shyampur S/S areas from 17:35 to 18:05.

Power interruption occurred (45 MW) under uTTARA S/S areas for 7 minutes.