POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

Revised

QF-LDC-08 Page -1

Reporting Date: 18-Apr-10 Till now the maximum generation is: 4606.0 MW at 17-Apr-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 3970.0 Day Peak Generation ΜV Min Gen. at 3158 Hour 9:00 8:00 ΜW Evening Peak Generation 4020.0 MM Max Generation MW 20:00 4005 E.P. Demand (at gen end) 5100.0 MW Hour 20:00 Max Demand 5000 MW Maximum Generation 4174 0 MW Hour 3.00 Shortage 995 MW Total Gen. (MKWH) 92.06 System L/ Factor 85.41% Load Shed 842 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Rule curve

Export from East grid to West grid :- Maximum 13239000 KWHR. MW 2:00 Energy Import from West grid to East grid :- Maximum N/N/ **KWHR**

Water Level of Kaptai Lake at 6:00 A M of 18-Apr-10 84.60 Ft.(MSL)

Gas Consumed: MMCFt Oil Consumed (PDB):

> HSD 330727 Liter

FO 0 Liter

Cost of the Consumed Fuel (PDB): Gas Tk61,762,892 : Tk13,229,064 Total: Tk74,991,956

Load Shedding & Other Information

Area	Yesterday		Today						
	Actual Shedding (s/s end)		Estimated Demand(s	s/s end) Estimated Shedding (s/s e	Rates of Shedding				
	MW		from toMW	MW	(On Estimated Demand)				
Dhaka	427	(18:10- 01:50, gen. shortage)	1770	307	17%				
Chittagong Area	100	(18:10- 01:50, gen. shortage)	486	114	23%				
Khulna Area	92	(18:10- 02:50, gen. shortage)	454	107	24%				
Rajshahi Area	82	(18:10-00:56, gen. shortage)	416	98	24%				
Comilla Area	93	(18:10- 01:05, gen. shortage)	334	79	24%				
Mymensing Area	51	(18:10-00:30, gen. shortage)	246	58	24%				
Sylhet Area	-	0	189	-	-				
Barisal Area	14	(18:10- 02:50, gen. shortage)	92	21	23%				
Rangpur Area	55	(18:10- 00:56, gen. shortage)	244	58	24%				
Total	914	20:00	4231	842					

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Kaptai- 3 (19/04/08)
	2) Khulna 110MW (31/03/09)
	3) Haripur SBU GT-3 (18/06/09)
	4) Ashuganj CCPP ST (05/12/09)
	5) Kaptai -4 (17/01/10)
	6) Ghorasal-2 (29/03/10)
	7) HPL St (15/04/10)
	8) Siddhirganj Gt-1 (15/04/10)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Descript				d load			Areas	

a) There was generation shortage in the evening peak hour yesterday.

77.19

Ft.(MSL)

Actual

- b) Due to low gas pressure, RPCL (175 MW), Raozan (360 MW), NEPC (110 MW), HPL (250 MW) and were limited to 89 MW, 320 MW, 20 MW and 193 MW respectively
- c) Barapukuria unit -2 tripped at 10:30 due to vacuum problem and was synchronized at 18:34.
- d) Ashuganj unit -2 tripped at 04:02 (18/04/10) due to pre-heater tube leakage. It may be synchronized before evening peak hour today.
- e) Ashuganj unit 4 tripped at 09:26 (18/04/10) due to re-heater tube leakage
- f) Bheramara 132 KV bus -B was under shut down from 11:36 to 11:41 due to maintenance of breaker no. - 652 B
- g) Hasnabad 132/33 KV T2 transformer was shut down at 13:45 due to red-hot maintenance of 33 KV bus. Again T5 and T6 transformers tripped at 14:02 showing 'Over voltage' and 'O/C' respectively and T1 was shut down at 15:20 due to emergency maintenance of 33 KV bus isolator. They were switched on at 16:45 respectively.
- h) Thakurgaon 132/33 KV T2 transformer was under shut down from 17:04 to 17:45 due to maintenance of 33 KV bus.
- i) Bagerhat 132/33 KV T1 and T2 transformer tripped at 17:46 showing 'Lock out' due to 33 KV Rampal feeder fault and were switched on at 17:50.
- j) Rangpur Saidpur 132 KV line -2 was under shut down from 19:25 to 19:50 due to red-hot maintenance of 132 KV B-phase breaker at Rangpur end. Again it tripped at 23:53 showing DIST B-phase' from both end and was switched on at 00:59 (18/04/10).
- k) Saidpur Barapukuria 132 KV line -1 & 2 tripped at 23:58 from Saidpur end and both end showing 'DIST' and were switched on at 00:02 (18/04/10 and 00:04 (18/04/10) respectively.
- I) Sremongal Fenchuganj P/S 132KV line -1 & 2 tripped at 04:47 (18/04/10) showing 'DIST from Fenchuganj end . At that time , Shahjibazar 86 MW, Sylhet RPP (50 MW), Shahjibazar RPP (50 MW) also tripped. So Sylhet zone was isolately running from the national grid. Sremongal - Fenchuganj P/S were synchronized at 05:25 (18/04/10). The machines were synchronized at 07:30 (18/4/10), 06:20 (18/04/10) and 07:15 (18/04/10) respectively.
- m) Mymensing Jamalpur 132 KV line -1 & 2 tripped at 05:48 (18/04/10) from Mymensing end showing 'DIST ABC' and were switched on at 05:57 (18/04/10).
- n) After project work, Aminbazar Tongi 230 KV line 1 & 2 were switched on at 18:32. Again they are under shut down since 07:33 (18/04/10) due to the same reason.

So about 914 MW (20:00) of load shed was imposed over

from 14:02 to 16:45.

the whole area (except Sylhet) of the national grid.

Power interruption occurred (54 MW) under Hasnabad S/S areas

Power interruption occurred (18 MW) under Bagerhat S/S areas from 17:46 to 17:50

Power interruption occurred (40 MW) under Mymensing S/S areas from 05:48 to 15:57.

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division

Deputy General Manager Load Despatch Circle