POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC. DHAKA DAILY REPORT

QF-LDC-08

Reporting Date: 6-May-10 Till now the maximum generation is: 4606.0 MW at 5-May-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 3783.0 MW Day Peak Generation 12:00 Min Gen. at 3236 MW Hour 6:00 Evening Peak Generation 4074.0 MW 21:00 Max Generation 3975 MW E.P. Demand (at gen end) 4720.0 MW Hour 21:00 Max Demand 5050 MW Maximum Generation 4196.5 MW Hour : 2.00 Shortage 1075 MW Total Gen. (MKWH) 91.40 System L/ Factor 85.41% Load Shed 944 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 11164000 KWHR. Energy Import from West grid to East grid :- Maximum N/N/ KWHR Water Level of Kaptai Lake at 6:00 A M of 6-May-10 76.27 81.05 Ft.(MSL) Actual : Ft.(MSL) Rule curve

Gas Consumed : Total 847.44 MMCFt. Oil Consumed (PDB) :

HSD : 322789 Liter

FO : 0 Liter

Cost of the Consumed Fuel (PDB): Gas :

Tk62,634,290

I : Tk12,911,568 T

Total: Tk75,545,858

Load Shedding & Other Information

Area	Yesterday Actual Shedding (s/s end)		Today		
			Estimated Demand(s/s end) Estimated Shedding (s/s e Rates of She		Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	349	(18:20-23:40, gen. shortage)	1854	348	19%
Chittagong Area	97	(18:20-22:40, gen. shortage)	512	129	25%
Khulna Area	-	0	478	120	25%
Rajshahi Area	-	0	435	108	25%
Comilla Area	76	(18:20-22:25, gen. shortage)	350	87	25%
Mymensing Area	-	0	258	64	25%
Sylhet Area	-	0	194	-	-
Barisal Area	-	0	97	24	25%
Rangpur Area	45	(18:20-20:25, gen. shortage)	255	64	25%
Total	567	21:00	4433	944	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down		
	1) Kaptai- 3 (19/04/08)		
	2) Khulna 110MW (31/03/09)		
	3) Haripur SBU GT-3 (18/06/09)		
	4) Ashuganj CCPP ST (05/12/09)		
	5) Kaptai -4 (17/01/10)		
	6) HPL St (15/04/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 567 MW (21:00) of load shed was imposed over the Dh
	Chittagong, Comilla & Rangpur areas of the national grid .

- b) Due to low gas pressure, RPCL (175 MW), Raozan (360 MW), NEPC (110 MW) and Tongi GT (105 MW) were limited to 90 MW, 220 MW, 72 MW and 20 MW respectively.
- c) After maintenance Barapukuria unit -2 synchronized at 15:08. Again it was shut down at 15:26 due to boiler drum level high and was synchronized at 17:39.
- d) Haripur Power Ltd. Steam was under shut down at 17:09 due to steam turbine vibration high.
- e) Khulna 60 MW tripped at 19:20 due to over current.
- f) Raozan unit-2 was shut down at 22:44 due gas limitation.
- g) Baghabari GT-1 was under shutdown from 05:59(06/05/10) to 08:40 (06/05/10) due to changing of filter.
- h) At Dhanmondi S/S 33KV breaker of 132/33 KV GT-3 transformer tripped at 14:26 due to 33 KV feeder fault and was switched on at 15:25. Again 33KV breakers of 132/33 KV GT-1 & GT-2 transformers tripped at 14:58 due to 33 KV feeder fault and were switched on at 15:05.
- Faridpur Madaripur 132KV line-2 was under shut own from 16:12 to 19:32 due to isolator maintenance work.
- j) Sylhet Chatak 132 KV line -2 was under shut down from 11:20 to 13:44 due to Stretching of guye wire.

Power interruption (116 MW) occurred under Dhanmondi S/S areas for 7 minutes.

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle