The Summary of Yesterday's ( 5-Jun-10 ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3595.0 MW Hour 12:00 Min Gen. at 7:00 2753 MW Evening Peak Generation 4293.0 MW Max Generation MW Hour 21:00 4305 E.P. Demand (at gen end) : 4600.0 Hour 21:00 Max Demand 4700 MW Maximum Generation 4293.0 MW 21:00 395 MW Hour Shortage Total Gen. (MKWH) 85.58 System L/ Factor 85.41% Load Shed 346 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid: Maximum 500 MW at 22:00 Energy 9743000 KWHR.

Import from West grid to East grid: Maximum - MW at - Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of 6-Jun-10
: 82.85 Ft.(MSL), Rule curve: 77.30

Gas Consumed : Total 734.08 MMCFt. Oil Consumed (PDB) :

HSD : 196326 Liter FO : 0 Liter

Ft.( MSL

Cost of the Consumed Fuel (PDB): Gas : Tk54,255,853 Oil : Tk7,853,022 Total : Tk62,108,875

## **Load Shedding & Other Information**

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e Rates of Shedding	
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	124	(18:35-22:30, gen. shortage)	1785	133	7%
Chittagong Area	-	0	508	49	10%
Khulna Area	26	(18:35-23:20, gen. shortage)	450	47	10%
Rajshahi Area	29	(18:35-22:50, gen. shortage)	374	39	10%
Comilla Area	35	(18:35-22:20, gen. shortage)	290	28	10%
Mymensing Area	26	(18:35-22:20, gen. shortage)	216	21	10%
Sylhet Area	-	0	204	-	-
Barisal Area	-	0	89	9	10%
Rangpur Area	29	(18:35-22:50, gen. shortage)	200	20	10%
Total	269	21:00	4116	346	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down	
	1) Kaptai- 3 (19/04/08)	10) Tongi GT ( 01/06/10)	
	2) Khulna 110MW (31/03/09)	11) Siddhirganj GT-1 (01/06/10)	
	3) Haripur SBU GT-3 (18/06/09)		
	4) Ashuganj CCPP ST (05/12/09)		
	5) Raozan -1 (08/05/10)		
	6) Ghorasal 2(26/04/10)		
	7) Kaptai- 4 (17/01/10)		
	8) Khulna 60 MW ( 04/06/10)		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

a) There was generation shortage in the evening peak hour yesterday.

So about 269 MW (21:00) of load shed was imposed over the whole (except Chittagong, Sylhet & Barisal ) areas of the national grid .

- b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW), NEPC (110 MW), and Siddhirganj peaking plant (120 MW) were limited to 160 MW, 106 MW, 16 MW and 110 MW respectively.
- c) After maintenance, Sikalbaha 60 MW was synchronized at 15:25.
- d) After maintenance, Siddhirganj peaking plant GT-2 was synchronized at 19:04. Again it tripped at 01:10 (06/06/10) due to generator breaker trip and was synchronized at 06:47 (06/06/10).
- e) Haripur NEPC tripped at 20:25 due to gas booster tripped and was synchronized at 00:30 (06/06/10).
- f) Shahjibazar GT-8 and GT-9 were shut down since 06:28 (06/06/10) and 06:34 (06/06/10) respectively due to maintenance work at 132 KV bus. They may be synchronized before evening peak hour today.
- g) Khulna (C) Noapara 132 KV line -1 was under shut down from 09:20 to 17:59 due to armoring work.
- h) Jamalpur 132/33 KV T3 transformer was under shut down from 08:50 to 15:28 due to replacement of 33 KV breaker.
- i) Shyampur 132/33 KV GT-1 transformer was under shut down from 10:52 to 16:04 due to installation of new transformer.
- j) Barisal Patuakhali 132 KV line was under shut down from 13:02 to 16:46 due to replacement of line breaker at Barisal end.
- k) Maniknagar (DIST A) Haripur ( DIST Z1) 132 KV line -1 tripped at 01:14 (06/06/10) from both end and was switched on at 10:47 (06/06/10)

Manager Deputy General Manager
Load Despatch Division Load Despatch Circle