## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTEF DAILY REPORT

: Tk56,168,228

Forced load shaded / Interrupted Areas

QF-LDC-08 Page -1

Reporting Date : 9-Oct-06 Till now the maximum generation is:-4698.5 MW at 19-Aug-06 The Summary of Yesterday's ( 8-Oct-06 ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3436.0 3042 Hour 12:00 Min Gen. at 4132.5 Evening Peak Generation : MW 20:00 Max Generation 4173 MW Hour : E.P. Demand (at gen end) : 4500.0 MW 5000 MW Hour : 20:00 Max Demand 4132.5 MW 827 Maximum Generation Hour : 20:00 Shortage MW Total Gen. (MKWH) 85.41% 80.74 System L/ Factor Load Shed 753 MW EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum  $\mathsf{MW}$ Energy 8597000 KWHR. Import from West grid to East grid :- Maximum MW KWHR. Energy at Water Level of Kaptai Lake at 6:00 A M of 9-Oct-06 108.61 106.81 Ft.( MSL ) Actual: Ft.(MSL), Rule curve : Gas Consumed : MMCFt. Oil Consumed (PDB): HSD : 1404206 Liter FO : 0 Liter Cost of the Consumed Fuel (PDB): Gas Tk51,838,257 Total : Tk108,006,485

## **Load Shedding & Other Information**

Area	Yesterday		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	112	(17:30-23:30 gen. shortage)	1946	269	14%
Chittagong Area	63	(17:30-22:44 gen. shortage)	563	112	20%
Khulna Area	35	(17:30-22:30 gen. shortage)	513	102	20%
Rajshahi Area	31	(17:30-22:30 gen. shortage)	422	84	20%
Comilla Area	29	(17:30-22:35 gen. shortage)	332	66	20%
Mymensing Area	26	(17:30-22:35 gen. shortage)	217	41	19%
Sylhet Area	-	0	226	13	6%
Barisal Area	8	(17:30-22:30 gen. shortage)	99	19	19%
Rangpur Area	16	(17:30-22:30 gen. shortage)	235	47	20%
Total	320	20:00	4553	753	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down	
	1) Khulna 110MW (31/03/09)	7) Ashuganj-4(12/09/10)	
	2) Haripur SBU GT-3 (18/06/09)	8) Barapukuria- 1(07/10/10)	
	3) Ghorasal 2(26/04/10)	9) Raozan-1 (03/10/10)	
	4) Siddirganj GT-1 (18/06/10)		
	5 ) Ghorasal 6(18/07/10)		
	6) Ghorasal-5(12/09/10)		
	:		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

a) There was generation shortage in the evening	91	So about 320 MW (20:00) of load shed was imposed over the
b) Due to low gas pressure Raozan (360 MW), F were limited to 140 MW, 107 MW and 90 MV	, , , , ,	whole (except Sylhet) areas of the national grid .
<ul> <li>c) Sylhet RPP tripped at 16:15 due to tripping of d) After maintenance Tongi GT was synchronize</li> <li>e) Sylhet - Chatak 132 KV line tripped at 07:20( at 07:41(10/10/10).</li> </ul>	ed at 00:58 (10/10/2010).	
Deputy / Asstt. Manager	Manager	Deputy General Manager
Network Operation Division	Network Operation Division	Load Despatch Circle