POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA. DAILY REPORT

MW

at

Oil Consumed (PDB):

12-Dec-09 Reporting Date: 4296 0 MW at 20:00 Till now the maximum generation is: The Summary of Yesterday's (11-Dec-09 Today's Actual Min Gen. & Probable Gen. & De) Generation & Demand Day Peak Generation 2674.0 10:00 Min Gen. at 5:00 **Evening Peak Generation** 3678 5 N/N/ Hour 20:00 Max Generation 3830 MW 20:00 E.P. Demand (at gen end) 4050.0 Hour Max Demand 4150 Maximum Generation 3678.5 MW 20:00 Shortage 320 Hour Total Gen. (MKWH) 64.11 System L/ Factor Load Shed 277 92.35% EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MW 22:00 Energy 8089000

Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M of 12-Dec-09 98.63 Ft.(MSL) Actual Rule curve

> HSD 187752

Energy

105.00 Ft.(MSL)

FO 0

Cost of the Consumed Fuel (PDB): Gas Tk41 586 201 : Tk7.510.094 Total: Tk49.096.295

Load Shedding & Other Information

MMCFt

562 66

Area	Yesterday		Today
	Actual Shedding (s/s end)	Estimated Demand(s/s end)	Estimated Shedding (s/s enc Rates of Shed
	MW	fro MW to	MW (On Estimated [
Dhaka	167 0- 21:48, gen. shor	1507	84 6%
Chittagong Area	42 0- 21:48, gen. shor	404	41 10%
Khulna Area	27 0- 21:50, gen. shor	395	40 10%
Rajshahi Area	30 0- 21:40, gen. shor	298	30 10%
Comilla Area	19 0- 20:02, gen. shor	330	34 10%
Mymensing Area	21 0- 20:02, gen. shor	195	21 11%
Sylhet Area	- 0	205	-
Barisal Area	4 0- 21:50, gen. shor	69	7 10%
Rangpur Area	11 0- 21:40, gen. shor	188	20 11%
Total	321 20:00	3591	277

Information of the Generating machines under maintenance

Planned Shut- Dowr		Forced Shut- Down	
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Raozan -2 (08/11/09)	
	2) Shajibazar- 2 (13/07/08)	10) Ashuganj -2 (27/11/09)	
	3) Shajibazar-4 (18/10/08)	11) Fenchuganj CCPP GT-2 (05/12/09)	
	4) Khulna 110 (31/03/09)	12) Ashuganj CCPP ST (05/12/09)	
	5) Haripur SBU GT-3 (18/06/09).	13) Haripur SBU GT-2 (06/12/09)	
	6) Shahjibazar 5 (05/08/09)	14) KPCL (11/12/09).	
	7) Shahjibazar -6 (11/10/09).	15) KPCL (11/12/09).	
	8) Raozan -1 (19/10/09)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 321 MW (20:00) of load shed was imposed over the
	whole area (except Sylhet) of the national grid .

- b) Due to gas limitation, Raozan -1, 2 and Shahjibazar 4 & 5 were under shut down.
- c) Baghabari GT-2 was synchronized (on test) at 11:26.

Gas Consumed:

Total

- d) Kaptai -2 was shut down at 12:38 due to maintenance of unit breaker. It is ready now.
- e) Barapukuria unit -1 was forced shut down at 17:50 due to super heater tube leakage.
- f) After maintenance, Ashuganj unit -1 was synchronized at 18:54. But it tripped at 02:40 (12/12/09) showing 'drum level low
- g) After maintenance Ashugani CCPP GT-1 was synchronized at 00:12(12/12/09).
- h) Mirpur 132/33 KV T1 transformer was shut down at 08:06. It is now under maintenance due to breaker problem.
- i) Maniknagar Haripur 132 KV line -1 was under shut down from 08:32 to 15:25 due to air leakage from breaker at Maniknagar end.
- j) Hasnabad Meghnaghat 230 KV line -2, Siddhirganj Haripur 132 KV line -2, Kalyanpur 132/33 KV T3 transformer and Halisahar 132/33 KV T2 transformer were under annual maintenance from 08:56 to 16:19, 09:12 to 15:00, 09:35 to 17:12 and 10:25 to 15:30 respectively.
- k) After maintenance, Khulna South Satkhira 132 KV line was switched on at 15:58.

Deputy / Asstt. Manager Load Despatch Division Load Despatch Division Deputy General Manage Load Despatch Circle

	QF-LDC-08 Page -1	QF-LDC-08 Page -1
emand		
MW		MW
KWHR.		KWHR.
KWHR.		KWHR.
Liter Liter		Liter Liter
Litei		Litei
lding Demand		