

QF-LDC-08
Page -1

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure Raozan (360 MW), RPCL (210 MW) and Baghabari (100 MW) were limited to 140 MW, 91 MW and 70 MW respectively.</p> <p>c) After maintenance Kaptai #3 was synchronized at 08:25 and again tripped at 14:05 due to oil temperature high and was synchronized at 16:15.</p> <p>d) Kaptai #2 tripped at 08:30 due to auxiliary supply failure and was synchronized at 09:45.</p> <p>e) After maintenance Khulna 60 MW was synchronized at 14:15.</p> <p>f) Ashuganj #3 was under shut down at 00:37(11/10/10) due to maintenance of feed water line leakage.</p> <p>g) Dohazari - Sikalbaha 132 KV line-1 was shut down at 12:58 due to protection test and was switched on at 14:05.</p> <p>h) Jessore - Jhenida 132 KV line-1 was under shut down from 07:57 to 10:54 due to red hot maintenance.</p> <p>i) Siddirganj 132/33 KV T2 transformer was under shut down from 21:03 to 21:52 due to red hot maintenance.</p> <p>j) Ishurdi 132/33 KV T1 transformer tripped at 02:20(11/10/10) showing E/F relays.</p>	<p>So about 802 MW (20:00) of load shed was imposed over the whole (except Sylhet) areas of the national grid .</p>
	<p>Due to generation shortage, about 125 MW (09:00) of load shed has been running since morning (11/10/10) over the whole area (except Sylhet) of the national grid.</p>

Deputy / Asstt. Manager

Network Operation Division

Manager

Network Operation Division

Deputy General Manager

Load Despatch Circle