

QF-LDC-08
Page -1

20:00

Reporting Date : 7-Nov-09

Page -1

Gas Consumed :	Total	690.23	MMCFt.	Oil Consumed (PDB) :			
					HSD :	226081	Liter
					FO :	0	Liter

Cost of the Consumed Fuel (PDB) :	Gas	:	Tk51,014,899		Oil	:	Tk9,043,226		Total	:	Tk60,058,125
-----------------------------------	-----	---	--------------	--	-----	---	-------------	--	-------	---	--------------

Area	Yesterday			Today		
	Actual Shedding (s/s end)			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	MW	fro	to			
Dhaka	148	(18:10-23:40, gen. shortage)		1686	214	13%
Chittagong Area	63	(18:10-23:30, gen. shortage)		439	61	14%
Khulna Area	48	(18:10-23:05, gen. shortage)		376	52	14%
Rajshahi Area	41	(18:10-23:30, gen. shortage)		295	41	14%
Comilla Area	40	(18:10-23:25, gen. shortage)		313	44	14%
Mymensing Area	29	(18:10-23:25, gen. shortage)		211	29	14%
Sylhet Area	-	(18:10-23:40, gen. shortage)		193	26	13%
Barisal Area	10	(18:10-23:05, gen. shortage)		77	10	13%
Rangpur Area	22	(18:10-23:30, gen. shortage)		165	23	14%
Total	401	19:30		3755	500	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Ashuganj CCPP ST (04/09/09)
2) Shajibazar- 2 (13/07/08)	10) Shahjibazar -6 (11/10/09).
3) Shajibazar-4 (18/10/08)	11) Raozan -1 (19/10/09)
4) Khulna 110 (31/03/09)	12) Barapukuria -2 (01/11/09)
5) RPCL GT-4 (06/06/09)	13) Shahjibazar GT-9(03/11/09)
6) Haripur SBU GT-3 (18/06/09).	14) Ashuganj CCPP GT-1 (03/11/09)
7) Baghabari GT-2 (02/07/09)	
8) Shajibazar 5 (05/08/09)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to gas limitation Raozan (180 MW), Tongi GT (105 MW), RPCL (160 MW) and HPL (360 MW) were limited to 100 MW, 70 MW , 121 MW and 252 MW respectively.</p> <p>c) Due to gas limitation, Sikalbaha St, Raozan -1 and Shahjibazar- 4 & 5 were under shut down.</p> <p>d) After maintenance, Bhulta 132/33 KV T2 transformer was switched on at 13:20.</p> <p>e) After NLDC project work, Ullon - Siddhirganj 132 KV line -1 was switched on at 13:25.</p> <p>f) After annual maintenance, Khulna (S) - Ishurdi 230 KV line -1, Bogra - Serajganj 132 KV line -2, Kabirpur 132/33 KV T1 transformer, Tongi - Ghorasal 230 KV line -2 and Khulna (C) - Noapara 132 KV line -1 were switched on at 17:44, 15:44, 18:02, 16:23 and 13:58 respectively.</p> <p>g) Rampura 230/132 KV TR1 transformer was under shut down from 10:15 to 11:13 due to red-hot maintenance of Y-phase isolator.</p> <p>h) Ishurdi - Natore 132 KV line -1 and Mymensing 132/33 KV T2 transformer are under annual maintenance since 07:55 (07/11/09) and 08:05 (07/11/09) respectively.</p>	<p>So about 401 MW (19:30) of load shed was imposed over the whole area (except Sylhet) of the national grid .</p>

Deputy General Manager
Load Despatch Circle