		POWER	GRID COMPANY OF BANGLADESH L	TD			Revised	
			IONAL LOAD DESPATCH CENTER	10.			Reviseu	QF-LDC-08
			DAILY REPORT					Page -1
						Reporting Date :	3-Jan-20	
Till now the maximum gener The Summary of Yesterday's	ration is : - s 2-Jan-20	12893 MW Generation & Demand		21:00		1 29-May-19 Ial Min Gen. & Proba	able Con 8 Dom	
Day Peak Generation :		.1 MW	Hour :	12:00	Min. Gen. at	6:00	4682	
Evening Peak Generation :		.0 MW	Hour :	19:00	Available Max		14920	
E.P. Demand (at gen end) :		.0 MW	Hour :	19:00	Max Demand		7700	
Maximum Generation :		.0 MW	Hour :	19:00	Reserve(Gen	eration end)	7220	
Total Gen. (MKWH) :	160	.0 EXPORT / IMPOR	T THROUGH EAST-WEST INTERCO	Dad Factor : 76.37%	Load Shed		0	MW
Export from East grid to West grid	id :- Maximum			-326 MW at	8:00	Energy		MKWHR.
Import from West grid to East grid	id :- Maximum			MW at	-	Energy	-	MKWHR.
Vater Level of Kaptai Lake at 6:0		3-Jan-20			-			
Actual :	95.83 Ft.(MSL) ,			Rule curve : 102.81	Ft.(MSL)			
Gas Consumed :	Total = 1064.	35 MMCFD.		Oil Consumed	(PDB):			
					()	HSD :		Liter
						FO :		Liter
			71.405.000.704					
Cost of the Consumed Fuel (PDE	B+Pvt): Gas Coal		Tk125,908,721 Tk20,241,410	Oil	: Tk56,563,597	Total	Tk202,713,727	
	Coar	•	1820,241,410	- Oli	. 1800,000,001	rotar .	18202,710,727	
	Load Shedd	ling & Other Information						
Area	Yesterday		Fatimated Demand (C/C and)		Today		Rates of Shedd	
	MW		Estimated Demand (S/S end) MW		Esumated Sh	edding (S/S end) MW	(On Estimated D	
Dhaka	0 0:00		2702			0	0%	omand)
Chittagong Area	0 0:00		910			0	0%	
Khulna Area	0 0:00		814			0	0%	
Rajshahi Area	0 0:00		735			0	0%	
) Mymensingh Area	0 0:00 0 0:00		664 536			0	0% 0%	
Sylhet Area	0 0:00		311			0	0%	
Barisal Area	0 0:00		138			0	0%	
Rangpur Area	0 0:00		413			0	0%	
Total	0		7224			0		
	Information of the G	enerating Units under shut de	- March - Marc					
Pla	nned Shut- Down			Forced Shut				
				1) Barapukuria				
				2) Summit Me	ghna 305 MW			
				 Ghorasal U Baghabari 				
				5) Sylhet 150				
				6) Sirajganj ur	nit-3			
				 Ashuganj P 	recision			
				8) Ashuganj u	nit-4,5			
Ado	ditional Information o	f Machines, lines, Interrupt	ion / Forced Load shed etc.					
	Description				Commonto o	n Power Interruptio	-	
a) Hathazari 132/33 kV T-2 trans	Description former was under shut	down from 09:04 to 15:30 f	pr A/M		Comments o	n Power Interruptio	n	
b) Kallyanpur 132/33 kV T-3 tran								
c) Savar-Aminbazar 132 kV Ckt-	2 was under shut dowr	from 09:24 to 17:28 for A/N	1.					
d) Maniknagar 132 kV reserve B			М.					
e) Ullon-Siddirganj 132 kV Ckt w								
f) Tangail-RPCL 132 kV Ckt-2 wa								
 g) Srimongal-Fenchuganj 132 kV h) Fenchuganj-Kulaura 132 kV C 								
 i) Bhulta 400 kV Bus-2 was under shut down from 10:11 to 16:20 for A/M. j) Aminbazar-Kaliakoir 230 kV Ckt-2 was under shut down from 08:53 to 20:15 for C/M. 								
k) Kaliakoir-Kodda 230 kV Ckt was under shut down from 09:05 to 16:33 for A/M.								
I) Natore 132/33 kV T-3 was under shut down from 08:34 to 15:17 for A/M.								
m) Madaripur-Shariatpur132 kV								
 n) Shyampur(old)-Shyampur(Ne was switched on at 09:22. 	w) 132 kV Ckt-2 trippe	d at 08:15 showing dist.BY-	ohase,∠1 and was					
	reformer along with 33	kV Rue section-2 were unde	r shut down from 08:37					
(c) Barishal(S) 132/33 kV T-2 transformer along with 33 kV Bus section-2 were under shut down from 08:37 to 16:47 for 33 kV Bus extension work.								
p) Rampura-Madartek 132 kV Cl	kt-1 was under shut do		VM.					
q) After restoration of gas Bagha								
r) After maintenance Siddirganj-3	335 MW CCPP GT &	ST were synchronized at 17:	07 & 23:16 respectively.					
s) Siddirganj peaking GT_1 was t) Patuakhali 132/33 kV T-3 trans			h air comprossor & CP					
u) Bogura(Old)-Bogura(New) 132 kV Ckt-2 tripped at 04:2 showing dist.O/C relay & inter trip and was switched on at 04:44(3/1/20).								
						power interruption of	curred under Bo	gura old S/S
at 04:26 & 04:28(3/1/20) respectively.						20 to 04:26(3/1/20).		
w) Paramount-200 MW-Baghabari 230 kV Ckt tripped at 04:18(3/1/20) showing O/V and was switched on at 05:05.						ower interruption occ	urrod under Dei-	hahi S/S
x) Rajshahi 132/33 kV T-2 transformer tripped at 04:58(3/1/20) showing O/C relay due to 33 kV incoming CB flashing 09:55(3/1/20) and was switched on at 09:55(3/1/20).						58 to 09:55(3/1/20).	uneu unuer rajs	C/C IIIan
y) Madunaghat 132/33 kV T-1 transformer is under shut down since 07:05(3/1/20) for A/M.								
		. ,						
Sub Divisional Engineer		Executive Engineer				Superintend	lent Engineer	
Network Operation Division		Network Operation Divisio	n			Load Desp		
1					1			