			COMPANY OF BANGLADES							QF-LDC	
			DAILY REPORT				Dea	Deter	0 Mar 00	Page	
Fill now the maximum generation		12893 MW					Hrs on 29-May-		3-Mar-20		
The Summary of Yesterday's Day Peak Generation :	2-Ma	r-20 Generation 8214.4 MW	& Demand Hour	: 12:00			y 's Actual Min Gen. & Pr Gen. at	obable Gen. & D 8:00		576 MW	
Evening Peak Generation :		9756.0 MW	Hour				able Max Generation	0.00		285 MW	
.P. Demand (at gen end) :		9756.0 MW	Hour				Demand (Evening) :	•		00 MW	
Aaximum Generation :		9756.0 MW	Hour	19:30			rve(Generation end)		58	885 MW	
otal Gen. (MKWH) :		189.8	System Load Factor	: 81.04		Load	Shed :			0 MW	
Export from East grid to West grid :- N	lavimum	EXPORT / IMPORT TH	IROUGH EAST-WEST INTER	R CONNEC 248 MW	at	1:00		Energy		MKWHR	
mport from West grid to East grid :- M			-	MW	at	-		Energy		- MKWHR	
Water Level of Kaptai Lake a		3-Mar-20									
Actual : 8	9.43 Ft.(MSL) ,		Rule curv	/e :	92.68	Ft.(MSL)				
Gas Consumed :	Total =	1109.63 MMCFD.		Oil Co	nsumed (PDB):						
							HSD : FO :			Liter Liter	
							10 .			Litei	
Cost of the Consumed Fuel (PDB+Pvt)	:	Gas : Coal :	Tk126,862,977 Tk40,485,338		C	Oil : Tk14	9,475,879	Total : Tk3	816 824 104		
						011 . 1814	9,475,679	10141 . 183	510,024,194		
		ing & Other Information	<u>1</u>								
Area Ye	esterday	Es	timated Demand (S/S end)			Toda Estim	y nated Shedding (S/S end)	Ra	ates of Shedding		
	MW		MW				MW		n Estimated Den		
Dhaka	0 0:0		3327					0	0%		
Chittagong Area Khulna Area	0 0:0 0 0:0		1127 1009					U	0% 0%		
Rajshahi Area	0 0.0		911					0	0% 0%		
Cumilla Area	0 0:0		824					0	0%		
Mymensingh Area	0 0:0		665					0	0%		
Sylhet Area	0 0:0		377					0	0%		
Barisal Area	0 0:0		171					0	0%		
Rangpur Area	0 0:0 0	00	513 8923					0	0%		
				3) Gho 4) Bag 5) Ash 6) Sira 7) Sid 8) Kap	ola 225 MW STG orasal Unit-2,4 & 5. ghabari 100 MW & 7 huganj unit-3,5 ajganj unit-2,3 dhirganj 335 MW otai-2,3,5 dhirgani 210 MW						
Additiona	Il Information of Machines	, lines, Interruption / Fo	prced Load shed etc.	<u> 9) Sia</u>	dhirganj 210 MW						
a) Aminbazar-Savar 132 kV Ckt-1 was	Description	7 to 17.17 for 1/11				Com	ments on Power Interrup	otion			
 b) Sikalbaha 230 kV Bus coupler was u c) Kodda 132/33 kV T-5 transformer was d) Rangpur-Saidpur 132 kV Ckt-1 & 2 w e) Halishahar-Julda 132 kV Ckt-1 & 2 trasphase at Julda end and were switch f) Payra #1 tripped at 18:16 due to proke g) Dhamrai-Kaliakoir 132 kV Ckt-2 was h) Kodda-RPCL 132 kV Ckt is under sh i) Rangpur-Rangpur Confidence 132 kV j) Satkhira 132/33 kV T-2 transformer is k) B.Baria 132/33 kV T-1 transformer is k) B.Baria 132/33 kV T-1 transformer is l) Hasnabad-Lalbagh 132 kV Ckt trippe was switched on at 08:24(3/3/20). m) Sylhet-Fenchuganj 132 kV Ckt-2 tripe end and was switched on at 02:31(3/3 n) Gopalganj 132/33 kV GT-2 transformer on at 09:30(3/3/20). o) Joydevpur 132/33 kV GT-2 transformer switched on at 05:04(3/3/20). p) Ullon-Siddirganj 132 kV Ckt tripped at 07:57(3/3/20). r) Ghorasal #2 tripped at 07:3393/3/20) 	as under shut down from 09 were under shut down from ripped at 08:09 showing dis ned on at 08:28. olem with main steam contro- s under shut down from 08:1 hut down since 07:06(3/3/20 / Ckt-1 & 2 are under shut of s under shut down since 07: s under shut down since 07: s under shut down since 07: s under shut down since 07: d at 07:40 (3/3/20) showing oped at 02:09(3/3/20) show 3/20). ner tripped at 07:04(3/3/20) at 07:41(3/3/20) showing dist.2	9:12 to 12:54 for D/W. 12:25 to 16:10 for D/W. t.Z1,O/C at Halishahar er ol valve. 7 to 16:32 for A/M. 9) for D/W. down since 06:58(3/3/20) 40(3/3/20) for C/M. 53(3/3/20) for C/M. 53(3/3/20) for C/M. 0/C,86 relays at Lalbag ing dist.E/F,A/R block at showing PRD and was s showing dist.RYB-phase st.Z1,BC-phase and was 23,Z4,YB-phase and was	for D/W. h end and Fenchuganj switched e and was switched			areas Abou areas Abou areas Abou	t 38 MW power interruptio from 07:40 to 08:24(3/3/2 t 18 MW power interruptio from 02:09 to 02:31(3/3/2 t 30 MW power interruptio from 04:47 to 05:04(3/3/2 t 52 MW power interruptio from 07:41 to 07:54(3/3/2	20). n occurred under 20). n occurred under 20). n occurred under	Biyanibazar S/S		
Sub Divisional EngineerExecutive EngineerNetwork Operation DivisionNetwork Operation Division							Superintendent Engineer Load Despatch Circle				