			ER GRID COMPANY OF B NATIONAL LOAD DESPA DAILY REPOR	TCH CENTER	D.	F	Reporting Date :	QF-LDC-08 Page -1 15-Apr-20
Till now the maximum gener	ration is : -		893 MW		21:0	0 Hrs on 29-M	ay-19	•
The Summary of Yesterday's	S		neration & Demand			Today's Actual Min Gen. 8		. & Demand
Day Peak Generation :		7847.1 MV			12:00	Min. Gen. at	8:00	7371 MW
Evening Peak Generation :		10344.0 MV			21:00	Available Max Generation	:	15687 MW
E.P. Demand (at gen end):		10344.0 MV			21:00	Max Demand (Evening):		10000 MW
Maximum Generation :		10344.0 MV	V		21:00	Reserve(Generation end)		5687 MW
otal Gen. (MKWH) :		199.3	System Lo		80.30%	Load Shed :		0 MW
		EXPORT / IMP	PORT THROUGH EAST-V					
xport from East grid to West gri	rid :- Maximum			-230 N		5:00	Energy	MKWHR.
nport from West grid to East gri			-	N	MW at	-	Energy	- MKWHR.
Water Level of Kaptai La	ake at 6:00 A M on	15-	-Apr-20					
Actual :	80.09 Ft.	(MSL),		Rule curve :	85.20	Ft.(MSL)		
		•						
Gas Consumed :	Total =	1197.23 MN	MCFD.	C	Oil Consumed (PDB):	HSD FO	<u>:</u>	Liter Liter
Cost of the Consumed Fuel (PDE	B+Pvt):	Gas :	Tk162,401,118					
		Coal :	Tk91,458,904		Oil	: Tk151,792,541	Total :	Tk405,652,563
	<u>Loa</u>	d Shedding & Other Inf	<u>formation</u>					
Area	Yesterday		· · ·	0/0 1)		Today		5. (0.1)
			Estimated Demand (S/S end)		Estimated Shedding (S/S er		Rates of Shedding
	MW		MW			MW		(On Estimated Demand)
haka	0	0:00	3512				0	0%
hittagong Area	0	0:00	1191				0	0%
lhulna Area	0	0:00	1067				0	0%
Rajshahi Area	0	0:00	963				0	0%
tumilla Area	0	0:00	871				0	0%
lymensingh Area	0	0:00	703				0	0%
ylhet Area	0	0:00	397				0	0%
arisal Area	0	0:00	181				0	0%
Rangpur Area	0	0:00	542				0	0%
otal	0		9426				0	
	Information of the Gen	nerating Units under shut	down.					
Die	and Chief Davis							
Plan	nned Shut- Down				Forced Shut-Down			
					1) Barapukuria ST: Unit-2			
					2) Siddhirganj 210 MW GT-1			
				3	3) Ghorasal Unit-1,3,4 & 5.			
					4) Ashuganj unit-5			
					5) Sirajganj unit-2			
				le le	6) Kaptai-2,5			
				15	o) Napia-2,0			
				7	7) Megnaghat-450 MW			
				7	7) Megnaghat-450 MW			
				7	7) Megnaghat-450 MW			
Addi	itional Information of N	Machines, lines, Interru	ption / Forced Load shed (7	7) Megnaghat-450 MW			
	Des	scription	-	7	7) Megnaghat-450 MW	Comments on Power Inter		
) Ramganj 132/33 kV T-2 transt	Des	scription	-	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
i) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT. i) Chatak-Sylhet 132 kV Ckt-2 w	Des former was under shut of	scription down from 08:10 to 11:1	5 for high temperature	7	7) Megnaghat-450 MW			nder Ramganj S/S area
a) Ramganj 132/33 kV T-2 transl at 33 kV bushing CT. b) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.	Des former was under shut ov vas under shut down fro	scription down from 08:10 to 11:1 om 08:30 to 09:59 for air	5 for high temperature pressure low of CB at	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
a) Ramganj 132/33 kV T-2 transl at 33 kV bushing CT. o) Chatak-Sylhet 132 kV Ckt-2 w Chatak end. c) Agargaon 230/132 kV T-2 tran	Des former was under shut ovas under shut down fro	scription down from 08:10 to 11:1 om 08:30 to 09:59 for air ut down from 08:55 to 11	5 for high temperature pressure low of CB at :26 for C/M.	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT.) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajganj unit-2 GT was synch	Des former was under shut own fro vas under shut down fro nsformer was under shu pronized at 10:47 and S	scription down from 08:10 to 11:1 om 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 13	5 for high temperature pressure low of CB at :26 for C/M.	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
) Ramganj 132/33 kV T-2 transf at 33 kV bushing CT.) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajganj unit-2 GT was synch) Khulshi-Halishar 132 kV Ckt-2	Des former was under shut own fro vas under shut down fro nsformer was under shu pronized at 10:47 and S	scription down from 08:10 to 11:1 om 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 13	5 for high temperature pressure low of CB at :26 for C/M.	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT. Chatak-Syhet 132 kV Ckt-2 w Chatak end. Agargaon 230/132 kV T-2 tran) Sirajganj unit-2 GT was synch (Khulshi-Halishar 132 kV Ckt-2 Khulshi end.	Des former was under shut down fro was under shut down fro nsformer was under shu rronized at 10:47 and S' 2 was under shut down f	scription down from 08:10 to 11:1 om 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 13 from 12:10 to 12:24 for b	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT. Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajqanj unit-2 GT was synch) Khulshi-Halishar 132 kV Ckt-2 Khulshi end. Rampura-Bhulta 230 kV Ckt-2	Des former was under shut down fro vas under shut down fro nsformer was under shu rronized at 10:47 and S' 2 was under shut down f	down from 08:10 to 11:1 down from 08:10 to 11:1 im 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1; from 12:10 to 12:24 for b from 11:59 to 16:08 for tr	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming.	7	7) Megnaghat-450 MW	About 20 MW power interru		nder Ramganj S/S area
) Ramganj 132/33 kV T-2 transl at 33 kV bushing CT. Chatak-Sylhet 132 kV Ckt-2 w Chatak end. Agargaon 230/132 kV T-2 tran Sirajganj unit-2 GT was synch J Khulshi-Halishar 132 kV Ckt-2 Khulshi end. Rampura-Bhulta 230 kV Ckt-2	Des former was under shut down fro vas under shut down fro nsformer was under shu rronized at 10:47 and S' 2 was under shut down f	down from 08:10 to 11:1 down from 08:10 to 11:1 im 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1; from 12:10 to 12:24 for b from 11:59 to 16:08 for tr	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming.	7	7) Megnaghat-450 MW	About 20 MW power interru	ption occurred ur	
) Ramganj 132/33 kV T-2 transf at 33 kV bushing CT.) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajganj unit-2 GT was synch) Khulshi-Halishar 132 kV Ckt-2 Khulshi end. Rampura-Bhulta 230 kV Ckt-2) Sylhet 33 kV Bus section-2 we	Des former was under shut down fro vas under shut down fro nsformer was under shu rronized at 10:47 and S' 2 was under shut down f	down from 08:10 to 11:1 down from 08:10 to 11:1 im 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1; from 12:10 to 12:24 for b from 11:59 to 16:08 for tr	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming.	7	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT. O Chatak-Syhte 132 kV Ckt-2 w Chatak end. A Sargaon 230/132 kV T-2 tran A Sargaon 230/132 kV T-2 tran A Sargaon 230/132 kV Ckt-2 Khulshi end. Rampura-Bhulta 230 kV Ckt-2 A Syhte 133 kV Bus section-2 we CB maintenance.	Des former was under shut down fro was under shut down fro nsformer was under shu ronized at 10:47 and S' 2 was under shut down f was under shut down fron as under shut down fron	down from 08:10 to 11:1 down from 08:10 to 11:1 im 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1; from 12:10 to 12:24 for b from 11:59 to 16:08 for tr	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming.	7	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
) Ramganj 132/33 kV T-2 transl at 33 kV bushing CT.) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajganj unit-2 GT was synch) Khulshi-Halishar 132 kV Ckt-2 Khulshi end. Rampura-Bhulta 230 kV Ckt-2) Sylhet 33 kV Bus section-2 wa CB maintenance.) Shahjibazar 330 MW GT-1 syl	Des former was under shut down fro vas under shut down fro nsformer was under shut vronized at 10.47 and S' 2 was under shut down f was under shut down fron under shut down fron	down from 08:10 to 11:10 down from 08:30 to 09:59 for air at down from 08:55 to 11 was synchronized at 13 from 12:10 to 12:24 for b to 11:08 to 12:26 for T-2:	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming.	7	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
at 33 kV T-2 transf at 33 kV bushing CT. () Chatak-Syhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajganj unit-2 GT was synch) Khulshi-Halishar 132 kV Ckt-2 Khulshi end.) Rampura-Bhulta 230 kV Ckt-2 () Syhet 33 kV Bus section-2 wa CB maintenance.) Shahjibazar 330 MW GT-1 sy) Shahjibazar 330 MW GT-1 sy Shahjadpur 132/33 kV T-1 tran	Des former was under shut down fro was under shut down fro nsformer was under shut ronized at 10:47 and S' was under shut down f was under shut down fon su under shut down fron rochronized at 14:27.	teription down from 08:10 to 11:1 on 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1: trom 12:10 to 12:24 for b trom 11:59 to 16:08 for tr n 11:08 to 12:26 for T-2: on at 18:30.	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming.	7	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
a) Ramganj 132/33 kV T-2 transl at 33 kV bushing CT. O Chatak-Sylhet 132 kV Ckt-2 w Chatak end. I) Agargaon 230/132 kV T-2 tran I) Sirajganj unit-2 GT was synch I) Krulshi-Halishar 132 kV Ckt-2 Khulshi end. I) Rampura-Bhulta 230 kV Ckt-2 I) Sylhet 33 kV Bus section-2 we CB maintenance. I) Shahjibazar 330 MW GT-1 syl Shahjiadpur 132/33 kV T-1 tran J After maintenance Baghabari 7	Des former was under shut down fro nsformer was under shut down fro nsformer was under shut nonized at 10.47 and S' was under shut down fro as under shut down fron under shut down from rechronized at 14.27.	down from 08:10 to 11:1 on 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 13 from 12:10 to 12:24 for b from 11:08 to 12:26 for T-21 on at 18:30. d at 18:47.	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming	7	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
at 33 kV T-2 transf at 33 kV bushing CT.) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran I) Sirajganj unit-2 GT was synch I) Khulshi-Halishar 132 kV Ckt-2 Khulshi end.) Rampura-Bhulta 230 kV Ckt-2 CB maintenance.) Shahjibazar 330 MW GT-1 sy Shahjibazar 330 MW GT-1 sy Shahjiadpur 132/33 kV T-1 tran After maintenance Baghabari 7 Barapukuria 230/132 kV T-2	Des former was under shut down fro say under shut down fro insformer was under shut aronized at 10:47 and S' was under shut down for as under shut down from the say under shut down from the	scription down from 08:10 to 11:1 vm 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1: from 12:10 to 12:24 for b from 11:59 to 16:08 for tr in 11:08 to 12:26 for T-2 i on at 18:30. d at 18:47.	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming	etc.	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
i) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT. I) Chatak-Syhte 132 kV Ckt-2 w Chatak end. I) Agargaon 230/132 kV T-2 tran I) Sirajganj unit-2 GT was synch I) Khulshi-Halishar 132 kV Ckt-2 I) Sylhet 33 kV Bus section-2 we CB maintenance. I) Shahjibazar 330 MW GT-1 sy Shahjadpur 132/33 kV T-1 tran I) After maintenance Baghabari 7 I) Barrapukuria 230/132 kV T-2 a showing 508F trp REBSou Showing 508F transport	Des former was under shut down fro was under shut down fro nsformer was under shu ronized at 10-47 and S' was under shut down fro was under shut down fro as under shut down fro morhonized at 14-27. nsformer was witched 71 MW GT synchronize and the shut down fron former was reference to the first former was former to the T-6 transformer and me	cription down from 08:10 to 11:1 m 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1: rom 12:10 to 12:24 for b rom 11:59 to 16:08 for tr n 11:08 to 12:26 for T-2: on at 18:30. d at 18:47. peaks at 18:	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming 0) from 132 kV side ter and 132/33 kV T-3 & T-4	etc.	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
at 33 kV T-2 transf at 33 kV bushing CT.) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 tran) Sirajqanj unit-2 GT was synch) Khulshi-Halishar 132 kV Ckt-2 Khulshi end. Rampura-Bhulta 230 kV Ckt-2) Sylhet 33 kV Bus section-2 wa CB maintenance.) Shahjibazar 330 MW GT-1 sy Shahjadpur 132/33 kV T-1 tran After maintenance Baghabari 7) Barapukuria 230/132 kV T-2 a showing 50BF trip REB500 at 'transformers tripped at 02:36(1)	Des former was under shut down fro was under shut down fro nsformer was under shu ronized at 10-47 and S' was under shut down fro was under shut down fro as under shut down fro morhonized at 14-27. nsformer was witched 71 MW GT synchronize and the shut down fron former was reference to the first former was former to the T-6 transformer and me	cription down from 08:10 to 11:1 m 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1: rom 12:10 to 12:24 for b rom 11:59 to 16:08 for tr n 11:08 to 12:26 for T-2: on at 18:30. d at 18:47. peaks at 18:	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming 0) from 132 kV side ter and 132/33 kV T-3 & T-4	etc.	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
a) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT.) Chatak-Syhet 132 kV Ckt-2 w Chatak end.) Agargaon 230/132 kV T-2 transt 1) Sirajganj unit-2 GT was synch chyloshi-Halishar 132 kV Ckt-2 Khulshi-end.) Rampura-Bhulta 230 kV Ckt-2 Khulshi end.) Syhet 33 kV Bus section-2 we CB maintenance.) Shahjibazar 330 MW GT-1 sy) Shahjibazar 330 MW GT-1 sy) Shahjiadpur 132/33 kV T-1 tran) After maintenance Baghabari 7) Barapukuria 230/132 kV T-2	Des former was under shut down fro was under shut down fro nsformer was under shu ronized at 10-47 and S' was under shut down fro was under shut down fro as under shut down fro morhonized at 14-27. nsformer was witched 71 MW GT synchronize and the shut down fron former was reference to the first former was former to the T-6 transformer and me	cription down from 08:10 to 11:1 m 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1: rom 12:10 to 12:24 for b rom 11:59 to 16:08 for tr n 11:08 to 12:26 for T-2: on at 18:30. d at 18:47. peaks at 18:	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming 0) from 132 kV side ter and 132/33 kV T-3 & T-4	etc.	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
a) Ramganj 132/33 kV T-2 transt at 33 kV bushing CT. O) Chatak-Sylhet 132 kV Ckt-2 w Chatak end.) Agargano 230/132 kV T-2 transt 1) Sirajganj unit-2 GT was synch b) Khulshi-Halishar 132 kV Ckt-2 Khulshi end.) Rampura-Bhulta 230 kV Ckt-2 I) Sylhet 33 kV Bus section-2 ws CB maintenance. O) Shahjibazar 330 MW GT-1 sy I) Shahjibazar 330 MW GT-1 sy I) Shahjibazar 330 MW GT-1 sy I) Shapibazar 320 MW GT-2 showing 50BF trip REB500 at transformers tripped at 02:36(1) on at 03:10(15/04/2020).	Des former was under shut down fro was under shut down fro nsformer was under shu ronized at 10-47 and S' was under shut down fro was under shut down fro as under shut down fro morhonized at 14-27. nsformer was witched 71 MW GT synchronize and the shut down fron former was former tire.	cription down from 08:10 to 11:1 m 08:30 to 09:59 for air at down from 08:55 to 11 T was synchronized at 1: rom 12:10 to 12:24 for b rom 11:59 to 16:08 for tr n 11:08 to 12:26 for T-2: on at 18:30. d at 18:47. peaks at 18:	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming 0) from 132 kV side ter and 132/33 kV T-3 & T-4	etc.	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	
at 33 kV bushing CT. 1) Chatak-Sylhet 132 kV Ckt-2 w Chatak end. 1) Agargaon 230/132 kV T-2 transl 2) Sirajganj unit-2 GT was synch 2) Khulshi-Halishar 132 kV Ckt-2 Khulshi end. 1) Rampura-Bhulta 230 kV Ckt-2 1) Sylhet 33 kV Bus section-2 wa CB maintenance. 2) Shahjiabazar 330 MW GT-1 syl 3) Shahjiadpur 132/33 kV T-1 transl 2) Barapukuria 230/132 kV T-2 a showing 50BF trip REB500 at 1 transformers tripped at 02:36(11	Des former was under shut down fro was under shut down fro nsformer was under shu ronized at 10-47 and S' was under shut down fro was under shut down fro as under shut down fro morhonized at 14-27. nsformer was witched 71 MW GT synchronize and the shut down fron former was former tire.	scription down from 08:10 to 11:1 wn 08:30 to 09:59 for air ut down from 08:55 to 11 T was synchronized at 13 rom 12:10 to 12:24 for b rom 11:59 to 16:08 for tr n 11:08 to 12:26 for T-21 on at 18:30. d at 18:47. goed at 02:36(05)04/202 aster trip at T-2 transform 6 CB lock out at T-3 trans	5 for high temperature pressure low of CB at :26 for C/M. 3:10. ird nest removing at ee trimming. transformer incoming 0) from 132 kV side ter and 132/33 kV T-3 & T-4	etc.	7) Megnaghat-450 MW	About 20 MW power interru from 08:10 to 11:15.	ption occurred ur	nder Sylhet S/S area