1			POWER GRID CO	MPANY OF BAI	NGLADESH L	TD.					
1				OAD DESPATO							QF-LDC-0
			D	DAILY REPORT	Г						Page -
Till now the maximum a	oneration is :		12893 MW				21:	00 Hrs on	Reporting Date : 29-May-19	14-May-20	
Till now the maximum go The Summary of Yesterd		13-May-20	Generation & De	mand			21:		Sen. & Probable Gen.	& Domand	
Day Peak Generation :	iay s		.3 MW	manu	Hour :	12:00		Min. Gen. at	6:00	7208 MW	
Evening Peak Generation :			.0 MW		Hour :	21:00		Available Max Genera		14697 MW	
E.P. Demand (at gen end) :			.0 MW		Hour :	21:00		Max Demand (Evening		11500 MW	
Maximum Generation :			.0 MW		Hour:	1:00		Reserve(Generation e		3197 MW	
Total Gen. (MKWH) :		223		System Loa		: 88.17%		Load Shed	:	0 MW	
		EXPOR	RT/IMPORT THRO	UGH EAST-WE	ST INTERCO		R				
Export from East grid to Wes					-20	1 MW	at	19:00	Energy	MKW	
Import from West grid to East			-			MW	at	-	Energy	- MKW	HR.
	ai Lake at 6:00 A M on		14-May-20								
Actual :	76.30	Ft.(MSL),			Rule curve	:	79.53	Ft.( MSL )			
Gas Consumed :	Total =	4400	72 MMCFD.			010	I (DDD)				
Gas Consumed :	i otai =	1193.1	2 MINICED.			Oil Cons	umed (PDB):		HSD :	Liter	
									HSD : FO :		
									FO :	Liter	
Cost of the Consumed Fuel	(DDB : D:#) :	0	_	TL170 E2E 11E							
Cost of the Consumed Fuel	(PDB+PVI):			Tk170,535,115 Tk83,595,848			Oil	. TI-000 040 000	T-4-1	TI-FOO 244 024	
i		Coal	<u> </u>	1883,595,848			Oll	: Tk266,213,068	TOTAL :	Tk520,344,031	
		Load Shedding & Otl	har Information								
		Load Siledding & Ott	ler iniormation								
Area	Yesterday							Today			
	rootoraay		Estim:	ated Demand (S/	(S end)			Estimated Shedding (	S/S end)	Rates of Shedding	
	MW			MW	,					(On Estimated Demand)	
Dhaka	0	0:00		4110					0	0%	
Chittagong Area	0	0:00		1399					0	0%	
Khulna Area	0	0:00		1254					0	0%	
Rajshahi Area	0	0:00		1133					0	0%	
Cumilla Area	0	0:00		1024					0	0%	
Mymensingh Area	0	0:00		826					0	0%	
Sylhet Area	0	0:00		460					0	0%	
Barisal Area	0	0:00		213					0	0%	
Rangpur Area	0	0:00		637					0	0%	
Total	0			11055					0		
	Information of the	Generating Units unde	r shut down.								
	Planned Shut- Down						01 / 5				
	Planned Shut- Down						Shut- Down	_			
						Barag     Bibiya	oukuria ST: Unit-1,	2			
								-			
							asal Unit-1,2,3,5 & ganj unit-5	7.			
							ganj-335 MW				
						6) Kapta	i-2,5				
						6) Kapta 7) Raoz	i-2,5 an # 2				
						6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	. 97			
						6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2	ST.			
	Additional Information	n of Machines, lines, l	nterruption / Forcec	d Load shed etc.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	st.			
,	Additional Information		nterruption / Forcec	d Load shed etc.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW				
		Description		d Load shed etc.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	Comments on Powe	r Interruption		
a) Chapainawabganj 132/33	kV T2 transformer was	Description s shut down at 09:53 fo	or gas filling.			6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k	kV T2 transformer was	Description s shut down at 09:53 for t down from 12:05 to 13	or gas filling. 3:40 due to R/H at R-			6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k c) Hathazari 132/33 kV T2 tr	kV T2 transformer was V Ckt-2 was under shu ransformer was under s	Description s shut down at 09:53 fo t down from 12:05 to 13 thut down from 11:28 to	or gas filling. 3:40 due to R/H at R- o 12:10 for C/M.	-phase isolator.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k c) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k'	kV T2 transformer was V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1	Description s shut down at 09:53 for t down from 12:05 to 13 that down from 11:28 to 4 from both ends and v	or gas filling. 3:40 due to R/H at R- o 12:10 for C/M. vas switched on at 17	-phase isolator.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k c) Hathazir 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k' e) Aminbazar-Mirpur 132 kV	kV T2 transformer was V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1	Description s shut down at 09:53 for t down from 12:05 to 13 that down from 11:28 to 4 from both ends and v	or gas filling. 3:40 due to R/H at R- o 12:10 for C/M. vas switched on at 17	-phase isolator.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k c) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k' e) Aminbazar-Mirpur 132 kV switched on at 15:55.	3 kV T2 transformer was kV Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:10 Ckt-1 tripped at 15:30	Description s shut down at 09:53 fo t down from 12:05 to 13:05 thut down from 11:28 to 4 from both ends and v from Aminbazar end si	or gas filling. 3:40 due to R/H at R- o 12:10 for C/M. vas switched on at 17 howing RST relay an	-phase isolator. 7:16. nd was		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k c) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k' e) Aminbazar-Mirpur 132 kV switched on at 15:55. f) Aminbazar-Manikganj PP	3 kV T2 transformer was kV Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:10 Ckt-1 tripped at 15:30	Description s shut down at 09:53 fo t down from 12:05 to 13:05 thut down from 11:28 to 4 from both ends and v from Aminbazar end si	or gas filling. 3:40 due to R/H at R- o 12:10 for C/M. vas switched on at 17 howing RST relay an	-phase isolator. 7:16. nd was		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalbaha-Dohazari 132 k c) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k e) Aminbazar-Mirpur 132 kV switched on at 15:55. f) Aminbazar-Manikganj PP switched on at 16:18.	3 kV T2 transformer was kV Ckt-2 was under shu ransformer was under stu Y Ckt-1 tripped at 16:1 Y Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped a	Description s shut down at 09:53 fot t down from 12:05 to 13 hut down from 11:28 to 4 from both ends and v from Aminbazar end si t 15:49 from Aminbaza	or gas filling. 3:40 due to R/H at R- 5:12:10 for C/M. vas switched on at 17 howing RST relay an	-phase isolator. 7:16. Id was 72 and was		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikaibaha-Dohazari 132 ko O Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k e) Aminbazar-Mirpur 132 kV switched on at 15:55. f) Aminbazar-Manikganj PP switched on at 16:18. g) Ashuganj(S)-Ghorashal 2: h) Tangail-Kaliakoir 132 kV t	is kV T2 transformer was kV Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1- Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at	Description s shut down at 09:53 fot town from 12:05 to 13; thut down from 11:28 to 4 from both ends and v from Aminbazar end sit 15:49 from Aminbazar and 16:31 showing Dist. and	or gas filling. 3:40 due to R/H at R- 112:10 for C/M. vas switched on at 17 howing RST relay an r end showing Dist. 2 d was switched on at	-phase isolator. 7:16. Ind was Z2 and was		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalibaha-Dohazari 132 k o Hathazari 132/33 k V Tz t d) Ghorashal-Ishwardi 230 k e o Aminbazar-Mirpur 132 kV switched on at 15:55. f) Aminbazar-Manikganj PP switched on at 16:18. g) Ashuganj(S)-Ghorashal 2: h) Tangal-Kaliakoir 132 kV t switched on at 22:18.	I kV T2 transformer was V Ckt-2 was under shu ransformer was under so V Ckt-1 tripped at 16:1 Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at 21:	Description shut down at 09:53 fot down from 12:05 to 11 thut down from 11:28 to 4 from both ends and v from Aminbazar end si t 15:49 from Aminbazar end si t 15:49 from Tangail end sh 70m Tangail end sh	or gas filling. 3:40 due to R/H at R- 12:10 for C/M. vas switched on at 1: howing RST relay an rr end showing Dist. 2 d was switched on at sowing General trip, 2	-phase isolator. 7:16. nd was 22 and was 117:43. 22 and was		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW		r Interruption		
a) Chapainawabganj 132/33 b) Sikalibaha-Dohazari 132 k c) d) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k e) Aminbazar-Mirpur 132 kV switched on at 15:55 f) Aminbazar-Manikganj PP switched on at 16:18. g) Ashuganj(S)-Ghorashal z: h) Tangail-Kaliakoir 132 kV t switched on at 22:18. i) Aminbazar-Mirpur 132 kV t switched on at 22:18.	k V T2 transformer was (V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1-1 Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at 21: Ckt-1&2 was shut down	Description sishut down at 09:53 for down from 12:05 to 11:04 for more of the description	or gas filling. 3:40 due to R/H at R. or 12:10 for C/M. vas switched on at 17: howing RST relay an ir end showing Dist. 2 d was switched on at sowing General trip, 2 for C/M at Mirpur S/	-phase isolator. 7:16. Id was Z2 and was 117:43. Z2 and was S.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	Comments on Powe		udor Whulishi S/S green	
a) Chapainawabganj 132/33 b) Sikialibaha-Dohazari 132 k o) Haltazari 132/33 k V Tz t d) Ghorashal-Ishwardi 230 k! e) Aminbazar-Minpur 132 kV switched on at 15:55. f) Aminbazar-Manikganj PP switched on at 16:18. g) Ashuganj(S)-Ghorashal 2: h) Tangal-Kaliakoir 132 kV t switched on at 22:18.	k V T2 transformer was (V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1-1 Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at 21: Ckt-1&2 was shut down	Description sishut down at 09:53 for down from 12:05 to 11:04 for more of the description	or gas filling. 3:40 due to R/H at R. or 12:10 for C/M. vas switched on at 17: howing RST relay an ir end showing Dist. 2 d was switched on at sowing General trip, 2 for C/M at Mirpur S/	-phase isolator. 7:16. Id was Z2 and was 117:43. Z2 and was S.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	Comments on Powe	nterruption occurred un		
a) Chapainawabganj 132/33 b) Sikalibaha-Dohazari 132 k c) d) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k e) Aminibazar-Mirpur 132 kV switched on at 15:55 f) Aminbazar-Manikganj PP switched on at 16:18. g) Ashuganj(S)-Ghorashal z: h) Tangail-Kaliakoir 132 kV t switched on at 22:18. i) Aminbazar-Mirpur 132 kV t switched on at 22:18.	k V T2 transformer was (V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1-1 Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at 21: Ckt-1&2 was shut down	Description sishut down at 09:53 for down from 12:05 to 11:04 for more of the description	or gas filling. 3:40 due to R/H at R. or 12:10 for C/M. vas switched on at 17: howing RST relay an ir end showing Dist. 2 d was switched on at sowing General trip, 2 for C/M at Mirpur S/	-phase isolator. 7:16. Id was Z2 and was 117:43. Z2 and was S.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	Comments on Powe			
a) Chapainawabganj 132/33 b) Sikalibaha-Dohazari 132 k o) d) Hathazari 132/33 k V T2 tr d) Ghorashal-Ishwardi 230 k e) Aminbazar-Mirpur 132 k V switched on at 16:18. g) Ashuganj(S)-Ghorashal z: h) Tangail-Kaliakoir 132 k V t switched on at 22:18. i) Arninbazar-Mirpur 132 k V t switched on at 22:18.	k V T2 transformer was (V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1-1 Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at 21: Ckt-1&2 was shut down	Description sishut down at 09:53 for down from 12:05 to 11:04 for more of the description	or gas filling. 3:40 due to R/H at R. or 12:10 for C/M. vas switched on at 17: howing RST relay an ir end showing Dist. 2 d was switched on at sowing General trip, 2 for C/M at Mirpur S/	-phase isolator. 7:16. Id was Z2 and was 117:43. Z2 and was S.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	Comments on Powe	nterruption occurred un		
a) Chapainawabganj 132/33 b) Sikalibaha-Dohazari 132 k c) d) Hathazari 132/33 kV T2 tr d) Ghorashal-Ishwardi 230 k e) Aminbazar-Mirpur 132 kV switched on at 15:55 f) Aminbazar-Manikganj PP switched on at 16:18. g) Ashuganj(S)-Ghorashal z: h) Tangail-Kaliakoir 132 kV t switched on at 22:18. i) Aminbazar-Mirpur 132 kV t switched on at 22:18.	k V T2 transformer was (V Ckt-2 was under shu ransformer was under s V Ckt-1 tripped at 16:1-1 Ckt-1 tripped at 15:30 132 kV Ckt-1 tripped at 30 kV Ckt-2 tripped at 21: Ckt-1&2 was shut down	Description sishut down at 09:53 for down from 12:05 to 11:04 for more of the description	or gas filling. 3:40 due to R/H at R. or 12:10 for C/M. vas switched on at 17: howing RST relay an ir end showing Dist. 2 d was switched on at sowing General trip, 2 for C/M at Mirpur S/	-phase isolator. 7:16. nd was Z2 and was 17:43. Z2 and was S. ) for C/M.		6) Kapta 7) Raoz 9) Chan	i-2,5 an # 2 dpur 163 MW	Comments on Powe	nterruption occurred un	).	