		POWER GRID COMPANY OF B		TD.					OPID
		NATIONAL LOAD DESPA DAILY REPO							QF-LDC Pag
							Reporting Date :	4-Oct-20	1 ag
ill now the maximum generation is : -	3-Oct-20	12893 MW			21:0		29-May-19		
The Summary of Yesterday's Day Peak Generation :	3-Oct-20 9624.0	Generation & Demand	Hour :	12:00		Min. Gen. at	n Gen. & Probable Gen. 8 8:00		80 MW
Evening Peak Generation :	12091.0		Hour :	20:00		Available Max Gene			88 MW
E.P. Demand (at gen end) :	12091.0		Hour :	20:00		Max Demand (Ever			00 MW
Maximum Generation :	12091.0		Hour:	20:00		Reserve(Generatio	n end)		88 MW
Fotal Gen. (MKWH) :	243.		oad Factor	: 83.79%		Load Shed	:		0 MW
Export from East grid to West grid :- Maxim		T/IMPORT THROUGH EAST-V		NNECTOR 2 MW = a		21:00	Energy		MKWHR.
mport from West grid to East grid :- Maxim		-	5.	MW a		21.00	Energy Energy		- MKWHR.
Water Level of Kaptai Lake at 6:00		4-Oct-20		IVIVV C			Liicigy		MICWIN.
Actual : 99.42			Rule curve	:	106.27	Ft.(MSL)			
	T . 1	2 MMCFD.		010	I (DDD)				
Gas Consumed :	Total = 1120.12	MINICED.		Oil Consun	ned (PDB):		HSD :		Liter
							FO :		Liter
		T1 4 4 7 4 0 5 0 7							
ost of the Consumed Fuel (PDB+Pvt) :	Gas Coal	: Tk147,135,87 : Tk79,401,778			Oil	: Tk618,250,589	Total · T	k844,788,239	
	Coai	. 1875,401,770	,		Oil	. 1k010,230,309	Total . I	K044,700,233	
	Load Shedding & Other	er Information							
Nego Y .	dov					Today			
Area Yestero	uay	Estimated Demand	(S/S end)			Today Estimated Shedding	g (S/S end)	Rates of Shedding	
MW		MW	(2. 2 0.10)			_oa.oa onoddin		On Estimated Dem	
Dhaka 0	0:00	4528					0	0%	- '
Chittagong Area 0	0:00	1544					0	0%	
Khulna Area 0	0:00	1384					0	0%	
Rajshahi Area 0 Cumilla Area 0	0:00 0:00	1251					0	0% 0%	
Jumilia Area 0 Mymensingh Area 0	0:00	1130 912					0	0%	
Sylhet Area 0	0:00	505					0	0%	
Barisal Area 0	0:00	235					0	0%	
Rangpur Area 0	0:00	703					0	0%	
otal 0		12191					0		
	(11.0 5.11.5 1								
informatio	on of the Generating Units under	snut down.							
				4) Ashugar 5) Kaptai-2 6) Raozan 7) Siddirga	,4,5				
Additional Info		erruption / Forced Load shed e	tc.			O			
a) Aminbazar-Kaliakoir 132 kV Ckt-1 was u	Description nder shut down from 09:42 to 16	59 for Δ/M				Comments on Pov	wer Interruption		
 Aminbazar-Kailakolf 132 kV Ckt-1 was ui) Mirpur-Uttara 132 kV Ckt was under shut) B.Pukuria-Saidpur 132 kV Ckt-1 was und at Saidpur end. Mymensing-Netrokona 132 kV Ckt-1 was) Mymensing-Netrokona 132 kV Ckt-1 was 	down from 08:20 to 17:50 for A der shut down from 10:08 to 23:13	M. 3 due to problem at CT							
) Mymensing 132 kV Bus-B was under shu HVDC 10CF13 filter was under shut dowr)) Tangail 1323 kV T-2 transformer was u) Rangpur 132/33 kV T-1 transformer was s Bogura 230/132 kV T-1 transformer was u After maintenance Ashuganj(N)-360 MW) Summit Megnaghat-305 MW GT-2 was s	n from 09:14 to 16:05 for A/M. under shut down from 08:2 to 12: under shut down from 08:10 to 1 under shut down from 08:11 to 1 CCPP ST was synchronized at 0	32 for C/M. 6:20 for A/M. 7:44 for A/M.							
Chandraghona-Rangamati 132 kV Ckt-1 n) Natore 132/33 kV T-1 transformer was u Natore 132/33 kV T-2 transformer was u) Natore 132/33 kV T-2 transformer was ui) Chandraghona-Rangamati 132 kV Ckt-2) Bibiyana-3 CCPP GT & ST were synchro J Haripur-Megnaghat 230 kV Ckt-1 was un) Barapukuria 132/33 kV T-3 transformer tr	was under shut down from 10:35 under shut down from 13:11 to 14 nder shut down from 14:15 to 14 was under shut down from 17:17 unized at 16:37 & 17:18 respectiv der shut down from 08:15 to 21:	:33 for C/M. :44 for C/M. / to 21:06 for D/W. ely. 10 for A/M.							
on at 16-41. s) Chandraghona-Rangamati 132 kV Ckt-1 tripped at 17:31 showing gen.trip at Chandraghona end and was switched on at 17:40. t) Bagerhat-Bhandaria 132 kV Ckt was under shut down from 06:23 to 08:38(4/10/20) for red hot maint. t) Chowmuhoni 13/2/3 kV T-1 transformer is under shut down since 06:32(4/10/20) for C/M.						About 25 MW power interruption occurred under Rangamati & Khagrachari S/S areas from 17:31 to 17:40. About 20 MW power interruption occurred under Chowmuhoni S/S area			
Raozan #1 tripped at 03:02(4/10/20) due) Kuiara-163 MW CCPP GT was synchror Siddirganj-Maniknagar 230 kV Ckt-1 is ur Ashuganj(S)-360 MW CCPP GT was syn	to boiler trip and was synchroniz nized at 22:58 and shut down at 0 nder shut down since 07:17(4/10/	ed at 04:46(4/10/20). 06:40(4/10/20) for internal problem	1.			since 06:32(4/10/20		o Grownundii S	o alca
Sub Divisional Engineer etwork Operation Division		Executive Engineer Network Operation Division					Superintendent I Load Despatch		