Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2020 | Day : **Tuesday** | Date : **10.11.20**

Probable Maximum Demand : 10400 MW | **Probable Maximum Generation :** 13965 MW

Water Level of Kaptai Lake at 06:00 AM Yesterday = **104.19** ft Today = **104.07** ft. Rule Curve = **108.10** ft.

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.11.20 (Yesterday) Actual Peak Generation (MW)		10.11.20 (Today) Probable Peak Generation (MW)		09.11.20 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A)	**Plants in operation:**													
1	a) Ghorasal TPP (Unit-1&2)	Gas	(PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.	
	b) Ghorasal Repowered CCPP Unit-3	Gas	(PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.	
	c) Ghorasal Repowered CCPP Unit-4	Gas	(PDB)	1 x 210	210	180	170	150	150	150				
	d) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	115	115	115	115	75		Gas Shortage	
2	Ghorasal 365 MW CCPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	200	200	200	200				
3	Ghorashal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	31	31	35	35	77		Gas Shortage	
4	Ghorashal 78.5 MW PP(MAX)	Gas	(QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage	
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas	(PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas	(IPP)	1x235+1x125	360	360	315	305	360	360				
8	Meghnaghat 450 MW CCPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	350	330	450	450				
9	210 MW Siddhirgonj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas	(EGCB)	1x273+1x139	412	412	0	0	0	0		412	Dust in gas	
11	Siddhirgonj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	95	57	100	100	153		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas	(EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.	
13	Siddhirganj 100 PP(Dutch Bangla)	HFO	(QRPP)	12x8.9	100	100	100	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS	(IPP)	2x110+1x110	305	305	150	140	155	155		165	GT-1 Under maint.	
15	Meghnaghat 100 MW(IEL)	HFO	(QRPP)	12x8.9	100	100	45	100	100	100				
16	Madanganj 102 PP(Summit)	HFO	(QRPP)	6x17	102	100	30	97	100	100				
17	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
18	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	100	0	0	50	100				
19	Gagnagar 102 MW PP (Digital Powe	HFO	(IPP)	12x8.924	102	102	94	94	100	100				
20	Narshingdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	16	19	19	19				
21	Summit Power,(Madhabdi+Ashulia)	Gas	(SIPP, REB)	6x3.67+7x8.73	80	80	47	56	56	56				
22	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	33	33	33	33				
23	Rupganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	25	25	33	33				
24	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	0	52	52	52				
25	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	105	104	100	100				
26	Kodda 150MW PP	HFO	(BPDB-RPCL)	9x17.06	149	149	0	150	150	150				
27	Katpotti 52 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	51	0	13	0	0				
28	Kamalaghat 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	54	54	54	54				
29	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	16	296	300	300				
30	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	0	59	149	149				
31	Keranigonj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	0	0	100	300				
32	Bramhangoan 100 MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Aurahati 100MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	60	100				
34	Nababganj 55 MW PP (Southern po	HFO	(IPP)	3x19.3	55	55	0	17	55	55				
35	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	55	55	55	55				
36	Bosila 108MW PP(CLC)	HFO	(IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
37	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	90	26	90	90				
	Manikgonj 162MW PP	HFO	(IPP)				15	0	0	0				
	Dhaka Zone Total				**6119**	**5895**	**2206**	**2733**	**3426**	**3766**	**508**	**1282**		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	159	163	160	160	67		Low Water Level	
39	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	115	115	120	120	65		Gas Shortage	
	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar	(PDB)		7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	0	0	25	25				
42	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	50	50	50	50				
44	Sikalbaha 105 MW PP (Baraka Sika	HFO	(IPP)	6x18.415	105	105	0	0	100	100				
45	Shikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	145	139	0	0				
46	Sikalbaha 225 MW CCPP	Gas	(PDB)	1 x 150+1 x 75	225	225	0	30	200	200	195		Gas Shortage	
47	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+ 3x8.04	300	300	250	178	300	300				
48	Juldah 100 MW Unit-1 (Acorn)	HFO	(QRPP)	8x13.45	100	100	0	0	100	100				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO	(IPP)	8x13.45	100	100	90	100	100	100				
50	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	0	51	102	102				
51	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	0	0	0	0				
52	Barabkunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	20	20	20	20				
*	Malancha, Ctg.EPZ (United)	Gas		5x8.73+3x9.34			3	18	10	20				
53	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	0	64	90	90				
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	52	54	54	54				
55	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
56	Juldah unit-2 (Acorn)	HFO	(IPP)	8x13.6	100	100	100	100	100	100				
	Chattogram Zone Total				**2326**	**2266**	**988**	**1082**	**1666**	**1651**	**327**	**180**		
57	a) Ashuganj TPP Unit- 3	Gas	(APSCL)	1 x 150	150	135	135	100	100	100	35		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas	(APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas	(APSCL)	1 x 150	150	134	100	100	100	100	34		Gas Shortage	
58	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	45	26	29	30	30				
59	Ashuganj 225 MW CCPP	Gas	(APSCL)	1×142+1*75	221	221	179	180	225	225				
60	Ashuganj 450 MW CCPP(South)	Gas	(APSCL)	1x360	360	360	0	0	0	0		360	Under maint.	
61	Ashuganj 450 MW CCPP(North)	Gas	(APSCL)	1x361	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15*4	55	55	54	30	30	30	25		Gas shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas	(IPP)	20*9.73+1*16	195	195	83	68	68	68	127		Gas shortage	
64	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	55	130	150	150				
66	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	0	0	0	50				
67	Chandpur 150 MW CCPP	Gas	(PDB)	1X106+1x57	163	163	0	70	70	70				
68	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	0	0	165	180				
69	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	0	0	22	22				
70	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	33	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	0	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	18	18	20	21				
74	Daudkandi 200 MW PP (B.Trac)	HSD	(IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO	(IPP)	7*18.415+1*9.78	114	114	0	0	114	114				
76	Chowmuhani 113 MW	HFO	(IPP)	12*9.78+2*3.1	113	113	41	113	113	113				
**	Impoprt (Tripura)		India		160	160	96	130	158	173				
	Cumilla Zone Total				**3040**	**2980**	**882**	**1115**	**1512**	**1793**	**350**	**720**		
77	RPCL 210MW CCPP	Gas	(IPP)	4x35+1x70	210	202	98	103	120	120	99		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	22	20	22	22				
79	Jamalpur 95 MW PP(Powerpac)	HFO	(IPP)	12x8.924	95	95	25	25	25	25				
80	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	85	115	115	115				
81	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	0	80	200	200				
82	Sarishabari 3 MW Solar Plant	Solar	(IPP)	12x8.924	3	3	0	0	1.6	0				
	Mymensingh PV 50 MW Solar PP	Solar	(IPP)				56	0	40	0				
	Mymensing Zone Total				**645**	**637**	**286**	**343**	**523.6**	**482**	**99**	**0**		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.11.20 (Yesterday) Actual Peak Generation (MW)		10.11.20 (Today) Probable Peak Generation (MW)		09.11.20 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
83	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	44	44	43	44				
84	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
85	Fenchugonj 51 MW PP (Barakatulla	Gas	(RPP)	19x2.90	51	51	44	44	51	51				
86	Fenchuganj 44MW (Energyprima)	Gas	(RPP)	12x3.3+5x2.0	44	44	46	49	44	44				
87	Kushiara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	110	107	110	110				
88	Hobiganj 11MW PP Cofidence-E	Gas	(SIPP, REB)	4x2.90	11	11	2	8	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	62	55	65	65				
90	Shajibazar 330 MW CCPP	Gas	(PDB)	2x110+2x110	330	330	160	158	160	160	172		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar	Gas	(RPP)	32x2.90	86	86	82	82	86	86				
92	Sylhet 225 MW CCPP	Gas	(PDB)	1x142+1x89	231	231	178	217	200	220				
93	Sylhet 20 MW GTPP	Gas	(PDB)	1 x 20	20	20	18	17	18	18				
94	Sylhet 50MW PP (EPL)	Gas	(RPP)	27x2.0	50	50	0	0	0	0				
95	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	22	24	25	25				
97	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	290	280	341	341				
98	Bibiyana-III 400 MW CCPP	Gas	(PDB)	1x285+1x115	400	400	376	422	400	400				
	Bibiyana South 400 MW	Gas	(PDB)				0	0	0	0				
	Sylhet Zone Total				**2033**	**1988**	**1474**	**1547**	**1594**	**1615**	**172**	**60**		
99	Bheramara GTPP Unit- 3	HSD	(PDB)	1 x 20	20	16	0	0	0	16				
100	Bheramara 410 MW CCPP	Gas	(NWPGCL)	1 x 278+1 x 132	410	410	385	345	410	410				
101	Faridpur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	0	0	30				
102	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	0	0	60				
103	Khulna 225 MW CCPP	HSD	(NWPGCL)	1 x 150+1x75	230	230	0	0	0	220				
104	Khulna 115 PP MW (KPCL-2)	HFO	(QRPP)	7x17	115	115	0	83	115	115				
105	Noapara 100 MW PP (Bangla Trac)	HSD	(IPP)	70x1.4+7x1.515	100	100	0	0	0	100				
106	Noapara 40 MW PP (Khanjahan Ali)	HFO	(QRPP)	5x8.5	40	40	0	8	40	40				
107	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	70	105	105	105				
108	Madhumati 100 MW PP	HFO	(NWPGCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)		India		1000	1000	716	825	740	853				
	Khulna Zone Total				**2288**	**2284**	**1171**	**1366**	**1510**	**2049**	**0**	**0**		
109	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	0	64	110	110				
110	Bhola 33 MW PP (Venture)	Gas	(RPP)	1x34.50	33	33	14	22	22	22				
111	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
112	Bhola 95 MW PP (Aggreko)	Gas	(QRPP)	1.1x96	95	95	35	91	95	95				
113	Payra 1320 MW Unit-1	Coal	(BCPCL)	1x622	622	622	410	590	600	660				
	Bhola Nutan Biddut BD LTD	Gas/HSD	(IPP)				34	0	0	0				
	Barishal Zone Total				**1054**	**1054**	**493**	**767**	**827**	**887**	**0**	**194**		
114	a) Baghabari 71 MW GTPP	Gas	(PDB)	1 x 71	71	71	65	55	70	70	16		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas	(PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
115	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	0	0	50				
116	Baghabari 200 MW PP (Paramount)	HSD	(IPP)	135x1.6	200	200	0	0	200	200				
117	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	0	0	40				
118	Amnura 50 MW PP(Sinha)	HFO	(QRPP)	7x7.79	50	50	0	0	0	0				
119	Chapainawabganj 100 MW Peaking	HFO	(PDB)	12x8.924	104	104	0	90	100	100				
120	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	0	50	50				
121	Katakhali 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	0	0	0	0				
122	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	0	0	33				
123	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGCL)	1x150+1x75	210	210	144	146	150	150				
124	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGCL)	1x150 + 1x75	220	220	177	171	225	225				
125	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGCL)	1x141+1x79	220	220	182	185	220	220				
126	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	0	0	0	0		414	Under maint.	10/11/2020
127	Bogra 22 MW PP (GBB)	Gas	(RPP)	6x4.0	22	22	21	22	22	22				
128	Bogura 20 MW PP (Energyprima)	Gas	(RPP)	5x3.3+5x2.0	20	10	10	10	10	10				
129	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	9	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	0	0	52	52				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO	(IPP)	6*18.55	113	113	20	109	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO	(IPP)	6x18.55	113	113	0	0	113	113				
	Rajshahi Zone Total				**2193**	**2183**	**628**	**799**	**1336**	**1459**	**116**	**414**		
133	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
134	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	150	150	150	150				
135	Rangpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	0				
136	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	4	106	113	113				
137	Saidpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	0				
138	Majipara, Tatulia 8 MW Solar PP (Sympa Pt	Solar	(IPP)	1 x 8	8	8	6	0	8	0				
	Rangpur Zone Total				**685**	605	**160**	**256**	**271**	**263**	**170**	**0**		
	Sub-total: Plants in operation				**20383**	**19892**	**8288.0**	**10008**	**12666**	**13965**	**1742**	**2850**		
	Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						**7764**	**9375**	**11865**	**13082**				
	(B) Contract expired power plants													
	Sub-Total: Plants under long term maintenance				0	0	0	0	0	0				
	Gross Total				**20383**	**19892**	**8288**	**10008**	**12666**	**13965**	**1742**	**2850**		

(C) Actual data of 09.11.20 (Yesterday) Monday :

01.	Max. Demand (Generation end)	:	**10008.00**	MW, at = **19:00 hrs**
02.	Max. Demand (Sub-station end)	:	**9375.00**	MW, at = **19:00 hrs**
03.	Highest Generation (Generation end)	:	**10008.00**	MW, at = **19:00 hrs**
04.	Minimum Generation (Generation end)	:	**6447.00**	MW, at = **5:00 hrs**
05.	Day-peak Generation (Generation end)	:	**8288.00**	MW, at = **12:00 hrs**
06.	Evening-peak Generation (Generation end)	:	**10008.00**	MW, at = **19:00 hrs**
07.	Evening Peak Load-shed (Sub-station end)	:	**0.00**	MW, at = **19:00 hrs**
08.	Actual Minimum Generation up to 8:00 hrs.	:	**6551.00**	MW, at = **7:00 hrs am**
09.	Generation shortfall at evening peak due to :	:		
	a) Gas limitation	:	**1505**	MW
	d) Coal supply Limitation	:	**170**	MW
	b) Low water level in Kaptai lake	:	**67**	MW
	c) Plants under shut down/ maintenance	:	**2850**	MW
10.	Total Energy (Generation + India Import)	:	**193.45**	MKWh
	By Gas = 119.714 MKWH			36.233 MKWh
	By Coal = 15.190 MKWH		By Hydro =	3.844 MKWh
	By Solar= 0.476 MKWH			
11.	Total Gas Supplied	:	**1035.56**	MMCFD

12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :

Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
Dhaka	**3600**	**3600**	**0**	Mymensingh	**671**	**671**	**0**
Chattogram	**1101**	**1101**	**0**	Sylhet	**368**	**368**	**0**
Khulna	**1066**	**1066**	**0**	Barishal	**257**	**257**	**0**
Rajshahi	**876**	**876**	**0**	Rangpur	**552**	**552**	**0**
Cumilla	**884**	**884**	**0**				
				Total	**9375**	**9375**	**0**

13. Fuel cost : (a) Gas = **148551298** Taka (c) Coal = **70463896** Taka
(b) Oil = **260501178** Taka Total = **479516371** Taka

14. Maximum Temperature in Dhaka was : **32.5° C**

15. Export through East-West interconnections :

At evening peak-hour	:	**210**	MW, at	**19:00 hrs**
Maximum	:	**57**	MW, at	**8:00 hrs**
Energy	:	**0**	MKWh	

(D) Forecast of 10.11.20 (Today) Tuesday :

01.	Maximum Demand	:	**10400**	MW	(Generation end)
02.	Maximum Generation	:	**13965**	MW	(Generation end)
03.	Maximum Shortage	:	**-3565**	MW	(Generation end)
04.	Maximum Load-shed	:	**0**	**MW**	At evening peak (Sub-station end)
05.	Total Generation	:	**201.03**	**MKWh**	
06.	Probable Max. Temperature in Dhaka :		**31.1° C**		

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Faozul Islam Shaker)
Deputy Secretary, Generation