

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month December, 2020				Day : Saturday				Date : 12.12.20				
Probable Maximum Demand :		8500 MW		Probable Maximum Generation :				13643 MW				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 99.41 ft				Today = 99.35 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.12.20 (Yesterday)		12.12.20 (Today)		Rule Curve = 105.10 ft		Status of Machines under shut-down/ Maintenance	
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	99	99	100	100	71	180	Gas Shortage
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			STG Commissioning
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	115	115	115	115	75		Gas Shortage
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	6	6	7	7	102		Gas Shortage
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	306	317	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	380	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	368	388	50	412			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	7	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	25	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	12	100	100			
19	Gagnagarj 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	0	100	100			
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	19	19			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	38	53	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	22	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	17	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	64	150	150			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	17	53	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	195	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	62	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	50	100			
33	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	60	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	162			
<b>Dhaka Zone Total</b>				<b>6281</b>	<b>6057</b>	<b>1849</b>	<b>2318</b>	<b>3416</b>	<b>4156</b>	<b>966</b>	<b>715</b>	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	49	47	47	181		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Sikr)	HFO (IPP)	6x18.415	105	105	0	0	100	100			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	235	203	215	225			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	143	160	300	300			
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
50	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	85	85			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	39	10	10			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	3	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0			
<b>Chattogram Zone Total</b>				<b>2326</b>	<b>2266</b>	<b>566</b>	<b>807</b>	<b>1443</b>	<b>1428</b>	<b>511</b>	<b>180</b>	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	100	135	135	35		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	70	100	129	129			
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	70	100	134	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	26	20	20			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	0	0	0	180		221	Under maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	255	0	0	0		360	Under maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	56	10	10			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	26	26	187		Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	6	7	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	120	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	16	20	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.02	200	200	0	0	0	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	9	113	113			
**	Impoort (Tijpara)	India		160	160	68	88	139	148			
<b>Cumilla Zone Total</b>				<b>3040</b>	<b>2980</b>	<b>664</b>	<b>750</b>	<b>1216</b>	<b>1665</b>	<b>222</b>	<b>941</b>	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	88	129	150	150	73		Gas Shortage
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	72	95	95			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	115	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	16	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	1	0	1.6	0			
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0			
	Tangal 22 MW PP(Pali Power Gen	HFO (SIPP)				0	0	0	0			
<b>Mymensing Zone Total&lt;/</b>												

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.12.20 (Yesterday)		12.12.20 (Today)		11.12.20 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30						
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	0	0	0	0						
87	Fenchugonj 51 MW PP (Barakattuli)	Gas (RPP)	19x2.90	51	51	53	53	51	51						
88	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3-5x2.0	44	44	46	50	44	44						
89	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	140	163	163						
90	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	5	11	11	11						
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	20	36	36						
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	151	84	152	152	246		Gas Shortage			
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	79	86	86						
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	120	150	150						
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20						
96	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0						
98	Shahjahanulla 25 MW PP	Gas (GIPP, REB)	3x9.34	25	25	16	16	19	19						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	315	341						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	344	397	400	400						
	Bibiyana South 400 MW	Gas (PDB)				0	0	0	0						
	<b>Sylhet Zone Total</b>			<b>2033</b>	<b>1988</b>	<b>1309</b>	<b>1308</b>	<b>1477</b>	<b>1503</b>	<b>246</b>	<b>0</b>				
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16						
102	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	270	205	250	250						
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25						
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	65	65						
105	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220						
106	Khulna 115 PP MW (KPLC-2)	HFO (QRPP)	7x17	115	115	0	0	115	115						
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100						
108	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	90	105	105						
110	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100						
**	Bheramara (HVDC)	India		1000	1000	305	632	462	702						
	<b>Khulna Zone Total</b>			<b>2288</b>	<b>2284</b>	<b>592</b>	<b>927</b>	<b>1162</b>	<b>1738</b>	<b>0</b>	<b>0</b>				
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110						
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	26	27	27						
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.			
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	74	95	95						
115	Payra 1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	430	490	600	660						
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0						
	United Payra Power Ltd.	HFO (IPP)				0	0	0	0						
	<b>Barishal Zone Total</b>			<b>1054</b>	<b>1054</b>	<b>451</b>	<b>606</b>	<b>832</b>	<b>892</b>	<b>0</b>	<b>194</b>				
116	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50						
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200						
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40						
120	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	34	34						
121	Chapanawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	34	70	100	100						
122	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50						
123	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50						
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	33						
125	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
126	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	0	0	0	0		220	Under maint.			
127	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	140	148	225	225						
128	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	359	332	400	400						
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22						
130	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3-5x2.0	20	10	0	0	0	0						
131	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	8	11	11	11						
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52						
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113						
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	111	113	113						
	<b>Rajshahi Zone Total</b>			<b>2193</b>	<b>2183</b>	<b>563</b>	<b>729</b>	<b>1370</b>	<b>1493</b>	<b>381</b>	<b>220</b>				
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	74	75	75						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
136	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.			
137	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
138	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	113	113						
139	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
140	Majpara Tatalia 8 MW Solar PP (Sympe P)	Solar (IPP)	1 x 8	8	8	2	0	8	0						
	<b>Rangpur Zone Total</b>			<b>685</b>	<b>605</b>	<b>78</b>	<b>74</b>	<b>196</b>	<b>189</b>	<b>85</b>	<b>274</b>				
	<b>Sub-total: Plants in operation</b>			<b>20595</b>	<b>20104</b>	<b>6316.0</b>	<b>7871</b>	<b>11744</b>	<b>13643</b>	<b>2484</b>	<b>2524</b>				
	Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss														
	(B) Contract expired power plants														
	Sub-Total: Plants under long term maintenance														
	<b>Gross Total</b>														
				<b>20595</b>	<b>20104</b>	<b>6316</b>	<b>7871</b>	<b>11744</b>	<b>13643</b>	<b>2484</b>	<b>2524</b>				
	<b>(C) Actual data of 11.12.20 (Yesterday) Friday :</b>														
01.	Max. Demand (Generation end)	:	7871.00	MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end)	:	7514.00	MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	7871.00	MW, at = 19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW			
04.	Minimum Generation (Generation end)	:	5487.00	MW, at = 4:00 hrs	Dhaka	2498	2498	0	Mymensingh	631	631	0			
05.	Day-peak Generation (Generation end)	:	6316.00	MW, at = 12:00 hrs	Chattogram	908	908	0	Sylhet	295	295	0			
06.	Evening-peak Generation (Generation end)	:	7871.00	MW, at = 19:00 hrs	Khulna	950	950	0	Barishal	223	223	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:00 hrs	Rajshahi	774	774	0	Rangpur	533	533	0			
08.	Actual Minimum Generation up to 8:00 hrs.	:	5083.00	MW, at = 7:00 hrs	Cumilla	702	702	0							
09.	Generation shortfall at evening peak due to :														
	a) Gas limitation	:	2218	MW	13.	Fuel cost :									
	d) Coal supply Limitation	:	85	MW		(a) Gas =	126843261	Taka	(c) Coal =	62922998	Taka				
	b) Low water level in Kaptai lake	:	181	MW		(b) Oil =	156767778	Taka	Total =	346534037	Taka				
	c) Plants under shut down/ maintenance	:	2524	MW	14.	Maximum Temperature in Dhaka was : 20.7° C									
10.	Total Energy (Generation + India Import)	:	155.29	MKWh	15.	Export through East-West interconnections :									
	By Gas =	110.232	MKWh	18.498	MKWh	At evening peak-hour : -281 MW, at 19:00 hrs									
	By Coal =	13.666	MKWh	1.133	MKWh	Maximum : -292 MW, at 18:00 hrs									
	By Solar =	0.227	MKWh			Energy : 1.9275 MKWh									
11.	Total Gas Supplied	:	889.84	MMCFD											
	<b>(D) Forecast of 12.12.20 (Today) Saturday :</b>														
01.	Maximum Demand	:	8500	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	:	13643	MW (Generation end)	05.	Total Generation : 167.70 MKWh									
03.	Maximum Shortage	:	-5143	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 26.9° C									

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazool Islam Shaker)  
Deputy Secretary, Generation