

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour		Energy Generated	Remarks
					Generation	Hour		
Unit No. X Capacity				MW	MW	MW		
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	170	3843000		Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	220	6477382		Machine problem
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0		Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	25	1608954		Low demand
5	Hanpur GTPP	SBU, PDB	2*32	20	0	0		Under maint.
6	Hanpur 412 MW CCPP	EGCB	1*273+1*139	412	299	7620610		Gas shortage
7	Hanpur 360MW CCPP(HPL)	IPP	1*235+1*125	360	165	4334000		Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	320	6845250		Gas shortage
9	Meghnaghat 100 MW (IEL)	QRPP	12*8.9	100	0	783360		Reserve.
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	235	5075724		fraco
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	0	0		Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	860321		
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	10	238907		Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	295308		bad weather.
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0		Under maint.
16	Siddhirgonj 2120 MW GTPP	EGCB	2*105	210	32	1665000		Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	50	984960		Low demand
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	166	4178933		ST Under maint.
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	32	720576		Low demand
20	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0		Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	701640		Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	32	1411680		Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	721802		
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	700341		Engine problem
25	Bosha 108MW PP(OLC)	IPP	12*9.75+1*3.5	108	0	0		Machine problem
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	39	994660		Engine problem
27	Maana 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	592300		
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	486100		Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	24	191040		Low demand
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0		Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	120	2157817		Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0		Reserve.
33	Bramhanganj 100 MW PP (Aggreko)	IPP	1*100	100	0	0		Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0		Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	115	2232432		Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	50	862800		Low demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	53	1224960		Low demand
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	108	1169280		Engine problem
	Spectra Solar Plant Ltd.	IPP	35	0	0	177803		
Dhaka area Total				5972	2523	59176900		
39	Chattogram TPP-1	PDB	1*210	180	0	0		Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0		Gas shortage
40	Rasaz 25 MW PP	IPP	3*8.9	25	25	401421		
41	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	96885		
42	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	0	210240		Reserve.
43	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	60	1406924		Unit-2 under maint
44	Sikalbaha 225MW	PDB	1*150+1*175	225	204	4742747		
45	Sikalbaha Peaking GT	PDB	1*150	150	80	2954689		Gas shortage
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0		Transformer O/L
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0		
48	Dhazari-Kalash 100 MW Peaking	PDB	6*17	100	68	1394242		Engine problem
49	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	10	583680		Engine problem
50	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	50	1976640		Low demand
51	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	439152		
	* Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	2	414240		
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	15	224640		Engine problem
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	31318		
54	Anwara 300 MW PP (United)	IPP	300 MW	300	16	200727		Transformer O/L
55	Jodiac Power	IPP	3*18.35+1*3.6	54	54	1195467		
56	Kamaphuli Power Ltd.	IPP	1*10	10	0	0		Reserve.
57	Juldah unit-2 (Acorn)	IPP	8*13.6	100	100	2123620		
	Anlima Energy Ltd.	IPP	6*21.2	116	100	1411364		
Chattogram area Total				2382	804	19809696		
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	80	2224350		Gas shortage
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0		Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0		Gas shortage
59	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	151	4187000		
60	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	240	6861300		FGMO
61	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	240	6511000		FGMO
62	Ashuganj 50 MW CCPP	APSCL	14*3.66	5	5	478800		Gas shortage
63	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	421920		Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	217454		Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0		Line fault
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0		Line fault
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	179866		Reserve.
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	84	2739540		Low demand
69	Chandpur 200MW (Desth energy)	IPP	0	200	120	2569920		Low demand
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	413920		Engine problem
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	155160		
**	Impport (Tripura)	Imported power	0	160	138	2706240		
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	713200		
73	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	24	235747		Low demand
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	377500		Engine problem
75	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0		Reserve.
76	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	197220		Low demand
77	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	17	1209600		Low demand
	Bhairab 54.5 MW	IPP	3*18.2	0	30	519840		Engine problem
Cumilla Area Total				2980	1241	32925155		
78	RPCL 210MW CCPP	IPP	4*35+1*70	202	104	2720880		Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	235044		Bad weather.
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	385920		Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13050		
82	Mymensingh 200 MW PP (United)	IPP	200	200	8	3189600		Low demand
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	8	1618800		#REF!
84	Sutakhal 50 MW Solar PP	IPP	50	50	0	327580		
85	Tangail Pali Power Gen 22 MW	IPP	4*7.8	0	22	0		Bad weather.
Mymensingh Area Total				709	128	8693194		
86	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	984000		Machine problem
87	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	41	991200		Machine problem
88	Kushlari 163 MW CCPP (KP)	IPP	1*109+1*54	163	110	2913054		Machine problem
89	Shajibazar 330 MW CCPP	PDB	3*110	330	164	3746000		Machine problem
90	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	14	770400		
91	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	0	0		Contract Expired
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	186500		
93	Shajibazar GTPP Unit- 8 & 9	PDB	2*35	66	34	739392		GT-9 Under maint.
94	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	20	1295040		Bad weather
	Shajibazar 100 MW GTPP	PDB	1*100	0	0	0		Under Shut down
95	Syhet 225 MW CCPP	PDB	1*142+1*89	231	150	4185610		Bad weather.
96	Syhet 20 MW GTPP	PDB	1*20	20	18	323000		
97	Syhet 50MW PP (EPL)	RPP	27*2	50	0	0		Contract Expired
98	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	296832		Engine problem
99	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	190	6714500		FGMO
100	Bibiana-III 400 MW CCPP	IPP	400 MW	400	292	8416000		FGMO
101	Syhet 10MW PP (Desth)	RPP	6*1.95	9	9	139140		
	Bibiana South 400 MW	PDB	400 MW	383	335	8366900		
Syhet Area Total				2371	1447	40067568		
102	Bheramara GTPP Unit-3	PDB	1*20	16	0	0		Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	836	16819636		
103	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	49	1599040		Engine problem
104	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	3	68160		Machine problem
105	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0		Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0		Reserve.
107	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	240	7881408		FGMO
108	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	40	8	292500		Low demand
109	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	240000		Reserve.
110	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	35	1679040		Engine problem
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0		Reserve.
Khulna Area Total				2284	1171	28539784		
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	220992		Low demand
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	28	448700		
114	Bhola 225 MW CCPP	PDB	2*63+1*68	194	65	1241000		Machine problem
115	Bhola 85 MW PP (Aggreko							