POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-0 Page -1 Reporting Date : 24-May-21 Fill now the maximum generation is : • 13792.0 Hrs Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 8:00 1 Generation & Demand 12021.0 MW 12:00 10785 MW Hour Day Peak Generation Evening Peak Generation 13357.0 MW Hour 21:00 Available Max Generation 15881 MW E.P. Demand (at gen end) Maximum Generation 13357.0 MW 13357.0 MW Hour Hour 21:00 21:00 Max Demand (Evening) : Reserve(Generation end) 14500 MW 1381 MW Total Gen. (MKWH) 292.5 System Load Factor : 91.25% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Load Shed Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on -200 MW MKWHR. 4:00 Energy MW MKWHR 24-May-21 Actual 73.99 Ft.(MSL) Rule curve 77.60 Ft.(MSL) 1271.34 MMCFD. Oil Consumed (PDB): Gas Consumed Total = HSD Liter Cost of the Consumed Fuel (PDB+Pvt) Tk167,641,644 Gas : Coal : Oil : Tk703,860,798 Total: Tk954,189,962 Load Shedding & Other Information Area Yesterda Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) 5110 1746 1566 Dhaka 0:00 0% 0% 0% 0% Chittagong Area Khulna Area 0:00 0:00 Rajshahi Area 0:00 1415 0% 0% 0% 0% Cumilla Area 0:00 1279 1032 566 lymensingh Area Sylhet Area 0:00 . Barisal Area 0:00 265 Rangpur Area Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1,2 2) Ghorasal-3.4.7 3) Ashuganj-3,4 4) Kaptai-2 5) Raozan #1.2 6) Sylhet-225 MW ST Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Bogura 132/33 kV T-4 transformer was under shut down from 08:09 to 10:57 due to R/H maintenance at 33 kV B-phase CT connection. at 35 x 0 B-priase of 1 confection. b) Dohazari-Cox's Bazar 132 kV Ckt was under shut down from 08:34 to 10:13 for D/W. c) Mymensingh 132/33 kV T-3 transformer was under shut down from 09:17 to 12:38 due to R/H maintenance. d) Savar 132/33 kV T-3 transformer was under shut down from 08:32 to 17:07 for C/M. b) Hallshahar-Khulshi 132 kV Ckt-3 is under shut down since 10:35 for D/W. f) Kodda 132/33 kV T-4 transformer was switched on at 11:58. g) Jamalpur-Mymensigh 132 kV Ckt-1 was under shut down from 07:37 to 19:04 for C/M. h) Sikalbaha-Anwara united 300 MW P/P 230 kV Ckt-2 was under shut down from 06:21 to 17:46 for D/W. i) Dohazari-Cox's Bazar 132 kV Ckt-2 tripped at 18:06 from Dohazari end showing dist. Z2 and was switched j) Dohazari-Co on at 18:25. k) Hathazari-Baroirhat 132 kV Ckt-2 tripped at 17:28 from Hathazari end showing dist. C-phase, O/C and was switched on at 17:44. I) Natore 132/33 kV T-4 transformation)) Natore 132/33 kV T-4 transformer was under shut down from 14:50 to 16:02 for D/W. m) Ishwardi-Bheramara 132 kV Ckt-1 tripped at 21:10 from Ishwardi end showing dist. C-phase, O/C and was switched on at 21:37. n) Ishwardi 132/33 kV T-1 transformer tripped at 21:10 due to 33 kV BPS feeder fault showing self protection, REF and was switched on at 22:11. o) Ghorashal-Ishwardi 230 kV Ckt-2 was under shut down from 14:46 to 17:18 due to fire at Tongi area o) Ghoráshari-Binward 230 kV Ckr. was under shut down from 14-4b to 17:18 due to fire at longi area. p) Ashuganj U-5 auxiliary transformer OAT-3 R-phase CT burst at 17:54. At the same time Ashuganj OAT-12, Ashuganj-Ghorashal 132 kV both Ckts, Ashuganj-Ghorashal 132 kV both Ckts, Ashuganj 25 MW, Ashuganj Pischison 55 MW, Ashuganj Techsung 125 MW, Ashuganj Encision 55 MW, Ashuganj Inti-5 & Mymensingh RPCL ST got tripped. q) All 132 kV Ckts including OAT-12 were normalized at 18:40. r) All power plant and Ckts connected to APSCL 230 kV Bus were tripped at 19:07 due to B-phase CT burst. At the same time Ashuganj North P.P. & Ashuganj (S)-Ghorashal got tripped. 3) Ashuganj Sirajang 130 kV Ckt.1.8 Ckt.2 vives switched no at 19:50 8 20 VM respectively. s) Ashuganj-Sirajganj 230 KV Ckt-1 & Ckt-2 were switched on at 19:52 & 20:04 respectively. t) Ashuganj-Cumilla(N) 230 kV Ckt-2 was switched on at 20:01. u) Ashuganj OAT-12 Transformer was switched on at 20:30. About 250 MW power interruption was imposed to control line load v) Ashuganj(N) GT was synchronized at 21:25. and voltage at Mymensingh & Ghorashal area. w) Mymensingh RPCL ST was synchronized at 21:57. x) Ashuganj-Ghorashal 230 kV Ckt.2 was switched on at 07:08(24/05/2021). y) Dhamral 132/33 kV T-1 transformer was under shut down from 06:05(24/05/2021) to 07:11(24/05/2021) for C/M. z) Halishahar-Julda 132 kV Ckt is under shut down since 06:45(24/05/2021) for D/W. 2) Frainstrate-Judie 22 kV Ckt is United stitut down since 00-49(24/0522/1) to LVW. aaa) Kishoreganj 132/33 kV T-1 & T-2 transformers tripped at 00-30(24-05-2021) showing O/C, A,B-phases relays due to 33 kV feeder fault and was switched on at 00-42(24-05-2021). ab) Munshiganj 132/33 kV T-1 & 33 kV Bus-1 transformer was under shut down from 06:40(24/05/2021) to

69:25(24/05/2021) for C/M.

ac) Sikalbaha-Anwara united 300 MW P/P 230 kV Ckt-1 is under shut down since 07:12(24/05/2021) for D/W.

ad) Purbasadipur-Thakurgaon 132 kV Ckt-1 is under shut down since 05:56(24/05/2021) for C/M. ae) Chandraghona 132/33 kV T-2 transformer was under shut down from 07:26(24/05/2021) to

07:36(24/05/2021) for BPDB work.
af) Dhamrai 132/33 kV T-2 transformer was under shut down from 07:14(24/05/2021) to 09:23(24/05/2021) for C/M.
ag) Jamalpur-Mymensing 132 kV Ckt-1 is under shut down since 07:40(24/05/2021) for D/W.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division About 90 MW power interruption occurred under Kishoreganj S/S area from 00:30(24-05-2021) to 00:42(24-05-2021). About 15 MW power interruption occurred under Munshigani S/S area from 06:40(24-05-2021) to 09:25(24-05-2021).

> Superintendent Engineer Load Despatch Circle