

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021		Day : Thursday		Date : 10.06.21							
Probable Maximum Demand : 13500 MW		Probable Maximum Generation : 15487 MW		Rule Curve = 78.34 ft.							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 73.42 ft.		Today = 73.73 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	09.06.21 (Yesterday)		10.06.21 (Today)		Gen. shortfall for : Gas/water/Coal limitation (MW)	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	98	104	104		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x225+1x125	360	360	176	181	260	260	179	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	105	175	150	200	35	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	327	335	335	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	7	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	235	280	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	64	87	87		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	93	102	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	21	20	21		
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, PDB)	6x3.67+7x3.73	80	80	54	53	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	6x8.73	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, PDB)	6x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	42	42	42		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	70	85	85		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	115	150	150	150		
25	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banoo Energy)	HFO (IPP)	3x18.69	54	54	53	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	145	228	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	133	133	133		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	103	100	300		
30	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x 9.69	100	100	0	0	100	100		
31	Aurabai 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x 9.69	100	100	0	101	50	100		
32	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	104	104		
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	126	162	162		
37	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	2	0	30	0		
Dhaka Zone Total				5976	5819	2455	3182	3469	3760	364	1457
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	20	25	25	25	205	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	95	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	9	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalab)	HFO (IPP)	6x18.415	105	105	68	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	100	120	120		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	210	203	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300		
48	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
49	Judah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	10	50	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	85	85	85	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22	22		
53	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			4	25	10	25		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	6	6		
55	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	108	110	110		
57	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	20	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	0	116	116		
Chattogram Zone Total				2442	2382	805	1042	1665	1655	205	180
59	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
60	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	100	135	100	135		
61	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
62	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	26	26	26		
63	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	212	218	220	220		
64	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	275	320	350		
65	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	300	320	340		
66	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	40	40	55	55		
67	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	26	26	26	169	Gas shortage
68	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
69	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	138	143	143		
70	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
71	Chandour 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	133	129	135	140		
72	Chandour 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	161	180	185	185		
73	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	0	22	22		
74	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	8	11	11		
75	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	28	33	33		
76	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	34	43	43		
77	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	12	9	20	21		
78	Daukidandi 200 MW PP (B. Trac)	HSD (IPP)	9x14+8x3.195+1x10.99	200	200	0	100	100	200		
79	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	100	100	100		
80	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	117	114	113	113		
81	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35		
82	** Impopt (Tripara)	India		160	160	128	156	152	180		
Cumilla Zone Total				3094	3034	1922	2134	2210	2479	438	0
83	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	147	148	154	154	54	Gas Shortage
84	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
85	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8	8		
86	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	115	115	115		
87	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	45	145	200	200		
88	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
89	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	7	0	50	0		
90	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	18	24	22	22		
Mymensingh Zone Total				717	709	343	460	571	519	54	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.06.21 (Yesterday)		10.06.21 (Today)		09.06.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening					
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	42	42	42			28	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			48	Under maint.	
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	50	47	51	51					
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	140	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	61	61					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	161	161	162					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	83	80	83					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	224	115	225	226					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	0	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	8	8					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	15					
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	275	341	341					
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	391	389	400	400					
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	383	400	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total				2422	2377	1917	1791	2019	2023	0	76			
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	275	300	390	400	110			Gas Shortage	
105	Farpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	7	20	20	20					
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 159+1x75	230	230	0	160	0	220					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105					
110	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	100	100					
Khulna Zone Total				2133	2129	1209	1596	1648	1928	110	0			
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	33	33	33					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	62	65	65			132	GT-2 & STG Under	
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1.1x96	95	95	31	12	12	12					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	550	622	622					
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110					
Bhola Nutan Biddut BD LTD						175	220	228	233					
Barishal Zone Total				1826	1826	631	893	1070	1185	0	132			
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	71				Gas Shortage	
117	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	100				Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	43	43	50	50					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	51	51	51					
121	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35					
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	50	90					
123	Katakhalii 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	40	40					
124	Katakhalii 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35					
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	94	0	0	150				Gas Shortage, STG S/D	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	138	173	200	200					
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	190	205	200	200					
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	387	418	400	400					
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
131	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	11	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	34	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total				2179	2179	1151	1429	1568	1655	321	0			
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	151	150	150	123			Coal Shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	12	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113					
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Maipara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total				685	605	156	276	271	283	293	0			
Sub-total: Plants in operation				21474	21060	10589.0	12803	14491	15487	1785	1845			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10120	12236	13849	14801				
(B) Plants under long term maintenance/ contract expired														
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020	
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021	
148	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0					
Gross Total				22023	21060	10589	12803	14491	15487	1785	1845			
(C) Actual data of 09.06.21 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	12803.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12236.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12803.00	MW,	at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	9143.00	MW,	at =	8:00 hrs	Dhaka	4226	4226	0	Mymensingh	971	971	0
05.	Day-peak Generation (Generation end)	:	10589.00	MW,	at =	12:00 hrs	Chattogram	1300	1300	0	Sylhet	532	532	0
06.	Evening-peak Generation (Generation end)	:	12803.00	MW,	at =	21:00 hrs	Khulna	1560	1560	0	Barishal	374	374	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1251	1251	0	Rangpur	815	815	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9754.00	MW,	at =	5:00 hrs	Cumilla	1207	1207	0				
09.	Generation shortfall at evening peak due to :	:									Total	12236	12236	0
a)	Gas limitation	:	1287	MW			13.	Fuel cost :	a) Gas =	168507468	Taka	c) Coal =	69279190	Taka
b)	Coal supply Limitation	:	293	MW			b) Oil =	502309550	Taka			Total =	740096207	Taka
c)	Low water level in Kaptai lake	:	205	MW										
d)	Plants under shut-down/ maintenance	:	1845	MW			14.	Maximum Temperature in Dhaka was :						
10.	Total Energy (Generation + India Import)	:	262.38	MKWh			15.	Export through East-West interconnections :						
	By Gas =	158.456	MKWh	By Oil =	63.273	MKWh	At evening peak-hour	:	-54	MW,	at	21:00 hrs		
	By Coal =	14.923	MKWh	By Hydro =	0.540	MKWh	Maximum	:	-92	MW,	at	19:30 hrs		
	By Solar =	0.470	MKWh				Energy	:	0.214	MKWh				
11.	Total Gas Supplied	:	1229.28	MMCFD										
(D) Forecast of 10.06.21 (Today) Thursday														