

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021		Day : Sunday				Date : 20.06.21					
Probable Maximum Demand :		11800 MW		Probable Maximum Generation : 15190 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 74.63 ft.		Today = 74.74 ft.		Rule Curve = 81.03 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	19.06.21 (Yesterday)		20.06.21 (Today)		Gen. shortfall for : Gas/water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	41	98	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x225+1x125	360	360	251	257	300	300	103	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	333	305	330	330	107	Under maint.
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	226	221	220	220		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	2	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	240	280	285	285		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	74	75		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	16	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	16	16		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	55	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	17	25	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	76	90	88	90		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	16	98	133	133		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	148	250	250		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	16	132	132		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x6.1.4	300	300	0	0	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x.969	100	100	0	0	100	100		
31	Aurabai 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x.969	100	100	0	0	100	100		
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	5	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	22	90	90		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	7	17	126	129		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	3	0	30	0		
Dhaka Zone Total				5976	5819	1825	2457	3551	3729	463	1152
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0		
41	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	26	46	46		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	17	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	203	204	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	300	300		
48	Judhad 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	50	100	100	100		
49	Judhad 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	10	20	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	100	100		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
*	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			2	28	10	25		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	24	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	108	110	110		
56	Judhad unit-2 (Acorn)	HFO (IPP)	8x13.5	100	100	0	10	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	17	116	116		
Chattogram Zone Total				2442	2382	568	1004	1650	1640	205	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	178	217	220	220		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	265	260	300	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	275	265	310	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	200	130	8	8	65	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	30	5	30		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	50	120	130		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	91	90	90		
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	59	100	180	180		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	21	17	17		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+8x1.95+1x1.99	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	100	17	80		
77	Chowmahani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	113	118	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	35	36		
**	Impopt (Tijura)	Inda		160	160	96	106	151	180		
Cumilla Zone Total				3094	3034	1544	1740	1936	2264	383	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	154	155	190	190	47	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	21	21	21		
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	100	175	175		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	12	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	1	24	22	22		
Mymensingh Zone Total				717	709	223	423	583	531	47	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.06.21 (Yesterday)		20.06.21 (Today)		19.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	53	51	51					
90	Kushiana 163 MW CCPP (KPP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	62	62					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	162	162	162					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	81	83					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	225	218	192	225					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	15	16					
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	295	341	341					
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	365	400	400					
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total				2422	2377	1820	1901	1948	1984	0	118			
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	320	300	380	400	110		Gas Shortage		
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	21					
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	91	90	90					
110	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
** Bheramara (HVDC) India				1000	1000	893	893	895	895					
Khulna Zone Total				2133	2129	1213	1284	1595	1886	110	0			
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	28	33	33					
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86		108	GT-2 & STG Under		
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1x196	95	95	12	12	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	260	350	622	622					
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110					
Bhola Nutan Biddut BD LTD						100	153	220	220					
Barishal Zone Total				1826	1826	475	629	1081	1192	0	108			
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	65	55	50	50		16	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	40					
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35					
122	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	89	90	100					
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40					
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35					
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D		
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	175	200	200					
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	165	165	200	200					
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	303	364	400	400					
130	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
131	Lullipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6*18.55	113	113	0	70	90	90					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0					
Rajshahi Zone Total				2179	2179	707	1120	1632	1681	266	0			
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Maipara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
Rangpur Zone Total				685	605	155	263	271	283	294	0			
Sub-total: Plants in operation				21474	21060	8530.0	10821	14247	15190	1768	1558			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8066	10232	13471	14363					
(B) Plants under long term maintenance/ contract expired														
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020	
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0					
Gross Total				22023	21060	8530	10821	14247	15190	1768	1558			
(C) Actual data of 19.06.21 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	10821.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10232.00	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10821.00	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	7676.00	MW, at =	8:00 hrs	Dhaka	3723	3723	0	Mymensingh	857	857	0	
05.	Day-peak Generation (Generation end)	:	8530.00	MW, at =	12:00 hrs	Chattogram	1003	1003	0	Sylhet	433	433	0	
06.	Evening-peak Generation (Generation end)	:	10821.00	MW, at =	21:00 hrs	Khulna	1175	1175	0	Barishal	295	295	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Rajshahi	1064	1064	0	Rangpur	725	725	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7929.00	MW, at =	5:00 hrs	Cumilla	957	957	0					
09.	Generation shortfall at evening peak due to :	:								Total	10232	10232	0	
a)	Gas limitation	:	1269	MW		13.	Fuel cost :		a) Gas = 159369040	Taka	c) Coal = 51378757	Taka		
b)	Coal supply Limitation	:	294	MW					b) Oil = 218665583	Taka	Total = 429413380	Taka		
c)	Low water level in Kaptai lake	:	205	MW										
d)	Plants under shut down/ maintenance	:	1558	MW		14.	Maximum Temperature in Dhaka was :						27.0° C	
10.	Total Energy (Generation + India Import)	:	217.97	MKWh		15.	Export through East-West interconnections :							
	By Gas = 150.655	MKWh		By Oil = 31.705	MKWh		At evening peak-hour						-132	MW, at 21:00 hrs
	By Coal = 10.837	MKWh		By Hydro = 0.604	MKWh		Maximum						-170	MW, at 20:00 hrs
	By Solar = 0.298	MKWh					Energy						0.441	MKWh
11.	Total Gas Supplied	:	1197.12	MMCFD										
(D) Forecast of 20.06.21 (Today) Sunday :														
01.	Maximum Demand	:	11800	MW	(Generation end)	04.	Maximum Load-shed						0	