

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month August, 2021		Day : Thursday				Date : 12.08.21					
Probable Maximum Demand :		13000 MW		Probable Maximum Generation :		14845 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 89.17 ft.		Today = 89.75 ft.		Rule Curve = 92.52 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	11.08.21 (Yesterday)		12.08.21 (Today)		11.08.21 (Yesterday)	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	166	162	260	260		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	240	240	240	210	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	210	210	280	280		
11	Siddhirgonj 210 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	318	337	335	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	275	265	300	300		
15	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	50	55	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	12	85	85		
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	94	102	102	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	21	20	20		
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	52	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	52	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	100		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	130	150	133	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	262	280	285	285		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.1.4	300	300	25	206	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x.969	100	100	25	50	100	100		
31	Aurshah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9+1x.969	100	100	50	102	50	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	95	94	94		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0		
<b>Dhaka Zone Total</b>				<b>5976</b>	<b>5819</b>	<b>3134</b>	<b>3457</b>	<b>3637</b>	<b>3874</b>	<b>548</b>	<b>660</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	123	121	120	120	109	Low Water Level
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Racozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	5	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	30	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	71	69	200	300		
48	Judah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
49	Judah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
*	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			2	20	5	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	87	96	97	97		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	97	94	110	110		
56	Judah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	97	116	116	116		
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>1126</b>	<b>1319</b>	<b>1550</b>	<b>1640</b>	<b>109</b>	<b>375</b>
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	13	23	23	23		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	160	207	215	215		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	290	270	330	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	270	330	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	30	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	142	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	50	50	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	85	90	90		
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	160	200	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+8x1.95+1x1.95	200	200	0	100	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	114	114	113	113		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	99	107	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impopt (Tirpura)	India		160	160	100	150	138	164		
<b>Cumilla Zone Total</b>				<b>3094</b>	<b>3034</b>	<b>1690</b>	<b>2034</b>	<b>2194</b>	<b>2320</b>	<b>505</b>	<b>0</b>
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	110	133	120	120		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	102	111	112	112		
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	134	181	175	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	9	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
<b>Myensingh Zone Total</b>				<b>717</b>	<b>709</b>	<b>408</b>	<b>478</b>	<b>510</b>	<b>483</b>	<b>0</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.08.21 (Yesterday)		12.08.21 (Today)		11.08.21 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugoni CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43			27	Under maint.
88	Fenchugoni CAPP Phase-2	Gas (PDB)	2x25+1x35	104	90	42	42	42	42			48	Under maint.
89	Fenchugoni 51 MW PP (Barakutallah)	Gas (RPP)	19x2.90	51	51	52	53	51	51				
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	175	237	260	260				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	83	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	145	105	200	200				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	280	341	341				
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	365	400	400				
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	15	70	250	250				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1528</b>	<b>1557</b>	<b>1959</b>	<b>1959</b>	<b>0</b>	<b>75</b>		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	15	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	295	290	320	320	120			Gas Shortage
105	Fatidpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	0	20				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	70	225	225				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
** Bheramara (HVDC) India				1000	1000	699	692	707	707				
<b>Khulna Zone Total</b>				<b>2133</b>	<b>2129</b>	<b>1099</b>	<b>1280</b>	<b>1507</b>	<b>1637</b>	<b>120</b>	<b>0</b>		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	31	33	33				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	87	89	89	107			Under maint.
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x96	95	95	11	11	12	12				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	390	580	622	622				
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	150	150				
117	Bhola 220MW CCPP (Nutan Bidyt BL)	Gas/HSD (IPP)	2x75+1x70	220	220	217	216	220	220				
<b>Barishal Zone Total</b>				<b>2046</b>	<b>2046</b>	<b>731</b>	<b>979</b>	<b>1236</b>	<b>1236</b>	<b>0</b>	<b>107</b>		
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	71				Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	43	43				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	150	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	0	40				
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	35	35	35	35				
123	Chapanawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	95	95				
124	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	35	35				
125	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
126	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	33				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0				STG S/D
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	149	144	155	155				
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	174	172	200	200				
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	411	394	400	400				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	95	95				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	94	94				
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
<b>Rajshahi Zone Total</b>				<b>2179</b>	<b>2179</b>	<b>1035</b>	<b>1401</b>	<b>1443</b>	<b>1510</b>	<b>171</b>	<b>0</b>		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	154	150	153	153	124			Coal Shortage
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	106	113	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Majpara, Tutula 6 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 6	6	6	1	0	6	0				
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>261</b>	<b>263</b>	<b>274</b>	<b>286</b>	<b>294</b>	<b>0</b>		
<b>Sub-total: Plants in operation</b>				<b>21694</b>	<b>21280</b>	<b>11012.0</b>	<b>12768</b>	<b>14310</b>	<b>14945</b>	<b>1747</b>	<b>1217</b>		
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>10473</b>	<b>12143</b>	<b>13609</b>	<b>14213</b>				
<b>(B) Plants under long term maintenance/ contract expired</b>													
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
145	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired				337	0	0	0	0	0				
<b>Gross Total</b>				<b>22031</b>	<b>21280</b>	<b>11012</b>	<b>12768</b>	<b>14310</b>	<b>14945</b>	<b>1747</b>	<b>1217</b>		
<b>(C) Actual data of 11.08.21 (Yesterday) Wednesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	12768.00	MW, at =	21:00 hrs	<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>							
02.	Max. Demand at eve. peak (Sub-station end)	:	12143.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12768.00	MW, at =	21:00 hrs	Dhaka	4108	4108	0	Mymensingh	977	977	0
04.	Minimum Generation (Generation end)	:	9794.00	MW, at =	8:00 hrs	Chattogram	1185	1185	0	Sylhet	509	509	0
05.	Day-peak Generation (Generation end)	:	11012.00	MW, at =	12:00 hrs	Khulna	1641	1641	0	Barishal	410	410	0
06.	Evening-peak Generation (Generation end)	:	12768.00	MW, at =	21:00 hrs	Rajshahi	1313	1313	0	Rangpur	833	833	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1167	1167	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9889.00	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	1344	MW									
	b) Coal supply Limitation	:	294	MW									
	c) Low water level in Kaptai lake	:	109	MW									
	d) Plants under shut down maintenance	:	1217	MW									
10.	Total Energy (Generation + India Import)	:	274.88	MKWh									
	By Gas =	142.046	MKWh	By Oil =	93.862	MKWh							
	By Coal =	15.723	MKWh	By Hydro =	2.873	MKWh							
	By Solar =	0.379	MKWh										
11.	Total Gas Supplied	:	1147.41	MMCFD									
<b>(D) Forecast of 12.08.21 (Today) Thursday :</b>													
01.	Maximum Demand	:	13000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14945	MW	(Generation end)	05.	Total Generation	:	279.87	MKWh			
03.	Maximum Shortage	:	-1945	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	33.6° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation