

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2021			Day : Friday				Date : 10.09.21				
Probable Maximum Demand : 12500 MW			Probable Maximum Generation : 14238 MW				Rule Curve = 101.07 ft.				
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 104.90 ft.				Today = 105.14 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.09.21 (Yesterday)		10.09.21 (Today)		09.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	203	203	203	203	126	STG Under maint
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	170	167	290	300	193	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	358	332	350	390	80	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	270	300	300	300	35	Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	300	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40		
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	56	77	77	77		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102		
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	22	22		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	54	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	17	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	70	70	90		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	133	150	149	149		
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	298	300	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	138	149	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	130	300	100	300		
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	70	100	100	100		
29	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	70	98	50	100		
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	35	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	93	94	94		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	34	0	30	0		
Dhaka Zone Total				5717	5560	3215	3555	3509	3799	1006	786
35	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	162	161	158	158	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0		
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	88	88	88	88		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	107	305	300	300		
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	94	100	100		
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment Issue
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
*	Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34			4	18	5	20		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	63	0	0		
51	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	37	54	54	54		
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	106	110	110		
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
54	Chattogram 116 MW PP (Anilima Enerç)	HFO (IPP)	6x21.06	116	116	96	114	116	116		
Chattogram Zone Total				2442	2382	1132	1503	1456	1446	240	415
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	23	23		
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	213	200	210	210		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	280	300	300		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	330	300	300		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	34	38	24	24	17	Gas shortage
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	63	8	8	8	187	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	133	130	140		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	141	141	141		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	21		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	100	200	100	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	96	98	114		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	93	98	113	113		
75	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	27	17	17		
**	Impoport (Tripura)	India		160	160	118	140	138	163		
Cumilla Zone Total				3094	3034	1995	2110	1958	2160	602	0
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	105	135	120	120	67	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	19	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		Dependable cap. : 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	39	108	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	38	198	175	200		
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
82	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0		
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	20	24	22	22		
Mymensing Zone Total				717	709	275	492	514	487	67	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.09.21 (Yesterday)		10.09.21 (Today)		09.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Load gear problem		
85	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT 4 Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	25	25	25					
87	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
88	Hobiganj 11MW PP Cofidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage		
90	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	159	158	160	160	172		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	80	80	84					
92	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	220	220	225	225					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24					
96	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	300	341	341					
97	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	240	316	315	315					
98	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	390	325	325	325					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work		
Sylhet Zone Total						2422	2377	1674	1685	1758	1762	258	89	
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	195	200	230	230					
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	7	25	0	22			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	220	225	170	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	30	100	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	88	88	88	88					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	519	717	714	714					
Khulna Zone Total						2133	2129	1059	1355	1352	1519	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	27	34	33	33					
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65	129		Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	84	84	70	85					
112	Payra 1320 MW TPP	Coal (BCPL)	2x622	1244	1244	440	600	622	622	644		Line Overload		
113	Potua khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	81	150	150					
114	Bhola 220MW CCGP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	104	105	220	220					
Barishal Zone Total						2046	2046	720	969	1270	1285	0	773	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	50	182	200	200					
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	38	40	40					
119	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0					
120	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	85	85					
121	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40					
122	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50					
123	Santalar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	19	0	20					
124	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
125	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	123	120	135	140					
126	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	136	144	185	185					
127	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	383	380	400	410					
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	22	22					
129	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	8	8	8					
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2179	2179	976	1378	1448	1487	381	0	
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	154	154	155	155	120		Coal Shortage		
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15					
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113					
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Majipara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total						685	605	274	267	275	293	205	85	
Sub-total: Plants in operation						21435	21021	11320.0	13314	13540	14238	2759	2148	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10804	12707	12922	13589					
(B) Plants under long term maintenance/ contract expired														
140	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired						596	159	0	0	0	0	0	0	
Gross Total						22031	21180	11320	13314	13540	14238	2759	2148	
(C) Actual data of 09.09.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	13314.00	MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12707.00	MW, at = 20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	13314.00	MW, at = 20:00 hrs										
04.	Minimum Generation (Generation end)	:	9736.00	MW, at = 7:00 hrs	Dhaka	4429	4429	0	Mymensingh	1007	1007	0		
05.	Day-peak Generation (Generation end)	:	11320.00	MW, at = 12:00 hrs	Chattogram	1311	1311	0	Sylhet	574	574	0		
06.	Evening-peak Generation (Generation end)	:	13314.00	MW, at = 20:00 hrs	Khulna	1609	1609	0	Barishal	396	396	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 20:00 hrs	Rajshahi	1352	1352	0	Rangpur	805	805	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9309.00	MW, at = 5:00 hrs	Cumilla	1224	1224	0						
09.	Generation shortfall at evening peak due to :	:							Total	12707	12707	0		
	a) Gas limitation	:	2554	MW	13.	Fuel cost :	(a) Gas = 141080317 Taka	(c) Coal = 77859445 Taka						
	d) Coal supply Limitation	:	205	MW			(b) Oil = 853715455 Taka	Total = 1072655217 Taka						
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2148	MW	14.	Maximum Temperature in Dhaka was :	32.0° C							
10.	Total Energy (Generation + India Import)	:	281.59	MKWh	15.	Export through East-West interconnections :								
	By Gas =	137.622	MKWh	By Oil =	103.068	MKWh	At evening peak-hour	-370	MW, at	20:00	hrs			
	By Coal =	16.846	MKWh	By Hydro =	3.724	MKWh	Maximum	-486	MW, at	24:00				
	By Solar =	0.697	MKWh				Energy	3.0085	MKWh					
11.	Total Gas Supplied	:	1081.37	MMCFD										
(D) Forecast of 10.09.21 (Today) Friday :														
01.	Maximum Demand	:	12500	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14238	MW (Generation end)	05.	Total Generation	:	264.37	MKWh					
03.	Maximum Shortage	:	-1738	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	35.0° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation