

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564687, 9551095

Month September, 2021		Day : Monday				Date : 20.09.21							
Probable Maximum Demand :		13300 MW		Probable Maximum Generation :		14564 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 106.05 ft		Today = 106.36 ft		Rule Curve = 103.37 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.09.21 (Yesterday)		20.09.21 (Today)		19.09.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	19.09.21 (Today) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage		
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	310	310	310	310	126			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem		
6	Harpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Harpur 360MW CAPP(HPL)	Gas (IPP)	1x235+ 1x125	360	360	303	213	210	200	147	Gas Shortage		
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+ 1x170	450	450	280	280	280	280	170	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Harpur 412 MW CAPP	Gas (EGCB)	1x273+ 1x139	412	412	337	392	412	412	20			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+ 1x118	335	335	250	251	250	250				
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+ 1x110	305	305	285	310	305	305				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+ 1x11.3	55	55	55	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	60	60				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	64	100	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	13	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+ 1x4.73	80	80	55	54	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	51	25	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	4	105	52	100				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	149	149				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35				
25	Kodda 300 MW PP Unit-3 (Summit)	HFO (IPP)	18x17.076	300	300	278	277	300	300				
26	Kodda 149 MW PP Unit-2 (Summit)	HFO (IPP)	8x18.415+ 1x8.97	149	149	149	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	100	300				
28	Biramganj 100 MW PP (Agraka)	HSD (IPP)	23x0.85+ 91x.959	100	100	0	0	100	100				
29	Aurahat 100MW PP (Agraka)	HSD (IPP)	23x0.85+ 91x.959	100	100	0	0	50	100				
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	25	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	94	94	94				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	112	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	7	0	30	0				
Dhaka Zone Total				5717	5560	2755	3055	3481	3767	845	806		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	167	166	168	168		40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0				
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
43	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+ 1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	174	304	300	300				
45	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	20	100	100				
46	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	100	100				
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	0	85				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			Environment Issue	
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	21				
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			5	17	7	20				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	88	88	88	88				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+ 1x3.5	54	54	0	54	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+ 1x6.4	110	110	110	110	110	110				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	72	114	116	116				
Chattogram Zone Total				2442	2382	1055	1469	1488	1562	240	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23				
57	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+ 175	221	221	198	213	180	190				
58	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	295	270	310	320				
59	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	290	265	320	330				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	56	56	55	55				
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+ 1*16	195	195	36	36	36	36	159	Gas shortage		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	43	43	43				
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	144	135	145				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
65	Chandpur 150 MW CAPP	Gas (PDB)	1X106+ 1x57	163	163	140	140	140	140				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	144	200	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	29	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+ 2x6.97	25	25	17	21	21	21				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	85x 4+ 60x 15+ 15x 158	200	200	0	0	150	200				
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+ 1*9.78	114	114	52	98	114	114				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+ 2*3.1	113	113	89	97	95	96				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
**	Import (Tripura)	India		160	160	112	130	138	164				
Cumilla Zone Total				3094	3034	1687	1867	2095	2262	557	0		
76	RPCL 210MW CAPP	Gas (IPP)	4x35+ 1x70	210	202	103	147	100	100	55	Gas Shortage		
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8			Dependable cap. : 8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	115	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	200	175	200				
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
82	Sutikhalhi 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
83	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	22	22					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.09.21 (Yesterday)		20.09.21 (Today)		19.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	10	30	30	30			G11 Load gear problem	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0			Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	51	51				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	159	160	160	160	170		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	78	78				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	145	190	220				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	300	341	341				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	317	316	316	316				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100 Under project work	
Sylhet Zone Total					2422	2377	1652	1594	1684	1714	256	130	
100	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	390	405	400	400				
102	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	27			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	230	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	20	50	100				
106	Rupsha 105 MW PP (Onon rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			Line Overload	
**	Bheramara (HVDC)	India		1000	1000	716	715	729	729				
Khulna Zone Total					2133	2129	1226	1508	1609	1726	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	27	33	33				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	66	67	68	68	127		Arrival of GT2 HGPI experts delayed due to covid 19	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	23	22	22	22				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	480	622	622	764		Line Overload	
113	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
114	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	164	225	220	220				
Barishal Zone Total					2046	2046	620	821	1225	1225	0	891	
115	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.29	50	50	0	27	27	27				
120	Chapainawabganj 100 MW Peaking PF	HFO (PDB)	12x8.924	104	104	0	93	90	94				
121	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	30				
122	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	33				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	180	220	200	220	0		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	188	200	220				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	355	388	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
129	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
130	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	90	90	90	90				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
133	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total					2179	2179	970	1362	1482	1626	381	0	
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	78	77	77	7		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overheating	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.	
136	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	113	113	113				
138	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
Rangpur Zone Total					685	605	154	191	198	215	7	359	
Sub-total: Plants in operation					21435	21021	10431.0	12370	13756	14564	2341	2601	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9978	11833	13158	13932			
(B) Plants under long term maintenance/ contract expired													
140	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	159	0	0	0	0	0	0	
Gross Total					22031	21180	10431	12370	13756	14564	2341	2601	
(C) Actual data of 19.09.21 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 12370.00 MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11633.00 MW, at = 19:30 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 12370.00 MW, at = 19:30 hrs		Dhaka	4349	4349	0	Mymensingh	1014	1014	0		
04.	Minimum Generation (Generation end)	: 9076.00 MW, at = 7:00 hrs		Chattogram	1227	1227	0	Sylhet	521	521	0		
05.	Day-peak Generation (Generation end)	: 10431.00 MW, at = 12:00 hrs		Khulna	1348	1348	0	Barishal	309	309	0		
06.	Evening-peak Generation (Generation end)	: 12370.00 MW, at = 19:30 hrs		Rajshahi	1274	1274	0	Rangpur	729	729	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs		Cumilla	1062	1062	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9021.00 MW, at = 5:00 hrs						Total	11833	11833	0		
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2334 MW											
d)	Coal supply Limitation	: 7 MW											
b)	Low water level in Kaptai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2601 MW											
10.	Total Energy (Generation + India Import)	: 259.98 MKWh											
	By Gas = 146.472 MKWh	By Oil = 76.885 MKWh											
	By Coal = 12.252 MKWh	By Hydro = 3.951 MKWh											
	By Solar= 0.478 MKWh												
11.	Total Gas Supplied	: 1115.23 MIMCFD											
(D) Forecast of 20.09.21 (Today) Monday :													
01.	Maximum Demand	: 13300 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14564 MW (Generation end)	05.	Total Generation	: 279.53 MKWh								
03.	Maximum Shortage	: -1264 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	31.7° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)
Deputy Secretary, Generation