

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9544667, 9551095

Month September, 2021		Day : Tuesday		Date : 21.09.21								
Probable Maximum Demand :		13200 MW	Probable Maximum Generation :		14620 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 106.36 ft		Today = 106.59 ft								
Rule Curve =		103.60 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.09.21 (Yesterday)		21.09.21 (Today)		20.09.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310	126		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	173	193	210	220	167	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	364	363	412	412	49		
11	Siddhirgonj 2 nd 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 305 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	250	250	250			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	295	285	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	50	55	55	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	40	60	60			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	102	100	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	0	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x1.73	80	80	55	55	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	33	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	52	48	25	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	52	100			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	133	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	238	278	280	280			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	72	100	300			
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	50	100			
30	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	94	94	94			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	144	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	20	0	30	0			
Dhaka Zone Total			5717	5560	2606	3217	3461	3767	865	835		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	169	165	168	168	40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0			
38	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	24	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	39	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	93	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	302	287	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	10	100	100	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	76	90	100	100			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	0	85			
48	Haftazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	20	21			Environment issue
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			6	8	8	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	82	84	88	88			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	13	51	54	54			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	95	95	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
54	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	114	114	116	116			
Chattogram Zone Total			2442	2382	1225	1476	1489	1562	240	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	23	23			
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	184	182	180	190			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	280	310	320			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	325	280	320	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	56	56	55	55			
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20 ⁹ 73+1 ¹⁶ 16	195	195	65	8	36	36	187	Gas shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	130	135	145			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	141	140	140	140			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	108	190	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	2	47	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	70	150	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7 ¹⁸ 415+1 ¹⁹ 78	114	114	70	114	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12 ⁹ 78+2 ³ 1	113	113	86	95	95	96			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
**	Impoprt (Tripura)	India		160	160	96	138	138	164			
Cumilla Zone Total			3094	3034	1720	1950	2095	2262	585	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	191	139	120	140	63	Gas Shortage	
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8				Dependable cap : 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	70	185	175	200			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
82	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total			717	709	363	480	514	507	63	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.09.21 (Yesterday)		21.09.21 (Today)		20.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	51	51				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	158	160	160	160	170		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	80	78	78				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
96	Bisnana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	242	316	316	316				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	380	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total					2422	2377	1624	1664	1727	1727	256	117	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	370	395	400	400				
102	Fairdip 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	24	0	27			Line Overload	
103	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CAPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	120	230	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105				
107	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	100	100	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	715	713	729	729				
Khulna Zone Total					2133	2129	1222	1487	1609	1726	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	28	33	33				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	68	66	68	68		128	Arrival of GT2 HGPI experts delayed due to covid 19	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	22	22	22	22				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	480	622	622		764	Line Overload	
113	Potukhali 150 MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	150	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	223	223	220	220				
Barishal Zone Total					2046	2046	652	836	1225	1225	0	892	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	8	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	33	30	30				
120	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	27	27				
121	Chapsainwabarj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	94	90	94				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	19	0	30				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	0	43				
124	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	33				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	188	185	200	220	35		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	207	180	200	220				
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	398	400	400				
129	Bogra 22 MW PP (BBB)	Gas (RPP)	6x4.0	22	22	17	21	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	43	43	43				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	90	90				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	86	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2179	2179	1102	1275	1482	1626	416	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80	5		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	106	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total					655	605	157	186	201	218	5	359	
Sub-total: Plants in operation					21435	21021	10671.0	12571	13803	14620	2430	2618	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					10123	11926	13094	13870					
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
143	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	159	0	0	0	0	0	0	
Gross Total					22031	21180	10671	12571	13803	14620	2430	2618	
(C) Actual data of 20.09.21 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	: 12571.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11926.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 12571.00 MW, at = 19:00 hrs	Dhaka	4364	4364	0	Mymensingh	994	994	0			
04.	Minimum Generation (Generation end)	: 9021.00 MW, at = 7:00 hrs	Chattogram	1249	1249	0	Sylhet	555	555	0			
05.	Day-peak Generation (Generation end)	: 10671.00 MW, at = 12:00 hrs	Khulna	1393	1393	0	Barishal	311	311	0			
06.	Evening-peak Generation (Generation end)	: 12571.00 MW, at = 19:00 hrs	Rajshahi	1278	1278	0	Rangpur	700	700	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	1082	1082	0	Total	11926	11926	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9046.00 MW, at = 5:00 hrs	13.	Fuel cost : (a) Gas = 148748611 Taka (c) Coal = 55986102 Taka									
09.	Generation shortfall at evening peak due to :			(b) Oil = 546761179 Taka Total = 751495892 Taka									
a)	Gas limitation	: 2425 MW	14.	Maximum Temperature in Dhaka was : 30.8° C									
b)	Coal supply Limitation	: 5 MW	15.	Export through East-West interconnections :									
c)	Low water level in Kaptai lake	: 0 MW		At evening peak-hour : -84 MW, at 19:00 hrs									
d)	Plants under shut down/ maintenance	: 2618 MW		Maximum : -258 MW, at 23:00 hrs									
10.	Total Energy (Generation + India Import)	: 261.76 MKWh		Energy : 1.556 MKWh									
	By Gas = 148.141 MKWh	By Oil = 76.939 MKWh											
	By Coal = 12.044 MKWh	By Hydro = 3.955 MKWh											
	By Solar = 0.618 MKWh												
11.	Total Gas Supplied	: 1127.43 MCMCFD											
(D) Forecast of 21.09.21 (Today) Tuesday :													
01.	Maximum Demand	: 13200 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14620 MW (Generation end)	05.	Total Generation : 274.86 MKWh									
03.	Maximum Shortage	: -1420 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 32.1° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation