

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 954687, 9551095

Month October, 2021		Day : Saturday		Date : 09.10.21							
Probable Maximum Demand : 12800 MW		Probable Maximum Generation : 14426 MW		Rule Curve = 106.72 ft.							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 105.88 ft.		Today = 105.74 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.10.21 (Yesterday)		09.10.21 (Today)		08.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	290	310	310	126	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	212	327	300	300	33	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	303	333	305	360	79	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	331	333	335	335		
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	300	285	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	45	45		
15	Karaniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	4	37	40	40		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	102	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	18	20	20		
18	Summit Power (Madhaboli+Ashulia)	Gas (SIPP, REB)	6x3.07+3x1.73	80	80	38	55	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	90	90	90		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	115	149	149		
24	Kanailgahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	129	300	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	85	147	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	17	35	35		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	100	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0		
Dhaka Zone Total			5717	5560	2564	3236	3508	3837	761	865	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	163	160	160	160	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	120	120	60	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	46	25	50		
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	305	300	300		
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	10	82	82	82		
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	100	100	100		
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		Environment issue
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	16	16		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			13	42	10	20		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	48	85	88		
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	75	68	110	110		
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	108	116	116	116		
Chattogram Zone Total			2442	2382	883	1489	1433	1548	240	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	70	70	70	70	65	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	22	23	20	23		
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	136	137	140	140		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	285	280	300	330		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	275	270	330	330		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	30	47	55	55		
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	16	16	16	179	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
63	Ashuganj 150MW PP (Midland)	Gas (IPP)	23x7.015	150	150	117	137	135	137		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	30	85	85	85		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	116	200	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	150	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	98	98	98		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	96	95	96		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	13	17	17	17		
**	Impopt (Tripura)	India		160	160	78	118	138	164		
Cumilla Zone Total			3094	3034	1390	1778	2038	2201	507	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	136	153	160	180	49	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	106	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	35	180	170	180		
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0		
83	Tangail 22 MW PP/PPGL	HFO (IPP)	4x6.7	22	22	0	22	22	22		
Mymensingh Zone Total			717	622	339	483	541	519	49	0	

Sl. No.	Name of Power Station	Nos. of Unit	X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.10.21 (Yesterday)		09.10.21 (Today)		08.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CCGPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CCGPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	42	42	42		48			
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	50	50					
87	Kushira 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	56	60	62	10		Gas Shortage		
90	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	155	160	160	160	170		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	81					
92	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
96	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	341	341					
97	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	322	322	320	321					
98	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
Sylhet Zone Total						2422	2377	1584	1600	1642	1646	182	75	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	220	345	300	300					
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	5	25				Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				Line Overload	
104	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	120	120	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	709	708	722	726					
Khulna Zone Total						2133	2129	1066	1278	1407	1621	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	33	33					
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	0	50	65	70		144	Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	71	53	17	53					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	410	570	622	622		674	Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	0	150					
114	Bhola 220MW CCGP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	220	223	220	220					
Barishal Zone Total						2046	2046	722	984	1067	1258	0	818	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30					
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	27	27					
121	Chapsainwabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	94	90	94					
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30					
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	43					
124	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	33					
125	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	143	181	190	190	39		Gas Shortage		
127	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	155	205	200	200					
128	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	415	380	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
130	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	100	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	6	0	0					
Rajshahi Zone Total						2179	2179	884	1320	1471	1608	420	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	77	72	70	75	13			Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274		Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	40	109	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Majpara, Tabla 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total						655	605	124	181	191	188	13	359	
Sub-total: Plants in operation						21435	20934	9556.0	12349	13298	14426	2172	2532	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9145	11818	12726	13806					
(B) Plants under long term maintenance/ contract expired														
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
143	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired						596	0	0	0	0	0	0	0	
Gross Total						22031	20934	9556	12349	13298	14426	2172	2532	
(C) Actual data of 08.10.21 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	: 12349.00	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11818.00	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	MW	MW	
03.	Highest Generation (Generation end)	: 12457.00	MW, at = 22:00 hrs	Dhaka	3962	3962	0	Mymensingh	1022	1022	0			
04.	Minimum Generation (Generation end)	: 8924.00	MW, at = 9:00 hrs	Chattogram	1235	1235	0	Sylhet	489	489	0			
05.	Day-peak Generation (Generation end)	: 9556.00	MW, at = 12:00 hrs	Khulna	1539	1539	0	Barishal	370	370	0			
06.	Evening-peak Generation (Generation end)	: 12349.00	MW, at = 21:00 hrs	Rajshahi	1272	1272	0	Rangpur	699	699	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00	MW, at = 21:00 hrs	Cumilla	1230	1230	0	Total	11818	11818	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9555.00	MW, at = 5:00 hrs	13.	Fuel cost :			(a) Gas = 15017844 Taka	(c) Coal = 67944215 Taka					
09.	Generation shortfall at evening peak due to :													
a)	Gas limitation	: 2159	MW	(b) Oil = 550973613 Taka	Total = 769035672 Taka									
c)	Coal supply Limitation	: 13	MW											
b)	Low water level in Kaplai lake	: 0	MW											
c)	Plants under shut down/ maintenance	: 2532	MW											
10.	Total Energy (Generation + India Import)	: 255.60	MKWh	14.	Maximum Temperature in Dhaka was :			35.2° C						
	By Gas = 144.025	MKWh	By Oil = 72.923	MKWh										
	By Coal = 14.806	MKWh	By Hydro = 3.792	MKWh										
	By Solar = 0.612	MKWh												
11.	Total Gas Supplied	: 1124.90	MMCFD	15.	Export through East-West interconnections :									
(D) Forecast of 09.10.21 (Today) Saturday :														
01.	Maximum Demand	: 12800	MW (Generation end)	04.	Maximum Load-shed			: 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 14426	MW (Generation end)	05.	Total Generation			: 262.64 MKWh						
03.	Maximum Shortage	: -1626	MW (Generation end)	06.	Probable Max. Temperature in Dhaka			: 34.4° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation