

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month November, 2021		Day : Saturday				Date : 27.11.21					
Probable Maximum Demand :		8800 MW		Yesterday = 101.27 ft		Probable Maximum Generation :		13207 MW		Rule Curve = 106.40 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.11.21 (Yesterday)		27.11.21 (Today)		26.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasahat 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	188	272	300	300	88	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	340	343	350	350		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	150	150	150	150		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	0	0	55	55		
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	10	25	25		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	24	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	10	16	16		
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	41	53	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	149	149		
24	Kanailahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	300		
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	0	53	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	94	104	104		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	25	0	30	0		
Dhaka Zone Total			5717	5560	1486	1760	2943	3263	941	1025	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	79	76	75	75	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	17	17	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	283	300	300	300		
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	0	0	80	100		
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	14	10	100	100		
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.02	102	102	0	17	51	80		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20		Environment issue
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			30	34	10	20		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	90	90		
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	51	110	110		
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	10	0	100	100		
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	107	116	116		
Chattogram Zone Total			2442	2382	534	742	1311	1345	0	775	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	100	100	100	100	34	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	29	29	29		
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	202	184	220	220		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	270	340	340		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under maint.
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	51	55	55		
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	68	68	68	68	127	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	133	120	133		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	0	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	118	113	113		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impoprt (Tripura)	India		160	160	81	86	138	164		
Cumilla Zone Total			3094	3034	1067	1296	1832	2071	425	360	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	155	170	200	200	32	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	94	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	60	8	200	200		
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0		
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22		
Mymensingh Zone Total			717	622	282	318	611	559	32	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.11.21 (Yesterday)		27.11.21 (Today)		26.11.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42		28	GT1 Coupling problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT4 Load gear problem	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	53	50	50				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	33	33	33				
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	101	100	100	100	230		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	78	80	84				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	159	218	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	220	290	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	79	72	100	100				
Sylhet Zone Total					2422	2377	1296	1525	1622	1626	250	88	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	30				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
**	Bheramara (HVDC)	India	1000	1000	1000	633	680	645	693				
Khulna Zone Total					2133	2129	633	733	800	1288	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	25	25	25				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	65	67	68	68		127	Under maint.	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	390	620	620		854	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	161	216	220	220				
Barisal Zone Total					2046	2046	505	709	1054	1204	0	981	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27				
121	Chapsainwabarjan 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	95	95				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	20	35				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Under Overhauling	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	191	186	200	220	34		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	175	200	200	45		Gas Shortage	
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	335	354	400	400				
129	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	109	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	94	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2179	2179	763	986	1539	1658	250	210	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	80	80	80				
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	112	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
Rangpur Zone Total					655	605	82	192	201	193	0	359	
Sub-total: Plants in operation					21435	20934	6648.0	8261	11913	13207	1898	3798	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					6382	7930	11435	12678					
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0	
Gross Total					22031	20934	6648	8261	11913	13207	1898	3798	
(C) Actual data of 26.11.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	8261.00 MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	7930.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	8261.00 MW, at = 19:30 hrs	Dhaka	2801	2801	0	Mymensingh	640	640	0		
04.	Minimum Generation (Generation end)	:	6255.00 MW, at = 7:00 hrs	Chattogram	935	935	0	Sylhet	311	311	0		
05.	Day-peak Generation (Generation end)	:	6648.00 MW, at = 12:00 hrs	Khulna	959	959	0	Barisal	234	234	0		
06.	Evening-peak Generation (Generation end)	:	8261.00 MW, at = 19:30 hrs	Rajshahi	794	794	0	Rangpur	552	552	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:30 hrs	Cumilla	704	704	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5609.00 MW, at = 5:00 hrs					Total	7930	7930	0		
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :		(a) Gas = 130246451 Taka	(c) Coal = 48128691 Taka					
a)	Gas limitation	:	1898 MW				(b) Oil = 132196988 Taka	Total = 310572131 Taka					
b)	Coal supply Limitation	:	0 MW										
c)	Low water level in Kaplai lake	:	0 MW										
d)	Plants under shut down/ maintenance	:	3798 MW										
10.	Total Energy (Generation + India Import)	:	168.36 MKWh	14.	Maximum Temperature in Dhaka was :		29.6° C						
	By Gas = 118.934 MKWh		By Oil = 22.393 MKWh	15.	Export through East-West interconnections :								
	By Coal = 10.243 MKWh		By Hydro = 1.787 MKWh		At evening peak-hour :		-86 MW, at 19:30 hrs						
	By Solar = 0.617 MKWh				Maximum :		-164 MW, at 18:30 hrs						
11.	Total Gas Supplied	:	909.80 MMCFD		Energy :		0.1925 MKWh						
(D) Forecast of 27.11.21 (Today) Saturday :													
01.	Maximum Demand	:	8800 MW (Generation end)	04.	Maximum Load-shed		0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	13207 MW (Generation end)	05.	Total Generation		179.35 MKWh						
03.	Maximum Shortage	:	-4407 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :		26.9° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation