

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TFP Unit-3	PDB	1*210	190	190	446200	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	392	9412610	Machine problem
9	Haripur 360MW CCPP(HRPL)	IPP	1*235+1*125	360	336	7932000	Gas shortage
10	Meghnaghat 45 MW CCPP(MPL)	IPP	2*150+150	450	270	6631550	Gas shortage
11	Meghnaghat 100 MW(IELE)	ORPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	140	3492655	Gas shortage
13	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	288798	
15	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	24	305691	Engine problem
16	Narsinghji 22 MW PP (Doreen)	SIPP, REB	8*2.8	22	16	353556	Engine problem
17	210 MW Siddhirgonj TTP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	666000	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
20	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	102	615168	
22	Katpali 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
23	Kamalghat 54 MW PP(Banco En	IPP	3*18	54	35	836280	Engine problem
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	98	435640	Low demand.
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	406166	
26	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1094380	
27	Bosila 108MW PP(CLO)	IPP	12*8.775+1*3.5	0	0	0	
28	Summit Power (Madhadin-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	53	1236300	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	757400	
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	811900	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	51	608160	
32	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Machine problem
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	260	1410109	Low demand.
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
35	Biramhasang 100 MW PP (Aggr)	IPP	100	100	0	0	
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	132	851040	Engine problem
38	Gazipur 100 MW PP	RPCL	100 MW	105	35	190800	Low demand.
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1762560	
40	Manikganj 162MW PP(MPL)	IPP	9*18	162	162	3219840	
41	Spectra Solar Plant Ltd	IPP	35	35	35	39286	
42	Kanchan Purbachal Power Gener.	IPP	55	0	0	0	On test
Dhaka area Total			5560	2623	785	47856289	
43	Chattogram TTP-1	PDB	1*210	180	0	0	Gas shortage
44	Chattogram TTP-2	PDB	1*210	180	0	0	Gas shortage
45	Razzan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
46	Teknaf 20MW PP (SolarTech)Teknaf SolarTech Energy	IPP	20	20	0	115695	
47	Ratanra 50MW PP (Baraka)	IPP	8*6.88	50	50	858000	
48	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	62	1693942	Low water level & #2 Under
49	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	0	0	High Voltage.
52	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
53	Hathazari-Kabaila 100 MW Peakin	IPP	6*17	102	17	85743	Low demand.
54	Juldah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	0	14880	High Voltage.
55	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	50	859200	High Voltage.
56	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	494160	
57	* Malancha, Cig. EPZ (Unite)		5*8.73+3*9.34	0	6	308788	
58	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	20160	Line O/L
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	1681	
60	Amriata 300 MW PP (Unite)	IPP	300 MW	300	300	6465927	
61	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1182527	
62	Karnaphuli Power Ltd.	IPP	110	110	110	1233631	
63	Juldah unit-2 (Acorn)	IPP	8*13.6	100	10	51840	High Voltage.
64	Anilma Energy Ltd.	IPP	6*21.2	116	105	1752600	Engine problem
Chattogram area Total			2382	785	15147934		
65	Ashuganj TTP Unit-3	APSCCL	1*150	135	0	0	Gas shortage
66	Ashuganj TTP Unit-4	APSCCL	1*150	129	0	0	Gas shortage
67	Ashuganj TTP Unit-5	APSCCL	1*150	134	130	3145652	Gas shortage
68	Ashuganj 225 MW CCPP	APSCCL	1*142+1*75	221	0	0	#REF!
69	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	0	0	Under maint.
70	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	300	300	7044000	FGMO
71	Ashuganj 50 MW PP	APSCCL	14*3.968	45	29	642744	Engine problem
72	Ashuganj 55 MW PP (Precision)	IPP	15*4	55	52	1294960	Gas shortage
73	Ashuganj 195MW PP (APSCCL-UH)	IPP	20*9.73+1*116	195	180	4365818	Gas shortage
74	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1188652	
75	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	123	1326466	Engine problem
76	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	33360	Reserve.
77	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Machine problem
78	Chandpur 200MW (Doreen energy)	IPP	200	200	17	325440	High Voltage.
79	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	441540	Engine problem
80	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	232920	
81	** Impoport (Tripura)	Imported power	0	160	110	2036160	
82	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	796800	
83	Jangalia 52 MW PP (Lakdanava)	IPP	6*8.92	52	25	597322	Low demand.
84	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	9	200750	Engine problem
85	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
86	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve.
87	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	115	1711080	
88	Bhairab 54.5 MW	IPP	3*18.2	54	17	428040	33 kV feeder O/L
89	Chandpur 115(Doreen)	IPP	115	0	0	73920	On test
Cumilla Area Total			3034	1221	25875624		
90	RPCL 210MW CCPP	IPP	4*35+1*70	202	122	3269920	Gas shortage
91	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	449172	
92	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Engine problem
93	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	4600	
94	Mymensingh 200 MW PP (Unite)	IPP	200	200	24	177600	High Voltage.
95	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	115	1502400	
96	Sulakhali 50 MW Solar PP	IPP	50	50	0	189270	
97	Tangail Pali Power Gen-22 MW	IPP	4*6.7	22	24	362880	
Mymensingh Area Total			622	305	5975542		
98	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1005000	Machine problem
99	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	691081	Machine problem
100	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3428672	
101	Shajbazar 330 MW CCPP	PDB	3*110	330	241	3581000	GT-2 under maint
102	Fenchugonj 51 MW PP (Barakata)	RPP	16*2.90	51	53	1064800	
103	Fenchugonj 44MW (Energy)	RPP	12*3.35+2	0	0	0	Contract Expired
104	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	174528	
105	Shajbazar GTTP Unit- 8 & 9	PDB	2*35	66	30	781248	GT-9 under maint
106	Shajbazar 86MW PP (Shajbazar)	RPP	32*2.90	86	77	1683840	Engine problem
107	Shajbazar 100 MW GTTP	PDB	1*100	100	80	1685945	On test
108	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	198	4551740	Gas shortage
109	Sylhet 20 MW GTTP	PDB	1*20	20	18	404000	Gas shortage
110	Sylhet 50MW PP (EPL)	RPP	2*7.2	0	0	0	Contract Expired
111	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	438984	Engine problem
112	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
113	Bibiana-III 400 MW CCPP	PDB	400 MW	400	0	0	Under maint.
114	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	251100	
115	Bibiana South 400 MW	PDB	400 MW	383	400	9356900	
Sylhet Area Total			2377	1370	29112538		
116	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
117	** Bheramara (HVDC)	Imported power	2*500	1000	709	13707636	
118	Khuila 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
119	Fardipur 50 MW Peaking PP	PDB	8*6.89	50	0	0	Reserve.
120	Khuila 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
121	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	10496	Reserve.
122	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Under maint.
123	Noapara 40 MW PP (Khanjahan A	ORPP	5*8.5	0	0	0	Contract Expired
124	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	0	0	Reserve.
125	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	105	841440	
126	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Line O/L
Khuila Area Total			2128	814	14558572		
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
128	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	24	426300	Engine problem
129	Bhola 225 MW CCPP	PDB	2*63+1*68	194	65	1540000	Machine problem
130	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	11	437125	Engine problem
131	Payra 1320 MW	BCPCL	2*622	1244	400	8841900	Line O/L
132	Bhola Nutan Bidout BD LTD	IPP	220	220	205	4598536	
133	Unite Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.
Barisal Area Total			2046	705	15843861		
134	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
135	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
136	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	25	20016	Low demand.
137	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
138	Annara 50 MW PP(Sinha)	ORPP	7*7.9	50	0	0	Reserve.
139	Katakthali 50 MW PP (Northern)	ORPP	6*8.7	50	50	68848	
140	Katakthali 50 MW Peaking PP	PDB	6*8.7	50	8	4026	Low demand.
141	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	704700	Gas shortage
142	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	168	4561345	FGMO
143	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	185	4505764	FGMO
144	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1*262+1*132	414	332	9046109	FGMO
145	Santihar 50 MW Peaking PP	RPP	6*8.7	50	0	0	Engine problem
146	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	516480	
147	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
148	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	8	171540	Engine problem
149	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	342720	
150	Chapanawabganj 100 MW Peakin	PDB	12*8.924	104	20	44856	Low demand.
151	Baghabari 200 MW PP (Pearson)	IPP	200 MW	200	0	0	Reserve.
152	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	95	1396608	Engine problem
153	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	999760	
154	Sirajgonj 6.55 MW Solar</						