

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2022		Day : Saturday				Date : 15.01.22							
Probable Maximum Demand :		9300 MW				Probable Maximum Generation : 12072 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 96.45 ft		Today = 96.33 ft		Rule Curve = 100.34 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.01.22 (Yesterday)		15.01.22 (Today)		14.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :				
						Day		Evening		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	186	200	200	200				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	148	172	230	230	188		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	140	170	180	180	280		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	48	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	51	60	65	65				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	33	31	35	35				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	17	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	25	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
23	Kodda 150MW PP	HFO (BPD-RPCL)	9x17.06	149	149	0	0	150	150				
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	300	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	116	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	48	0	200	300				
28	Branhanganj 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	6	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	48	51	51				
Dhaka Zone Total				5853	5696	1826	1891	2653	2723	2325	598		
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	80	86	86	150		Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	25	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.69	50	50	25	25	25	25				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	0	300	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	30	0	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hafzazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	21	21				
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			23	42	15	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	79	92	90	90				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	51	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100				
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	100	116	116	116				
Chattogram Zone Total				2442	2382	712	772	1313	1303	510	473		
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	80	80	80	54		Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40		Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	136	150	200	200				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	290	270	330	330				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	90	90	260	260	270		Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5				
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	43	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	5	30	120				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	18	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9				
74	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.915+15x1.096	200	200	0	0	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	48	117	113	113				
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test	
**	Impopr (Tripura)	India		160	160	81	94	138	163				
Cumilla Zone Total				2944	2899	852	959	1820	2035	688	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	71	98	110	110	104		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	65	115	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	193	200	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
84	Suitakali												

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.01.22 (Yesterday)		15.01.22 (Today)		14.01.22 (Yesterday)		Status of Machines under shut-down Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x22-1x33	97	70	43	42	42	42		28	GT 1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	20	20	20	20		70	Under maint.	
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	45	51	51	51				
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	130	130	130				
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	68	70	72	72				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	113	110	110	110		220	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	79	81	81				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	24	24				
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	295	330	330				
99	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	100	400	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	959	1260	1299	1299	0	318	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220				
107	Noopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	0	60	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	29	0	16	0				
**	Bheramara (HVDC)	India		1000	1000	615	709	674	722				
Khulna Zone Total					2233	2229	661	839	905	1322	410	0	
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	26	25	25				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	93	91	91	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	400	620	620	844		Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2046	2046	641	748	1077	1227	0	844	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	44	45	45				
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	21	100	90	100				
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32				
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	43	43	43				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	176	169	180	200				
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	386	415	400	400				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	113	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total					2179	2179	846	1161	1357	1381	601	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	100	112	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
142	Majpara, Taluka 8 MW Solar PP (Sympa Powe Energygac Power Venture Thakurgaon Ltd)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					685	605	304	312	321	313	159	85	
Sub-total: Plants in operation					21521	21035	7236.0	8349	11266	12072	4797	2481	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					6968	8040	10849	11625					
(B) Plants under long term maintenance/contract expired													
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/contract expired					545	0	0	0	0	0	0	0	
Gross Total					22066	21035	7236	8349	11266	12072	4797	2481	
(C) Actual data of 14.01.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 8349.00 MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 8040.00 MW, at = 20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 8349.00 MW, at = 20:00 hrs	Dhaka	2661	2661	0	Mymensingh	785	785	0			
04.	Minimum Generation (Generation end)	: 6166.00 MW, at = 5:00 hrs	Chattoagram	856	856	0	Sylhet	317	317	0			
05.	Day-peak Generation (Generation end)	: 7236.00 MW, at = 12:00 hrs	Khulna	988	988	0	Barishal	243	243	0			
06.	Evening-peak Generation (Generation end)	: 8349.00 MW, at = 20:00 hrs	Rajshahi	876	876	0	Rangpur	579	579	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 20:00 hrs	Cumilla	735	735	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5708.00 MW, at = 5:00 hrs					Total	8040	8040	0			
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 4488 MW	13.	Fuel cost :	(a) Gas = 84693075 Taka	(c) Coal = 64032822 Taka							
	d) Coal supply Limitation	: 159 MW		(b) Oil = 412312157 Taka	Total = 561038054 Taka								
	b) Low water level in Kaptai lake	: 150 MW											
	c) Plants under shut down/ maintenance	: 2481 MW	14.	Maximum Temperature in Dhaka was :	22.4° C								
10.	Total Energy (Generation + India Import)	: 173.22 MKWh	15.	Export through East-West interconnections :									
	By Gas = 81.298 MKWh	By Oil = 59.803 MKWh		At evening peak-hour	: 220 MW, at 20:00 hrs								
	By Coal = 13.443 MKWh	By Hydro = 1.991 MKWh		Maximum	: 84 MW, at 8:00 hrs								
	By Solar= 0.469 MKWh			Energy	: 0 MKWh								
11.	Total Gas Supplied	: 699.98 MMCFD											
(D) Forecast of 15.01.22 (Today) Saturday :													
01.	Maximum Demand	: 9300 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 12072 MW (Generation end)	05.	Total Generation	: 192.95 MKWh								
03.	Maximum Shortage	: -2772 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	23.1° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation